

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 81100603051 DOC. DATE: 81/09/28 NOTARIZED: NO
 FACIL: 50-389 St. Lucie Plant, Unit 2, Florida Power & Light Co.
 AUTH. NAME: AUTH. AFFILIATION:
 OWEN, H. S. Florida, State of
 RECIP. NAME: RECIPIENT AFFILIATION:
 EISENHUT, D. G. Division of Licensing

DOCKET #: 05000389

SUBJECT: Submits Dept. of Environ. Regulation suggested changes based on review of environ. rept. Changes necessitated by plant design changes which occurred since CP was granted.

DISTRIBUTION CODE: C002S COPIES RECEIVED: LTR L ENCL ϕ SIZE: 11-11-11
 TITLE: Environ. Comments.

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTR ENCL
ACTION:	LICI BR #3 BC 06	7	NERSES, V. 05	1
INTERNAL:	ACCIDENT EVAL 19	1	EF TREAT SYS 15	1
	ENV ENG. BR 16	1	HYDRO-GEO BR 21	1
	I&EI 13	2	FIELD	1
	RADI ASSESS BR 17	1	REG. FILE	1
	SITI ANAL BR 18	1	UTIL FINANCE 20	1
EXTERNAL:	ACRS	1	LPDR 03	1
	NATL LAB 21	5	NRC PDR 02	1
	NSIC 04	1	NTIS	1

OCT 08 1980

EMU 4

TOTAL NUMBER OF COPIES REQUIRED: LTR 29 ENCL ϕ

STATE OF FLORIDA
DEPARTMENT OF ENVIRONMENTAL REGULATION

TWIN TOWERS OFFICE BUILDING
2600 BLAIR STONE ROAD
TALLAHASSEE, FLORIDA 32301



BOB GRAHAM
GOVERNOR
VICTORIA J. TSCHINKEL
SECRETARY

September 28, 1981

Mr. Darrell G. Eisenhut, Director
Division of Licensing
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, D. C. 20555

Re: St. Lucie Unit 2
Docket No. 50-389

Dear Mr. Eisenhut:


The Department of Environmental Regulation (DER) has reviewed the Environmental Report for the Operational License for Florida Power & Light Company (FPL) St. Lucie Plant Unit 2. The changes in plant design that have occurred since the construction license was granted requires that the state license be modified.

Review of the modified multiport diffuser indicated that a mixing zone must be designated for the thermal discharge pursuant to Section 17-3.05, Florida Administrative Code in order that the discharge be in compliance with the State water quality criteria. The DER proposes to designate a thermal mixing zone of 10.7 acre feet. Special Condition II A.2 will be changed to read.

2. Thermal Mixing Zone

The heated water discharged from the multiport diffuser shall not exceed 17°F above ambient outside of a thermal mixing zone of 10.7 acre-feet. The mixing zone shall be bounded by an area 1385.5 feet long extending seaward from the most landward discharge port, 21.0 feet to either side of the discharge pipe axis and 8.0 feet in height above the bottom of the discharge ports.

After consultation with the Environmental Protection Agency the DER will be modifying other conditions of certification dealing with effluent limitations, monitoring and sewage treatment as illustrated below.



*2002
5/10*

8110060305 810928
PDR ADDCK 05000389
C PDR

Mr. Eisenhut
Page Two
September 28, 1981

Condition II. B. should be modified to the following:

II.B. Chemical

Liquid wastes discharges shall not contain concentrations of pollutants ~~at the point of discharge which may be measured in the discharge canal~~ in excess of the following limitations:

1. Chlorine (Free Available Chlorine): at condenser discharge 0.2 mg/l average) 2 hr.
at end of discharge canal 0.5 mg/l maximum
0.1 mg/l maximum
2. Oil and Grease: 15 mg/l Daily average from low volume waste, pre-operational metal cleaning wastes, and radwaste discharges
3. Polychlorinated biphenyls or other polycyclic Halogenated compounds: None
4. ~~Copper~~-----20-ppb
5. 4. Boron: 4 mg/l (net)
6. ~~Cyclohexylamines~~-----0.5-mg/l
7. TSS: 30 mg/l Daily average
100 mg/l Daily Maximum
at the discharge from the low volume wastes, metal cleaning wastes and radwaste discharges

Condition III.A.1. should be modified as follows:

1. Chemical - the following parameters shall be monitored ~~in the intake and/or discharge~~ and reported to the Department quarterly:



1. The first part of the document discusses the importance of maintaining accurate records of all transactions and activities. It emphasizes the need for transparency and accountability in financial reporting.

2. The second part of the document outlines the various methods and techniques used to collect and analyze data. It includes a detailed description of the sampling process and the statistical tools employed.

3. The third part of the document presents the results of the study, showing the distribution of data points and the overall trends observed. It includes several tables and graphs to illustrate the findings.

4. The fourth part of the document discusses the implications of the results and provides recommendations for future research. It highlights the need for further investigation into certain areas and suggests potential areas for exploration.

5. The fifth part of the document concludes the study, summarizing the key findings and the overall contribution of the research. It expresses the hope that the results will be useful to other researchers and practitioners in the field.

Mr. Eisenhower
Page Three
September 28, 1981

Parameter	Sampling Location	Type of Sample	Frequency Of Sampling
Flow	** Intake	Pump Logs	hourly
Temperature	** Intake/POD	- -	hourly
pH-----*	POD-----	Grab-----	weekly
TDS-----*	POD-----	Grab-----	monthly
<u>TSS</u>	<u>Neutralization Basin</u>	<u>Composite</u>	<u>weekly</u>
Oil and Grease	POD <u>Neutralization Basin</u>	8-hour-Composite <u>Grab</u>	weekly
Dissolved-Oxygen--*	POD-----	Grab-----	weekly
Free and-Total Chlorine Residual	*-POD <u>Condenser Outlet</u>	<u>Multiple Grabs</u>	weekly during chlorination
<u>Total Chlorine Residual</u>	* POD	<u>Multiple Grabs</u>	<u>weekly during chlorination</u>
Boron	* POD	Grab	when batch discharges are required ***
Copper-----*	POD-----	Grab-----	monthly

* May be monitored in discharge canal at the location specified in III.A.2.b.

** May be monitored in intake canal (Plant Intake Structure)

*** From the refueling water storage tank and nonaerated waste hold up tanks (4).

III.A.2. Thermal - The monitoring of the thermal discharge shall be accomplished by-supplementing-the-program-required-by-the-NPDES-Permit-No.--FL0002208-for-Unit-No.-1-by-adding-two-recording-thermographs as follows:



[The text in this block is extremely faint and illegible, appearing as scattered black specks and small clusters across the page.]

Mr. Eisenhut
Page Four
September 28, 1981

- a.) At the surface of the water ~~at a point of maximum surface temperature of a~~ the discharge from Unit No. 2 the temperature shall be monitored twice annually in August and September by boat or by thermal image photography.

Condition III.B. should be modified to reflect the new biological monitoring program.

Condition VIII. should be modified as follows:

Delete existing language and replace with: Sanitary wastes shall be collected and treated in accordance with Chapter 17-6, FAC, and DER permits D056-34536 and DC56-37127 or as maybe subsequently reissued or modified.

With these changes the Department of Environmental Regulation has no objection to the issuance of an Operational License to St. Lucie No. 2.

Sincerely,

Hamilton S. Owen, Jr.
Hamilton S. Owen, Jr., P.E.
Administrator
Power Plant Siting Section

HSOjr:my

cc: Charles Kaplan, EPA
Robert Samworth, NRC

