

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8110070315 DOC. DATE: 81/09/29 NOTARIZED: NO
 FACIL: 50-389 St. Lucie Plant, Unit 2, Florida Power & Light Co.
 AUTH. NAME: UHRIG, R.E. AUTHOR AFFILIATION: Florida Power & Light Co.
 RECIP. NAME: EISENHUT, D.G. RECIPIENT AFFILIATION: Division of Licensing

DOCKET # 05000389

SUBJECT: Forwards responses to NRC requests for addl info re FSAR.
 Responses will be incorporated into FSAR amend.

DISTRIBUTION CODE: B0015 COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 6129
 TITLE: PSAR/FSAR AMDTS and Related Correspondence.

NOTES:

ACTION:	RECIPIENT ID CODE/NAME	COPIES		RECIPIENT ID CODE/NAME	COPIES	
		LTR	ENCL		LTR	ENCL
ACTION:	A/D LICENSNG	1	0	LIC BR #3 BC	1	0
	LIC BR #3 LA	1	0	NERSES, V. 04	1	1
INTERNAL:	ACCID EVAL BR26	1	1	AUX SYS BR 27	1	1
	CHEM. ENG. BR 11	1	1	CONT SYS BR 09	1	1
	CORE PERF. BR 10	1	1	EFF TR SYS BR12	1	1
	ELO	1	0	EQUIP QUAL BR13	3	3
	GEOSCIENCES 28	2	2	HUM FACT ENG 40	1	1
	HYD/GEOL BR 30	2	2	I&C SYS BR 16	1	1
	I&EI 06	3	3	IE/EPDB 35	1	1
	IE/EPLB 36	3	3	LIC GUID BR 33	1	1
	LIC QUAL BR 32	1	1	MATL ENG BR 17	1	1
	MECH ENG BR 18	1	1	MPA	1	0
	OP LIC BR 34	1	1	POWER SYS BR 19	1	1
	PROC/TST REV 20	1	1	QA BR 21	1	1
	RAD ASSESS BR22	1	1	REAC SYS BR 23	1	1
<u>REG. FILE</u> 01	1	1	SIT ANAL BR 24	1	1	
STRUCT ENG BR25	1	1				
EXTERNAL:	ACRS 41	16	16	FEMA-REP. DIV 39	1	1
	LPDR 03	1	1	NRC PDR 02	1	1
	NSIC 05	1	1	NTIS	1	1

MAY

TOTAL NUMBER OF COPIES REQUIRED: LTR 62 ENCL 57


8 1

THE UNITED STATES OF AMERICA
 DEPARTMENT OF THE ARMY
 OFFICE OF THE CHIEF OF STAFF
 WASHINGTON, D. C. 20315

MEMORANDUM FOR THE CHIEF OF STAFF
 SUBJECT: [Illegible]

1. [Illegible]

DATE	INITIALS	DESCRIPTION	STATUS	REMARKS
10/15/54	[Illegible]	[Illegible]	[Illegible]	[Illegible]
10/16/54	[Illegible]	[Illegible]	[Illegible]	[Illegible]
10/17/54	[Illegible]	[Illegible]	[Illegible]	[Illegible]
10/18/54	[Illegible]	[Illegible]	[Illegible]	[Illegible]
10/19/54	[Illegible]	[Illegible]	[Illegible]	[Illegible]
10/20/54	[Illegible]	[Illegible]	[Illegible]	[Illegible]
10/21/54	[Illegible]	[Illegible]	[Illegible]	[Illegible]
10/22/54	[Illegible]	[Illegible]	[Illegible]	[Illegible]
10/23/54	[Illegible]	[Illegible]	[Illegible]	[Illegible]
10/24/54	[Illegible]	[Illegible]	[Illegible]	[Illegible]
10/25/54	[Illegible]	[Illegible]	[Illegible]	[Illegible]
10/26/54	[Illegible]	[Illegible]	[Illegible]	[Illegible]
10/27/54	[Illegible]	[Illegible]	[Illegible]	[Illegible]
10/28/54	[Illegible]	[Illegible]	[Illegible]	[Illegible]
10/29/54	[Illegible]	[Illegible]	[Illegible]	[Illegible]
10/30/54	[Illegible]	[Illegible]	[Illegible]	[Illegible]
10/31/54	[Illegible]	[Illegible]	[Illegible]	[Illegible]



September 29, 1981
L-81-426

Office of Nuclear Reactor Regulation
Attention: Mr. Darrell G. Eisenhut, Director
Division of Licensing
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555



Dear Mr. Eisenhut:

Re: St. Lucie Unit 2
Docket No. 50-389
Final Safety Analysis Report
Requests For Additional Information

Attached are Florida Power & Light Company (FPL) responses to NRC staff requests for additional information which have not been formally submitted on the St. Lucie Unit 2 docket. These responses will be incorporated into the St. Lucie Unit 2 FSAR in a future amendment.

Very truly yours,

Robert E. Uhrig
Vice President
Advanced Systems & Technology


REU/TCG/ah

Attachments

cc: J. P. O'Reilly, Director, Region II (w/o attachments)
Harold F. Reis, Esquire (w/o attachments)

*Boal
S/11*

8110070315 810929
PDR ADDCK 05000389
A PDR



Attachment L-81-426
September 29, 1981

- A. Florida Power & Lights' Position on Purge Valve Qualification.
- B. Table 3.5-12, Allowable Ductility Factors
- C. Revision of response to questions 240.2 and 240.3
- D. Response to question 451.7

Florida Power & Lights' Position
On Purge Valve Qualification

Florida Power & Light Company commits to provide assurance of operability qualification of containment purge valves prior to power operation above 5% power.

SL2-FSAR

TABLE 3.5-12

ALLOWABLE DUCTILITY FACTORS (μ)

	<u>μ</u>
I. Reinforced Concrete	
a - Flexure (beams)	$\frac{0.10}{P - P'} \leq 10$
b - Flexure (slabs)	$\frac{0.10}{P - P'} \leq 30$
c - Compression (walls & columns)	1.3
d - Shear (beams & slabs)	
shear carried by concrete only	1.0
shear carried by concrete/stirrups	1.3
shear carried completely by stirrups	3.0

II. Structural Steel

a - Flexure (beams) 10

b - Shear (beams) 1

c - Axial compression (columns) 1

$$P = \frac{As}{bd}$$

$$P' = \frac{As'}{bd}$$

where:

As = area of tension reinforcement

As' = area of compression reinforcement

b = width of sections

d = depth of section to centerline of reinforcement

Question No.240.2
(3.4)

The Safety Evaluation Report (Construction Permit Stage) states that stoplog closures are to be provided to protect the entrances to safety related structures up to elevation +22 ft. MLW. Stoplog closures on the entrances of the Reactor Auxiliary Building and the Fuel Handling Building are shown in Figures 1.2-13 and 1.2-16 of the FSAR. However, they are not discussed or described in other sections of the FSAR dealing with flood protection.

State whether the stoplogs will be provided. If not, justify that they are not needed. Provide analyses of wave runup at all entrances below elevation +22 MLW.

If the stoplogs are to be installed, provide:

- a) the bottom elevation of the door openings and the dimensions of the openings secured by the stoplogs.
- b) the time required to place the stoplogs into position.
- c) the criteria to be used to determine when and if the stoplogs are to be placed into position.
- d) a discussion of the relevant technical specifications.

Response

Based upon PMF high water elevation 17.2 ft mean low water (MLW) wave runup elevation 16.0 ft MLW and plant island elevation 18.5 ft MLW, flood protection stoplogs at entrances (whose minimum elevation is at least + 19.5 feet) to safety-related buildings are not deemed necessary. Additional wave runup protection is provided to the entrances of the Fuel Handling Building and Reactor Auxiliary Building by the presence of adjacent buildings and structures (see Enlarged Site Plot Plan FSAR Figure 1.2-2). Since no permanent structures are located on the south side of the Reactor Auxiliary Building, additional wave runup protection will be provided by installing stoplogs in the entrance on the south wall and the southern most entrance on the east wall.

~~Inspection of the highway and dunes for breaching or erosion will be done periodically and aerial photographs of the beach and the dune areas will be taken once a year. In the Unit 2 Technical Specification for dunes are deleted.~~

A description of the stoplogs found at St. Lucie Unit 2 is contained in revised Subsection 3.4.1.

Question No.

240.3

(2.4.13)

Discuss the hydrologic technical specification explaining measures to be used to monitor the existing beach dunes and mangrove areas which are relied upon for hurricane protection. Provided the following information:

- (a) the means by which storm erosion will be measured and the frequency of such surveys.
- (b) the means by which the mangrove areas will be monitored to identify blighted areas and the frequency of such surveys.

Response

Beach dunes and mangroves areas are not relied upon to provide protection from hurricanes. As discussed in Subsection 2.4.5, the dunes are conservatively assumed to be eroded to an elevation of +4 feet MLW prior to computing the maximum possible quantities of erosion from Highway AIA and the plant island. No credit is taken for the energy dissipated or the time consumed in erosion of the dunes. Since the "stable base plain" elevations of +4 feet MLW to the east and south of the plant island and elevation +5 MLW on the north are the natural ground elevations of extensive flat areas, their viability is not dependent on the existence of the mangroves. In the wave analysis Subsection 2.4.5, no reduction of wave height or energy by the mangroves is assumed.

No FSAR change required.

A visual inspection of the highway and dunes for breaching or erosion will be done periodically and aerial photographs of the beach and the dune areas will be taken once a year if the unit 1- Technical Specification for mangroves are deleted.

