REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:811(0270039- DOC.DATE: 81/10/20 NOTARIZED: NO	DOCKET #
FACIL:50-335 St.	Lucie Plant, Unit 1, Florida Power & Light Co.	05000335
AUTH, NAMEI	AUTHOR AFFILIATION	4 • ,
UHRIG, R.EL	Florida Power & Light Co.	
RECIP. NAMEL	RECIPIENT AFFILIATION	1
EUSENHUTHD.G.	Division of Licensing	

SUBJECT:: Forwards: minor(corrections: to 810723 analysis; for main: steam) line break event.Conclusions: remain valid.

NOTES:

. .

	RECIPIENT: IO CODE/NAM	21	COPIA LTTR	ES Encli	RECIPIENT ID CODE/NAM	1E:	COPI Littri	ES Encli
ACTION::	0R31 #3 BCI	01	13	13		-	_	
INTERNAL	ELO		1	0	I&E	Q6 ⁴	2	2
	NRRVDHFS DEP	Y08	1	1	NRR/DL DIR		1	1
_	OR ASSESS BR		1	0	RAD ASMT BR		1	1.
\leq	REG. FILE	04	1 "	1				
EXTERNAL:	ACRS	09.	16'	16	LPDR	03.	1.	1<
	NRCI PDRI	02!	1	1	NSICI	05°	1	1.
	NTIS		1	1				

µА 4

oct 29 1831

TOTAL NUMBER OF COPIES REQUIRED: LITR 41 ENCL: 39

A PRI STATUS ST STATUS STA

ма продокти и продокти Продокти и пр Продокти и пр

• •



Office of Nuclear Reactor Regulation Attention: Mr. Darrell G. Eisenhut, Director Division of Licensing U. S. Nuclear Regulatory Commission Washington DC 20555

Dear Mr. Eisenhut:

Re: St. Lucie Unit 1 Docket No. 50-335 Main Steam Line Break Analysis

The purpose of this letter is to forward minor corrections to the analysis for the St. Lucie Unit 1 Main Steam Line Break event (Reference 1).

Vendor quality assurance checks on the results previously forwarded revealed that a non-conservative calculational value of 0.85 was used for the Doppler Coefficient multiplier and that Beginning-of-Cycle Doppler feedback data had been used rather than End-of-Cycle values as had been indicated in Reference 1.

Reanalysis has been performed using a more conservative multiplier value of 1.15 and End-of-Cycle Doppler feedback data. The magnitude of both the predicted return to power and the maximum core reactivity peaks increased but remained inside established safety criteria. Therefore, the conclusions presented in Reference 1 remain valid.

The attached tables correct the list of parameters and the sequence of events previously forwarded. These tables supersede Table 7.3.2-3 and 7.3.2-4 of Reference 1. Values changed by reanalysis are indicated by vertical lines.

Very truly yours,

2 E. VEnelfor

Robert E. Uhrig Vice President Advanced Systems & Technology

REU/WEW/jc

cc: Mr. J. P. O'Reilly, Region II Harold F. Reis, Esquire



REFERENCES

(1) FPL letter L-81-306, "Proposed License Amendment to Facility Operating License DPR-67; Shutdown Margin, Main Steam Isolation System Changes, and Control Element Assembly Sleeving", dated July 23, 1981. ì

• х . : • · · ·

.

. .

.

.

TABLE 7:3:2-3

KEY PARAMETERS ASSUMED IN THE STEAM LINE RUPTURE ANALYSIS 2-LOOP, NO LOAD

Parameter .	<u>Units</u>	Reference Cycle*	Cycle 5
Initial Core Power	MWt .	1.0	1.0
Initial Core Inlet Temperature	°F	532	532
Initial RCS Pressure	psia	2300 .	· 2300
Initial Steam Generator Pressure	psia ,	900	900
Minimum CEA Worth Available at Trip	%∆р	-4.3	-5.0
Doppler Multiplier		1.15	1.15
Moderator Cooldown Curve	%∆p vs. density	See Figure 7.3.2-10	See Figure 7.3.2-10
Inverse Boron Worth	ΡΡΜ/%Δρ	100	80
Effective Full Power MTC \cdot	10 ⁴ 4p/°F	-2.5	-2.2
ß Fraction (including uncertainty)	, ,	.0060	.0060

.*Cycle 4 stretch power submittal

¢

ł.

1.2

,

•

• 'n

. •

•

•

•

TABLE 7.3.2-4

:

SEQUENCE OF EVENTS FOR STEAM LINE RUPTURE EVENT WITH AUTOMATIC INITIATION OF AUXILIARY FEEDWATER AND MANUAL TRIP OF REACTOR COOLANT PUMPS 2-LOOP, NO LOAD

<u>Time (sec)</u>	Event	Setpoint or Value
0.0	Steam Line Rupture Occurs	
2.5	Low Steam Generator Pressure Trip Signal Occurs	578.0 psia
2.5	Main Steam Isolation Signal Generated	<i>5</i> 78.0 psia
3.4	Main Steam Isolation Valves Begin to Close	,
3.4	Trip Breakers Open	
3.9	CEAs Begin to Drop Into Core	
9.3	Main Steam Isolation Valves Completely Closed	
10.4	Pressurizer Empties	·
12.4	Safety Injection Actuation Signal	1578.0 psia
12.4	Reactor Coolant Pumps Manually Tripped	
42.4	High Pressure Safety Injection Pumps Start	
64.0	Main Feedwater Isolation	
180.0	Affected Steam Generator Blows Dry	
180.1	Auxiliary Feedwater Flow Initiated to Ruptured Steam Generator	183 lbm/sec
305.0	Peak Reactivity	+ . 290%Δρ
524.0	Return to Power	2.5% of rated power
600.0	Operator Isolates Ruptured Steam Generator and Terminates Auxiliary Feedwater Flow	

•

La La

• ,

.

ų

, •

٩

•

,

0

· · · · · · ·

.

.