



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

FLORIDA POWER & LIGHT COMPANY

DOCKET NO. 50-335

ST: LUCIE PLANT, UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 49
License No. DPR-67

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The applications for amendment by Florida Power and Light Company (the licensee) dated February 9, 1979 (as supplemented January 19, 1981) and February 21, 1979 comply with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the applications, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

8204220511 820412
PDR ADOCK 05000335
PDR



10

10

2. Accordingly, Facility Operating License No. DPR-67 is amended by changes to the Technical Specifications as indicated in the Attachment to this license amendment, and:

A. Revise paragraph 2.C(2) to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 49, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

B. Delete in its entirety Condition Q of Enclosure 1 appended to the license.

3. The license amendment is effective as of the date of its issuance.

FOR THE U. S. NUCLEAR REGULATORY COMMISSION



Robert A. Clark, Chief
Operating Reactors Branch #3
Division of Licensing

Attachement:
Changes to the Technical
Specifications

Date of Issuance: April 12, 1982

ATTACHMENT TO LICENSE AMENDMENT NO. 49

FACILITY OPERATING LICENSE NO. DPR-67

DOCKET NO. 50-335

Replace the following pages of the Appendix "A" Technical Specifications with the enclosed pages. The revised pages are identified by Amendment number and contain vertical lines indicating the area of change. The corresponding overleaf pages are also provided to maintain document completeness.

Pages

3/4 3-16

3/4 3-17

3/4 6-16b

TABLE 3.3-4 (Continued)ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION TRIP VALUES

<u>FUNCTIONAL UNIT</u>	<u>TRIP VALUE</u>	<u>ALLOWABLE VALUES</u>
6. LOSS OF POWER		
4.16 kv Emergency Bus Undervoltage (Undervoltage relays)	≥ 3307 volts	≥ 3307 volts
7. AUXILIARY FEEDWATER	$\geq 30\%$ level	$\geq 30\%$ level

TABLE 3.3-5

ENGINEERED SAFETY FEATURES RESPONSE TIMES

<u>INITIATING SIGNAL AND FUNCTION</u>	<u>RESPONSE TIME IN SECONDS</u>
1. <u>Manual</u>	
a. SIAS	
Safety Injection (ECCS)	Not Applicable
Containment Fan Coolers	Not Applicable
Feedwater Isolation	Not Applicable
Containment Isolation	Not Applicable
b. CSAS	
Containment Spray	Not Applicable
c. CIS	
Containment Isolation	Not Applicable
Shield Building Ventilation System	Not Applicable
d. RAS	
Containment Sump Recirculation	Not Applicable
e. MSIS	
Main Steam Isolation	Not Applicable
Feedwater Isolation	Not Applicable
2. <u>Pressurizer Pressure-Low</u>	
a. Safety Injection (ECCS)	$\leq 30.0^*/19.5^{**}$
b. Containment Isolation ***	$\leq 30.5^*/20.5^{**}$
c. Containment Fan Coolers	$\leq 30.0^*/17.0^{**}$
d. Feedwater Isolation	≤ 60.0

CONTAINMENT SYSTEMS

SPRAY ADDITIVE SYSTEM

LIMITING CONDITION FOR OPERATION

3.6.2.2 The spray additive system shall be OPERABLE with:

- a. A spray additive tank containing a volume of between 4010 and 5000 gallons of between 30 and 32% by weight NaOH solution, and
- b. Two spray additive eductors each capable of adding NaOH solution from the chemical additive tank to a containment spray system pump flow.

APPLICABILITY: MODES 1, 2 and 3.*

ACTION:

With the spray additive system inoperable, restore the system to OPERABLE status within 72 hours or be in at least HOT STANDBY within the next 6 hours; restore the spray additive system to OPERABLE status within the next 48 hours or be in COLD SHUTDOWN within the following 30 hours.

SURVEILLANCE REQUIREMENTS

4.6.2.2 The spray additive system shall be demonstrated OPERABLE:

- a. At least once per 31 days by verifying that each valve (manual, power operated or automatic) in the flow path that is not locked, sealed, or otherwise secured in position, is in its correct position.
- b. At least once per 6 months by:
 1. Verifying the contained solution volume in the tank, and
 2. Verifying the concentration of the NaOH solution by chemical analysis.
- c. At least once per 18 months, during shutdown, by verifying that each automatic valve in the flow path actuates to its correct position on a CSAS test signal.

*Applicable when pressurizer pressure is $\geq$ 1750 psia.

CONTAINMENT SYSTEMS

SPRAY ADDITIVE SYSTEM

SURVEILLANCE REQUIREMENTS (Continued)

- d. At least once per five years by verifying a sodium hydroxide (NaOH) flow rate of + gpm from the spray additive tank to a drain connection immediately downstream of the tank outlet valve, and a demineralized water flow rate of + gpm from that same drain connection to each containment spray pump. (Flow rates and tolerances for each of these two sources will be provided within six months following restart from the 1983 refueling outage.)

TABLE 3.3-5 (Continued)

ENGINEERED SAFETY FEATURES RESPONSE TIMES

<u>INITIATING SIGNAL AND FUNCTION</u>	<u>RESPONSE TIME IN SECONDS</u>
3. <u>Containment Pressure-High</u>	
a. Safety Injection (ECCS)	$\leq 30.0^*/19.5^{**}$
b. Containment Isolation***	$\leq 30.5^*/20.5^{**}$
c. Shield Building Ventilation System	$\leq 30.0^*/14.0^{**}$
d. Containment Fan Coolers	$\leq 30.0^*/17.0^{**}$
e. Feedwater Isolation	≤ 60.0
4. <u>Containment Pressure--High-High</u>	
a. Containment Spray	$\leq 30.0^*/18.5^{**}$
5. <u>Containment Radiation-High</u>	
a. Containment Isolation***	$\leq 30.5^*/20.5^{**}$
b. Shield Building Ventilation System	$\leq 30.0^*/14.0^{**}$
6. <u>Steam Generator Pressure-Low</u>	
a. Main Steam Isolation	≤ 6.9
b. Feedwater Isolation	≤ 60.0
7. <u>Refueling Water Storage Tank-Low</u>	
a. Containment Sump Recirculation	≤ 91.5
8. <u>Steam Generator Level</u>	
a. Auxiliary Feedwater	$\geq 180, \leq 600$

TABLE NOTATION

* Diesel generator starting and sequence loading delays included.

** Diesel generator starting and sequence loading delays not included.
Offsite power available.

***Not applicable to containment isolation valve I-MV-18-1.

TABLE 4.3-2

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>FUNCTIONAL UNIT</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL CALIBRATION</u>	<u>CHANNEL FUNCTIONAL TEST</u>	<u>MODES IN WHICH SURVEILLANCE REQUIRED</u>
1. SAFETY INJECTION (SIAS)				
a. Manual (Trip Buttons)	N.A.	N.A.	R	N.A.
b. Containment Pressure - High	S	R	M	1, 2, 3
c. Pressurizer Pressure - Low	S	R	M	1, 2, 3
d. Automatic Actuation Logic	N.A.	N.A.	M(1)	1, 2, 3
2. CONTAINMENT SPRAY (CSAS)				
a. Manual (Trip Buttons)	N.A.	N.A.	R	N.A.
b. Containment Pressure -- High - High	S	R	M	1, 2, 3
c. Automatic Actuation Logic	N.A.	N.A.	M(1)	1, 2, 3
3. CONTAINMENT ISOLATION (CIS)				
a. Manual (Trip Buttons)	N.A.	N.A.	R	N.A.
b. Containment Pressure - High	S	R	M	1, 2, 3
c. Containment Radiation - High	S	R	M	1, 2, 3, 4
d. Automatic Actuation Logic	N.A.	N.A.	M(1)	1, 2, 3
e. SIAS	N.A.	N.A.	R	N.A.
4. MAIN STEAM LINE ISOLATION (MSIS)				
a. Manual (Trip Buttons)	N.A.	N.A.	R	N.A.
b. Steam Generator Pressure - Low	S	R	M	1, 2, 3
c. Automatic Actuation Logic	N.A.	N.A.	M(1)	1, 2, 3
5. CONTAINMENT SUMP RECIRCULATION (RAS)				
a. Manual RAS (Trip Buttons)	N.A.	N.A.	R	N.A.
b. Refueling Water Storage Tank - Low	S	R	M	1, 2, 3
c. Automatic Actuation Logic	N.A.	N.A.	M(1)	1, 2, 3