

22
2/5

UNIT II
OFF NORMAL & EMERGENCY OPER. PROCEDURE

DOCUMENT REVISION DISTRIBUTION SHEET

DOCUMENT TITLE: OFF-NORMAL OPERATION OF THE COMPONENT Cooling Water Process Monitors A&B

DOCUMENT FILE NUMBER 2-1110036

DOCUMENT REVISION NUMBER 0

DOCUMENT DISTRIBUTED ON 7-14-82 DATE

DOCUMENT SENT TO:

2

COPY NO.	DOCUMENT HOLDER	TRANSMITTAL RETURNED	COPY NO.	DOCUMENT HOLDER	TRANSMITTAL RETURNED
	MASTER			<u>UNCONTROLLED COPIES</u>	
1	D. A. Sager			NRC - Region II	
2				Attn: EPSS Branch Chief	
3				H. Paduano - GO	
4				A. W. Bailey	
5	N. G. Roos			G. Anglehart - CE	
6	RSC				
7					
8					
9					
10	Watch Engineers II			G. Regal	
11				John Holwell-Backfield	
12				Training - Larry Baker	
13					
14					
15	Training			J. Spodick	
				T. Vogan - GO	
				G. J. Boissy	
				R. R. Jennings	
				H. M. Mercer	
				A. Pell	
				R. J. Frechette	
				Resident NRC	
				NRC - EE: HQ	
				Attn: Chief, Nuclear Response Branch	
				C. Buras - CE	

PROCESSED BY: _____ DATE _____



11
12
13

FLORIDA POWER & LIGHT COMPANY
ST. LUCIE PLANT UNIT NO. 2
OFF-NORMAL OPERATING PROCEDURE NO. 2-1110036
REVISION 0

1. TITLE: OFF-NORMAL OPERATION OF THE COMPONENT COOLING WATER PROCESS MONITORS A & B
2. PREPARED BY: Bill Kelsey 5/23 1982
3. SUBCOMMITTEE REVIEW BY: P. P. Luchetti for FP&L 5/27 1982
4. REVIEWED BY FRG ON: June 9 1982
5. APPROVED BY: C. M. Witting Plant Manager 6-9-1982
6. REVISION REVIEWED BY FRG ON: _____ 19____
7. APPROVED BY: _____ Plant Manager _____ 19____

FLORIDA POWER & LIGHT COMPANY
ST. LUCIE PLANT UNIT NO. 2
OFF-NORMAL OPERATING PROCEDURE NO. 2-1110036
REVISION 0

2

1.0 TITLE:

OFF-NORMAL OPERATION OF THE COMPONENT COOLING WATER PROCESS
MONITORS A & B

2.0 REVIEW AND APPROVAL:

Reviewed by Facility Review Group		JUNE 9 19 82	
Approved by <u>J. F. Barron</u>	Plant Manager	<u>June 9 19 82</u>	
Revision _____	Reviewed by FRG _____	_____ 19	
Approved by _____	Plant Manager _____	_____ 19	

3.0 PURPOSE AND DISCUSSION:

3.1 Purpose

This procedure only provides instruction in the off-normal operation of the Component Cooling Water Process Monitors. It does not provide instructions for corrective action for the C.C.W. systems. These are covered by Off-Normal Operating Procedure 2-0310031, C.C.W. - EXCESSIVE ACTIVITY.

3.2 Discussion

The C.C.W. process monitors are designed to provide an indication of the radioactivity in either HEADER, and to alarm when the radioactivity reaches or exceeds the alarm setpoint. Radioactive in leakage could occur at:

- 3.2.1 Letdown Heat Exchangers
- 3.2.2 Sampling System Heat Exchangers
- 3.2.3 Shutdown Cooling Heat Exchangers
- 3.2.4 Contaminated Make Up Water

4.0 SYMPTOMS:

- 4.1 Visual and audible alarms on the Control Room RMS safety cabinets and the three (3) system Operators Terminals.
- 4.2 Respective channel ALERT, HIGH, or FAIL alarms.
- 4.3 Increasing activity as noted on the respective channel recorders and on the channel graphic display histograms.

FOR INFORMATION ONLY

This document is not controlled. Before use,
verify information with a controlled document.

ST. LUCIE UNIT 2
OFF-NORMAL OPERATING PROCEDURE NO. 2-1110036, REVISION 0
OFF-NORMAL OPERATING OF THE COMPONENT COOLING WATER
PROCESS MONITORS A AND B

2

5.0 INSTRUCTIONS:

5.1 Immediate Automatic Action

5.1.1 The CCW surge tank vent valve (RCV-14-1) diverts from atmosphere and realigns to the chemical drain tank upon actuation of a HIGH or FAIL alarm.

5.2 Immediate Operator Action

5.2.1 Acknowledge the alarm(s) and notify the Chemistry Department.

5.3 Subsequent Operator Action

5.3.1 The CCW A & B headers are normally operated in a cross-connected mode through the "N" header isolation valves. A leak on either header should result in a trend increase in the other header. Check the CCW radiation monitor recorder trace.

5.3.2 Verify that the CCW surge tank vent valve is aligned to the Waste Management System.

5.3.3 Consult Off-Normal Operating Procedure 2-0310031, CCW Excessive Activity.

5.3.4 For an energized Fail alarm, the channel should be considered out of service. Consult the Plant technical specifications and notify responsible personnel to effect repairs. Note that when the system is operated in the cross-connected mode (see 5.3.1), radiation monitoring capability is achieved via the other CCW rad monitor.

6.0 REFERENCES:

6.1 FSAR Section 11.5.2.2.1

6.2 General Atomic Company Technical Manuals

6.3 PSL Technical Specifications

7.0 RECORDS REQUIRED:

7.1 Normal Log Entries