

September 3, 1982
L-82-397

Office of Nuclear Reactor Regulation
Attention: Darrell G. Eisenhut, Director
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Dear Mr. Eisenhut:

Re: St. Lucie Units 1 and 2
Docket Nos. 50-335 and 50-389
Emergency Preparedness Open Items

As requested during our telephone conversation with the Division of Emergency Preparedness on August 27, 1982, Florida Power & Light Company would like to clarify the following items regarding emergency preparedness and planning:

1. Emergency Action Levels (Table 3-1 of the St. Lucie Plant Radiological Emergency Plan).
 - a. Add the requirement to declare the appropriate level of emergency if chemistry analysis results are not reported to the Nuclear Plant Supervisor within one hour following an alarm on liquid or gaseous waste monitors (Unusual Event and Alert levels under "Fuel Element Failures" and Unusual Event level under "Uncontrolled Effluent Release").
 - b. Add an EAL addressing leaking or partially open relief valves under the Unusual Event level.
 - c. Add an EAL addressing the use of the containment high range radiation monitor in declaring a General Emergency.

2. Staffing Augmentation (Table 2-2a of the St. Lucie Plant Radiological Emergency Plan)

We will revise Table 2-2a to reflect our commitments in our letter of July 22, 1982, serial L-82-303 (R.E. Uhrig to J.P. O'Reilly).

3. Unannounced Drills (Section 7 of the St. Lucie Plant Radiological Emergency Plan)


We will expand the description of drills in our Emergency Plan such that it is clear that fire drills, medical drills, and accountability drills are unannounced when conducted in conjunction with annual exercises.

X005

Re: St. Lucie Units 1 and 2
Docket Nos. 50-335 and 50-389
Emergency Preparedness Open Items

- We will incorporate the changes described above and those committed to in our previous letter to you on Emergency Action Levels (L-82-368 dated August 24, 1982) in the next revision to our Emergency Plan which will be completed by December 31, 1982.

Very truly yours, ...



Robert E. Uhrig
Vice President
Advanced Systems and Technology

REU/JJM/mbd

cc: Mr. J.P. O'Reilly, Region II
Harold F. Reis, Esquire
Brain K. Grimes