



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

FLORIDA POWER & LIGHT COMPANY

DOCKET NO. 50-335

ST. LUCIE PLANT, UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 53
License No. DPR-67

1. The Nuclear Regulatory Commission (the Commission) has found that:

- A. The application for amendment by Florida Power and Light Company (the licensee) dated June 28, 1982 complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
- B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
- C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
- D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
- E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

DESIGNATED ORIGINAL

Certified By

Patricia J. Noxon

B210250050 820921
PDR ADDCK 05000335
PDR

2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the Attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-67 is hereby amended to read as follows: -

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 53, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. The license amendment is effective as of the date of its issuance:

FOR THE U.S. NUCLEAR REGULATORY COMMISSION



Robert A. Clark, Chief
Operating Reactors Branch #3
Division of Licensing

Attachment:
Changes to the Technical
Specifications

Date of Issuance: September 21, 1982

ATTACHMENT TO LICENSE AMENDMENT NO. 53

FACILITY OPERATING LICENSE NO. DPR-67

DOCKET NO. 50-335

- Replace the following pages of the Appendix "A" Technical Specifications with the enclosed pages. The revised pages are identified by Amendment number and contain vertical lines indicating the area of change. The corresponding overleaf pages are also provided to maintain document completeness.

Pages

8-4

8-5

8-6

ELECTRICAL POWER SYSTEM

SURVEILLANCE REQUIREMENTS (Continued)

4.8.1.1.2 Each diesel generator set shall be demonstrated OPERABLE:

- a. At least once per 31 days on a STAGGERED TEST BASIS by:
 1. Verifying the fuel level in the engine-mounted fuel tank.
 2. Verifying the fuel level in the fuel storage tanks.
 3. Verifying the fuel transfer pump can be started and transfers fuel from the storage system to the engine-mounted tank.
 4. Verifying the diesels start from ambient condition.
 5. Verifying the generator is synchronized, loaded to ≥ 1300 kw, and operates for ≥ 60 minutes.
 6. Verifying the diesel generator set is aligned to provide standby power to the associated emergency busses.
- b. At least once per 31 days by verifying that a sample of diesel fuel from the fuel storage tank is within the acceptable limits specified in Table 1 of ASTM D975-68 when checked for viscosity, water and sediment.
- c. At least once per 18 months during shutdown by:
 1. Subjecting the diesels to an inspection in accordance with procedures prepared in conjunction with its manufacturer's recommendations for this class of standby service.
 2. Verifying the generator capability to reject a load of ≥ 600 hp without tripping.
 3. Simulating a loss of offsite power in conjunction with a safety injection actuation signal, and:
 - a) Verifying de-energization of the emergency busses and load shedding from the emergency busses.
 - b) Verifying the diesels start from ambient condition on the auto-start signal, energize the emergency busses with permanently connected loads, energize

ELECTRICAL POWER SYSTEMS

SURVEILLANCE REQUIREMENTS (Continued)

the auto-connected emergency loads through the load sequencing system and operate for ≥ 5 minutes while the generator is loaded with the emergency loads.

- c) Verifying that on the safety injection actuation signal, all diesel generator trips, except engine overspeed and generator differential, are automatically bypassed.
- 4. Verifying the diesel generator set operates for ≥ 60 minutes while loaded to ≥ 3500 kw.
- 5. Verifying that the auto-connected loads to each diesel generator set do not exceed the 2000 hour rating of 3730 kw.
- 6. Verifying that the automatic sequence timers are OPERABLE with the interval between each load block within ± 1 second of its design interval.
- d. At least once per 18 months by verifying that each fuel transfer pump transfers fuel from each fuel storage tank to the engine mounted fuel tanks on each diesel via the installed cross connection lines.

4.8.1.1.3 The Class IE underground cable system shall be demonstrated OPERABLE within 30 days after the movement of any loads in excess of 80% of the ground surface design basis load over the cable ducts by pulling a mandrel with a diameter of at least 80% of the duct's inside diameter through a duct exposed to the maximum loading (duct nearest the ground's surface) and verifying that the duct has not been damaged.

THIS PAGE INTENTIONALLY LEFT BLANK

THIS PAGE INTENTIONALLY LEFT BLANK

ST. LUCIE - UNIT 1

3/4 8-6

Amendment No. 53