

Docket No.: 50-389

OCT 27 1982

APPLICANT: Florida Power and Light Company, (FP&L)

FACILITY: St. Lucie Plant, Unit 2

SUBJECT: SUMMARY OF MEETING HELD IN BETHESDA, MARYLAND WITH FP&L ON  
OCTOBER 12, 1982 REGARDING CLOSE-OUT OF PLANT SYSTEMS BRANCH  
ISSUES

A meeting was held on October 12, 1982 between the NRC and FP&L to discuss the seven open items which resulted from a site visit conducted on 8/30/82 by the Power Systems Branch. For reference, a copy of the site visit trip report describing the seven items is attached. The following is the resolution to these items.

1. FP&L will revise the drawing to show where barriers should be installed for conduits and cable trays. These drawings will be completely revised by 12/30/82. FP&L will submit information summarizing how they are going to do this. NRC staff will verify installation of the barriers.
2. Item 2 in the audit report was just an observation and did not require any FP&L action.
3. Additional information will be provided referencing the St. Lucie 2 Quality Instruction which will require the proper numerical identification of cable trays. This will be submitted by 10/22/82.
4. Additional Information will be furnished which will list the results of the revised calculations for PP 247. FP&L will also submit a brief description and revised drawings. This will be submitted by October 15, 1982.
5. Additional information will be submitted explaining how the circuitry works and how the test is performed. This will be submitted by 10/22/82. An additional Tech Spec is not required because it was agreed that the present TS contains the information.
6. Additional information will be submitted explaining why FP&L will not meet Reg. Guide 1.108 Position "1.b.5". This will be submitted by 10/22/82.

8211120182 821027  
PDR ADDCK 05000389  
A PDR

OFFICE							
SURNAME							
DATE							



Meeting Summary

- 2 -

7. This item is presently on hold. FP&L proposed a cage be placed around transformers. PSB will review this proposal and provide a response by 10/22/82.

Original Signed By:

*for* *V. W. Knighton*  
Victor Nerses, Project Manager  
Licensing Branch No. 3  
Division of Licensing

Enclosures:

1. List of Attendees
2. Site Visit Summary

cc w/enclosures:

See next page

OFFICE	DL:LB#3	DL:LB#3					
SURNAME	V. W. Knighton	G. Knighton					
DATE	10/22/82	10/27/82					



Dr. Robert E. Uhrig, Vice President  
Advanced Systems and Technology  
Florida Power & Light Company  
P. O. Box 5291000  
Miami, Florida 33152

Harold F. Reis, Esq.  
Lowenstein, Newman, Reis, Axelrad & Toll  
1025 Connecticut Avenue, N.W.  
Washington, D. C. 20036

Norman A. Coll, Esq.  
Steel Hector & Davis  
1400 Southeast First National  
Bank Building  
Miami, Florida 33131

Mr. Martin H. Hodder  
1131 N. E. 86th Street  
Miami, Florida 33138

Resident Inspector  
St. Lucie Nuclear Power Station  
c/o U. S. Nuclear Regulatory Commission  
7900 South A1A  
Jensen Beach, Florida 33457

Regional Administrator - Region II  
U. S. Nuclear Regulatory Commission  
101 Marietta Street  
Suite 3100  
Atlanta, Georgia 30303

ATTENDEES

Name

Organization

George Attarian  
Robert Sweeney  
Maiton Banger  
Wayne Thundgren  
Wolfgang Hehler  
Erroll Dotson  
J. Knight  
O. Chopra  
D. Hoffman  
P. Carrier  
E. Zuchman  
J. Franklin  
V. Nerses

Ebasco  
Ebasco  
Ebasco  
Ebasco  
FP&L  
FP&L  
NRC/NRR  
NRC/NRR  
NRC/NRR  
FP&L/Licensing  
Ebasco  
FP&L  
NRC/NRR