

REGULATOR INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:8208170193 DOC DATE: 82/08/12 NOTARIZED: NO DOCKET #
 FACIL:50-339 North Anna Power Station, Unit 2, Virginia Electric & 05000339
 AUTH.NAME AUTHOR AFFILIATION
 LEASBURG,R.H. Virginia Electric & Power Co.
 RECIP.NAME RECIPIENT AFFILIATION
 DENTON,H.R. Office of Nuclear Reactor Regulation, Director
 CLARK,R.A. Operating Reactors Branch 3

SUBJECT: Provides suppl to evaluation of RCS piping thermal sleeves.
 Util proposed alternative would be to detect damaged or
 leaking thimble by increasing testing to verify operability
 of incore detector leakage detection sys.

DISTRIBUTION CODE: A001S COPIES RECEIVED:LTR 1 ENCL 1 SIZE: 1
 TITLE: General Distribution for after Issuance of Operating License

NOTES:

	RECIPIENT ID CODE/NAME		COPIES		RECIPIENT ID CODE/NAME		COPIES	
	ORB #3 BC	01	LTR	ENCL			LTR	ENCL
INTERNAL:	ELD/HDS4		1	0	NRR/DHFS DEPY08		1	1
	NRR/DL DIR		1	1	NRR/DL/ORAB		1	0
	NRR/DSI/RAB		1	1	<u>REG FILE</u> 04		1	1
	RGN2		1	1				
EXTERNAL:	ACRS	09	10	10	LPDR	03	2	2
	NRC PDR	02	1	1	NSIC	05	1	1
	NTIS		1	1				

LB.

THE UNIVERSITY OF CHICAGO
DEPARTMENT OF CHEMISTRY
5800 S. UNIVERSITY AVENUE
CHICAGO, ILLINOIS 60637

RECEIVED
JAN 15 1964

FROM: [Illegible]

[Illegible text]

VIRGINIA ELECTRIC AND POWER COMPANY
RICHMOND, VIRGINIA 23261

August 12, 1982

R. H. LEASBURG
VICE PRESIDENT
NUCLEAR OPERATIONS

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
Attn: Mr. Robert A. Clark, Chief
Operating Reactors Branch No. 3
Division of Licensing
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Serial No. 476
NO/JHL:acm
Docket No. 50-339
License No. NPF-7

Gentlemen:

VIRGINIA ELECTRIC AND POWER COMPANY.
NORTH ANNA POWER STATION UNIT NO. 2
SUPPLEMENT TO THE EVALUATION OF RCS PIPING THERMAL SLEEVES


By letter dated August 4, 1982 (Serial No. 460), Vepco stated that incore instrumentation thimbles will be verified as operable by traversing the movable incore detectors in the lower vessel region on a weekly basis. This would identify any potential damage or deformation of the instrument thimbles by a loose part in the vessel lower internals area.

Vepco proposes an alternative to the above surveillance because the ability of a movable incore detector to traverse a thimble tube gives no definitive indication of the thimble's integrity. It is possible for a detector to pass through a damaged or deformed thimble. It is also possible for a detector to stick in an undamaged thimble due to lubrication or incore drive mechanism problems. The proposed alternative would be to detect a damaged or leaking thimble by increasing testing to verify operability of the Incore Detector Leakage Detection System. This system would give a positive indication (control room alarm) of damage to an incore detector thimble. The operability of the Incore Detector Leakage Detection System would be verified by performance of a functional test prior to Unit 2 startup and the alarm will be verified operable weekly by the Shift Technical Advisor to insure that any leakage would be immediately alarmed in the control room. In addition, the normally required core surveillance which utilizes the incore movable detector system will be performed as scheduled. These monthly flux maps will serve as further verification of the operability and integrity of the guide thimbles.

The Loose Parts Monitoring System will also identify any impact, vibration or movement of any loose parts in the vessel lower internals area.

If you have any questions, please contact us at your earliest convenience.

Very truly yours,


R. H. Leasburg

A001

cc: Mr. James P. O'Reilly
Regional Administrator
Region II

8208170193 820812
PDR ADOCK 05000339
P PDR

THE UNIVERSITY OF CHICAGO
LIBRARY

1954