

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8301030243 DOC. DATE: 82/12/21 NOTARIZED: NO DOCKET #
 FACIL: 50-335 St. Lucie Plant, Unit 1, Florida Power & Light Co. 05000335
 50-389 St. Lucie Plant, Unit 2, Florida Power & Light Co. 05000389
 AUTH. NAME AUTHOR AFFILIATION
 UHRIG, R.E. Florida Power & Light Co.
 RECIP. NAME RECIPIENT AFFILIATION
 EISENHUT, D.G. Division of Licensing

SUBJECT: Submits info describing const of emergency operations facility, scheduled to be fully operational by 831001.W/two oversize drawings. Aperture cards are available in PDR.

DISTRIBUTION CODE: B029S COPIES RECEIVED: LTR 1 ENCL 2 SIZE: 1+2
 TITLE: Licensing Submittal: Emergency Preparedness Correspondence

NOTES: *Aperture Card Dist*

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		LTTR	ENCL		ID CODE/NAME		LTTR	ENCL
	NRR ORB3 BC		1	1		LIC BR #3 BC		1	1
	KREUTZER, P.		1	0		LIC BR #3 LA		1	0
	NELSON, C. 01		1	1		NERSES, V. 01		1	1
INTERNAL:	IE/DEP DIR		1	0		IE/DEP EPDS 12		1	1
	IE/DEP/EPLB 06		4	4		NRR/DSI/AEB		1	1
	NRR/DSI/RAB		1	1		<u>REG FILES</u> 04		1	1
	RGN2		1	1					
EXTERNAL:	INPO, J. STARNES		1	1		LPDR 03		1	1
	NRC PDR 02		1	1		NSIC 05		1	1
	NTIS		1	1					


*Encls. to: Am - 2 Advanced
 CF - 1 ORB 3-1
 LIC 3-1*

1950

THE UNIVERSITY OF CHICAGO
DEPARTMENT OF CHEMISTRY
5408 SOUTH DIVISION STREET
CHICAGO, ILLINOIS 60637

RECEIVED
DEPARTMENT OF CHEMISTRY
UNIVERSITY OF CHICAGO

DATE	INITIALS	DESCRIPTION	DATE	INITIALS	DESCRIPTION
1	P	...	1	A	...
1	P	...	1	A	...
1	P	...	1	A	...
1	P	...	1	A	...
1	P	...	1	A	...
1	P	...	1	A	...
1	P	...	1	A	...
1	P	...	1	A	...
1	P	...	1	A	...
1	P	...	1	A	...



December 21, 1982
L-82-549

Office of Nuclear Reactor Regulations
Attention: Mr. Darrell G. Eisenhut, Director
Division of Licensing
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

Dear Mr. Eisenhut:

Re: St. Lucie Units 1 & 2
Docket Nos. 50-335 & 50-389
Emergency Operations Facility (EOF)

In response to requests from members of your staff, this letter is being forwarded to provide information on the St. Lucie Plant EOF that has not previously been submitted.

The St. Lucie Plant EOF will be constructed at Florida Power and Light's Midway Substation (at the intersection of Interstate 95 and Midway Road - SR 712) located approximately 10.5 miles West of the plant. The EOF will be a 100' by 93' 6" concrete block/masonry structure with a prestressed concrete roof, constructed in accordance with the South Florida Building Code. A protection factor is not applicable due to its location with respect to the plant. Standard industrial building HVAC will be installed with no special (HEPA) filtration provided. To facilitate radio Communications, a 150' radio tower will be installed adjacent to the EOF.

The contract was awarded on December 16, 1982, and the contractor was mobilized on December 20, 1982. The EOF will be fully operational by October 1, 1983.

Attached for your information are sheets 1 and 5 of drawing 8770-G-789 describing the site plan and floor plan respectively.

Very truly yours,

Robert E. Uhrig
Vice President
Advanced Systems & Technology

REU/RJS/cab

Attachment

Aperture Card Unit
B029
1/3
Encls To:
PM-2 Advanced
CF-1
OFF 3-1
LIE 3-1

8301030243 821221
PDR ADOCK 05000335
F PDR