

JAN 3 1983

DISTRIBUTION:

DCS MS-016

Docket No. 50-335

- ✓ Docket File
- NRC PDR
- L PDR
- NSIC
- ORB3 Rdg
- DEisenhut
- JHeltemes
- OELD
- ELJordan
- JMTaylor
- ACRS-10
- RAClark
- PMKreutzer-3
- KHeitner
- DSells
- Gray File

Dr. Robert E. Uhrig
 Vice President
 Advanced Systems & Technology
 Florida Power & Light Company
 P. O. Box 529100
 Miami, Florida 33152

Dear Dr. Uhrig:

SUBJECT: ADDITIONAL QUESTIONS REGARDING UPPER HEAD VOIDING DURING
 NATURAL CIRCULATION COOLDOWN, ST. LUCIE 1

- Reference: 1. Letter, Novak to Uhrig, "St. Lucie Unit 1 - Cooldown on Natural Circulation Information Request," dated July 8, 1980.
2. Letters, Uhrig to Novak, "St. Lucie Unit 1, Docket No. 50-335, Natural Circulation Cooldown," dated August 25, 1980, September 16, 1980, October 17, 1980, December 30, 1980, and February 9, 1981.

We are conducting a review of the St. Lucie Unit 1 responses (Ref. 2) to NRC questions concerning natural circulation cooldown (Ref. 1). In order to fully understand your earlier responses, we would appreciate your response to the enclosed questions. These questions were discussed with Mr. Ron Stevens of your staff on November 30, 1982.

Please provide us with a schedule for your response to these questions within 15 days of receipt of this letter.

The reporting and/or recordkeeping requirements contained in this letter affect fewer than ten respondents; therefore, OMB clearance is not required under P.L. 96-511.

Sincerely,

Original signed by
 Robert A. Clark

Robert A. Clark, Chief
 Operating Reactors Branch #3
 Division of Licensing

Enclosure:
 As stated

cc: See next page

OFFICE	ORB#3:DL	ORB#3:DL	ORB#3:DL			
SURNAME	KHeitner/pn	DSells	RAClark			
	1/3/83	1/3/83	1/3/83			

8301140539 830103
 PDR ADDCK 05000335
 P PDR

OFFICIAL RECORD COPY

Florida Power & Light Company

cc:

Harold F. Reis, Esquire
Lowenstein, Newman, Reis & Alexrad
1025 Connecticut Avenue, N.W.
Washington, D. C. 20036

Mr. Jack Schreve
Office of the Public Counsel
Room 4, Holland Building
Tallahassee, Florida 32304

Norman A. Coll, Esquire
McCarthy, Steel, Hector & Davis
14th Floor, First National Bank Building
Miami Florida 33131

Resident Inspector
c/o U.S.N.R.C.
7900 S. A1A
Jensen Beach, Florida 33457

Administrator
Department of Environmental Regulation
Power Plant Siting Section
State of Florida
2600 Blair Stone Road
Tallahassee, Florida 32301

State Planning and Development Clearinghouse
Office of Planning and Budgeting
Executive Office of the Governor
The Capitol Building
Tallahassee, Florida 32301

Mr. Weldon B. Lewis
County Administrator
St. Lucie County
2300 Virginia Avenue, Room 104
Fort Pierce, Florida 33450

U.S. Environmental Protection Agency
Region IV Office
ATTN: Regional Radiation
Representative
345 Courtland Street, N.E.
Atlanta, Georgia 30308

Mr. Charles B. Brinkman
Manager - Washington Nuclear Operations
C-E Power Systems
Combustion Engineering, Inc.
4853 Cordell Avenue, Suite A-1
Bethesda, Maryland 20014

Regional Administrator
Nuclear Regulatory Commission, Region II
Office of Executive Director for Operations
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303



100

ENCLOSURE I

ADDITIONAL QUESTIONS FOR ST. LUCIE UNIT 1
ON NATURAL CIRCULATION COOLDOWN

- 1.A. In the enclosure to letter L-80-431, dated December 30, 1980, it was stated that very conservative assumptions regarding fluid mixing were used in the RETRAN analysis for a 50°F/hr cooldown to 325°F. What were these conservative assumptions?
 - B. What condensation coefficient was used in the RETRAN analysis and why was it chosen?
 - C. RETRAN cannot model metal heat transfer to steam. Justify why this can be neglected.
2. In letter L-80-431, December 30, 1980, when you say that the "drain and fill" method was successfully used twice. What was the basis for this conclusion? Was 50° subcooling maintained in the hot legs?
3. The following questions refer to the enclosure to letter L-80-277, dated August 25, 1980.
 - A. At the end of drain and fill simulation, why does charging cause a loss of subcooling in the RCS? What is the upper head volume doing during the period from 2.95 to 3.95 hrs?
 - B. Explain the mechanism of the "fill" cycle in more detail. Charging water acts as a piston on RCS. What fills the upper head? What causes draining out of the pressurizer?



11
12
13

14

- C. What if T_{HOT} was used as the initial temperature rather than $520^{\circ}F$ (considering that the minimum subcooling (54°) was reached at the end of the simulation).

