

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)


ACCESSION NBR:8301210013 DOC,DATE: 83/01/14 NOTARIZED: NO DOCKET #
 FACIL:50-389 St. Lucie Plant, Unit 2, Florida Power & Light Co. 05000389
 AUTH.NAME AUTHOR AFFILIATION
 UHRIG,R,E. Florida Power & Light Co,
 RECIP.NAME RECIPIENT AFFILIATION
 EISENHUT,D.G. Division of Licensing

SUBJECT: Commits to perform inservice insp of low pressure turbine discs. Insp will be integral part of Inservice Insp Program will include ultrasonic test exam of base & keyway areas of turbine LP discus & MT & VT exams of accessible disc areas.

DISTRIBUTION CODE: B001S COPIES RECEIVED:LTR 1 ENCL 1 SIZE: 1
 TITLE: Licensing Submittal: PSAR/FSAR Amdts & Related Correspondence

NOTES:

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		LTTR	ENCL		ID CODE/NAME		LTTR	ENCL
	A/D LICENSNG		1	0	LIC BR #3 BC		1	0	
	LIC BR #3 LA		1	0	NERSES,V. 01		1	1	
INTERNAL:	ELD/HDS2		1	0	IE FILE		1	1	
	IE/DEP EPDS 35		1	1	IE/DEP/EPLB 36		3	3	
	NRR/DE/AEAB		1	0	NRR/DE/CEB 11		1	1	
	NRR/DE/EQB 13		2	2	NRR/DE/GB 28		2	2	
	NRR/DE/HGEB 30		1	1	NRR/DE/MEB 18		1	1	
	NRR/DE/MTEB 17		1	1	NRR/DE/QAB 21		1	1	
	NRR/DE/SAB 24		1	1	NRR/DE/SEB 25		1	1	
	NRR/DHFS/HFEB40		1	1	NRR/DHFS/LQB 32		1	1	
	NRR/DHFS/OLB 34		1	1	NRR/DL/SSPB		1	0	
	NRR/DSI/AEB 26		1	1	NRR/DSI/ASB		1	1	
	NRR/DSI/CPB 10		1	1	NRR/DSI/CSB 09		1	1	
	NRR/DSI/ICSB 16		1	1	NRR/DSI/METB 12		1	1	
	NRR/DSI/PSB 19		1	1	NRR/DSI/RAB 22		1	1	
	NRR/DSI/RSB 23		1	1	REG FILE 04		1	1	
	RGN2		3	3	RM/DDAMI/MIB		1	0	
EXTERNAL:	ACRS 41		6	6	BNL (AMDTS ONLY)		1	1	
	DMB/DSS (AMDTS)		1	1	FEMA-REP DIV 39		1	1	
	LPDR 03		1	1	NRC PDR 02		1	1	
	NSIC 05		1	1	NTIS		1	1	



January 14, 1983
L-83-17

Office of Nuclear Reactor Regulations
Attention: Mr. Darrell G. Eisenhut, Director
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Dear Mr. Eisenhut:

Re: St. Lucie Unit No. 2
Docket No. 50-389
ISI of L.P. Turbine Discs

In accordance with the St. Lucie Unit 2 SER (section 10.2.1) Florida Power and Light commits to perform inservice inspection of the low pressure turbine discs. The requirements for these inspections will be an integral part of the St. Lucie Unit 2 Inservice Inspection Program and will include the UT examination of the base and keyway areas of the turbine LP discs and MT and VT examinations of all accessible disc areas.

The initial inspections are to be conducted at the first refueling outage. Subsequent inspections will be conducted at intervals based on the vendor's recommendations.

Very truly yours,

Robert E. Uhrig
Vice President
Advanced Systems and Technology

REU/RJS/ok

Boo!

cc: J.P. O'Reilly, Region II
Harold F. Reis, Esquire

8301210013 830114
PDR ADOCK 05000389
Q PDR

