

Enclosure

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

In the Matter of

FLORIDA POWER & LIGHT
COMPANY

(St. Lucie Plant, Unit No. 1)

)
)
)
)
)

Docket No. 50-335

ORDER CONFIRMING LICENSEE COMMITMENTS
ON POST-TMI RELATED ISSUES

I.

The Florida Power & Light Company (the licensee) is the holder of Facility Operating License No. DPR-67 which authorizes the operation of the St. Lucie Plant, Unit No. 1 (the facility) at steady-state power levels not in excess of 2700 megawatts thermal. The facility is a pressurized water reactor (PWR) located at the licensee's site on Hutchinson Island in St. Lucie County, Florida.

II.

Following the accident at Three Mile Island No. 2 (TMI-2) on March 28, 1979, the Nuclear Regulatory Commission (NRC) staff developed a number of proposed requirements to be implemented on operating reactors and on plants under construction. These requirements include Operational Safety, Siting and Design, and Emergency Preparedness and are intended to provide substantial

additional protection in the operation of nuclear facilities based on the experience from the accident at TMI-2 and the official studies and investigations of the accident. The staff's proposed requirements and schedule for implementation are set forth in NUREG-0737, "Clarification of TMI Action Plan Requirements." Among these requirements are a number of items, consisting of hardware modifications, administrative procedure implementation and specific information to be submitted by the licensee, scheduled to be completed on or after July 1, 1981. On March 17, 1982, a letter (Generic Letter 82-05) was sent to all licensees of operating power reactors for those items that were scheduled to be implemented from July 1, 1981 through March 1, 1982. Subsequently, on May 5, 1982, a letter (Generic Letter 82-10) was also sent to all licensees of operating power reactors for those items that were scheduled for implementation after March 1, 1982. These letters are hereby incorporated by reference. In these letters each licensee was requested to furnish within 30 days pursuant to 10 CFR 50.54(f) the following information for items which the staff had proposed for completion on or after July 1, 1981:

- (1) For applicable items that have been completed, confirmation of completion and the date of completion, (2) For items that have not been completed, a specific schedule for implementation, which the licensee committed to meet, and (3) Justification for delay, demonstration of need for the proposed schedule, and a description of the interim compensatory measures being taken.

III.

Florida Power & Light Company responded to Generic Letter 82-05 by letter dated April 19, 1982, and the references stated therein. They also responded to Generic Letter 82-10 by letters dated July 2 and 9, August 13, 1982 and the references stated therein. In these submittals, Florida Power & Light Company confirmed that some of the items identified in the Generic Letters had been completed and made firm commitments to complete the remainder. The attached Tables summarizing the licensee's schedular commitments or status were developed by the staff from the Generic Letters and the licensee-provided information.

Generic Letters 82-05 and 82-10 addressed thirteen and sixteen items, respectively. Of the ten items listed in Generic Letter 82-10 requiring a response, six items are not included in this Order. Item I.A.1.3.2 is part of a separate rulemaking; Items I.C.1, III.A.1.2 (2 items), and III.A.2.2 will be handled separately following Commission actions that would proceed as a result of its consideration of Commission Paper SECY 82-111, as amended; for Items II.K.3.30 and II.K.3.31 (one item), the staff review of the generic models under II.K.3.30 has not been completed, and II.K.3.31 is not required until one year after staff approval of the generic models.

All of the items addressed in this Order are considered by the licensee to be completed or to require no modifications.

In view of the foregoing, I have determined that these modifications and actions are required in the interest of public health and safety and should, therefore, be confirmed by Order.

IV.

Accordingly, pursuant to Sections 103, 161i, and 161o of the Atomic Energy Act of 1954, as amended, and the Commission's regulations in 10 CFR Parts 2 and 50, IT IS HEREBY ORDERED EFFECTIVE IMMEDIATELY THAT THE LICENSEE SHALL:

Implement and maintain the specific items described as complete in the attachments to this Order. Incomplete items shall be completed by no later than the dates shown in the attachments (as described in the licensee's submittals noted in Section III herein) and maintained thereafter.

V.


The licensee may request a hearing on this Order within 20 days of the date of publication of this Order in the Federal Register. A request for a hearing shall be addressed to the Director, Office of Nuclear Reactor Regulation, U. S. Nuclear Regulatory Commission, Washington, D. C. 20555. A copy shall also be sent to the Executive Legal Director at the same address. A REQUEST FOR HEARING SHALL NOT STAY THE IMMEDIATE EFFECTIVENESS OF THIS ORDER.

If a hearing is requested by the licensee, the Commission will issue an Order designating the time and place of any such hearing.

If a hearing is held concerning this Order, the issue to be considered at the hearing shall be whether the licensee should comply with the requirements set forth in Section IV of this Order.

This Order is effective upon issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Robert A. Purple, Deputy Director
Division of Licensing
Office of Nuclear Reactor Regulation

Dated at Bethesda, Maryland
this 14th day of March,
1983.

Attachments:

1. Licensee's Commitments on Applicable
NUREG-0737 Requirements from Generic
Letter 82-05
2. Licensee's Commitments on Applicable
NUREG-0737 Requirements from Generic
Letter 82-10

LICENSEE COMMITMENTS ON APPLICABLE NUREG-0737 ITEMS
FROM GENERIC LETTER 82-05

ITEM	TITLE	NUREG-0737 SCHEDULE	REQUIREMENT	LICENSEE'S COMPLETION SCHEDULE (OR STATUS)*
I.A.3.1	Simulator Exams	10/1/81	Include simulator exams in licensing examinations.	Complete
II.B.2	Plant Shielding	1/1/82	Modify facility to provide access to vital areas under accident conditions.	Complete
II.B.3	Post-accident sampling	1/1/82	Install upgrade post-accident sampling capability.	Complete
II.B.4	Training for Mitigating Core Damage	10/1/81	Complete training program.	Complete
II.E.1.2	Aux FW Indication & Flow Indicator	7/1/81	Modify instrumentation to level of safety grade.	Complete
II.E.4.2	Containment Isolation Dependability	7/1/81	Part 5 - lower containment pressure setpoint to level compatible with normal operation.	Complete
II.E.4.2	Containment Isolation Dependability	7/1/81	Part 7 - isolate purge and vent valves on radiation signal.	Complete

*Where complete date refers to a refueling outage (the estimated date when the outage begins), the item will be completed prior to the restart of the facility.

LICENSEE COMMITMENTS ON APPLICABLE NUREG-0737 ITEMS
FROM GENERIC LETTER 82-05

ITEM	TITLE	NUREG-0737 SCHEDULE	REQUIREMENT	LICENSEE'S COMPLETION SCHEDULE (OR STATUS)*
II.F.1	Accident Monitoring	1/1/82	(1) Install noble gas effluent monitors.	Complete
		1/1/82	(2) Provide capability for effluent monitoring of iodine.	Complete
		1/1/82	(3) Install in-containment radiation-level monitor.	Complete
		1/1/82	(4) Provide continuous indication of containment pressure.	Complete
		1/1/82	(5) Provide continuous indication of containment water level.	Complete
		1/1/82	(6) Provide continuous indication of hydrogen concentration in containment.	Complete

*Where completion date refers to a refueling outage (the estimated date when the outage begins), the item will be completed prior to the restart of the facility.

ITEM	TITLE	NUREG-0737 SCHEDULE	REQUIREMENT	LICENSEE'S COMPLETION SCHEDULE (OR STATUS)*
I.A.1.3.1	Limit Overtime	10/1/82 per Gen. Ltr. 82-12 dtd. 6/15/82	Revise administrative procedures to limit overtime in accordance w/NRC Policy Statement issued by Gen. Ltr. No. 82-12, dtd. June 15, 1982.	Complete
I.A.1.3.2	**Minimum Shift Crew	To be superseded by Proposed Rule.	To be addressed in the Final Rule on Licensed Operator Staffing at Nuclear Power Units.	To be addressed when Final Rule is issued.
I.C.1	**Revise Emergency Procedures	Superseded by SECY 82-111	Reference SECY 82-111, Requirements for Emergency Response Capability.	To be determined
II.D.1.2	RV and SV Test Programs	7/1/82	Submit plant specific reports on relief and safety valve program.	Complete
II.D.1.3	Block Valve Test Program	7/1/82	Submit report of results of test program.	Complete
II.K.3.30 & 31	**SBLOCA Analysis	1 yr. after staff approval of model	Submit plant specific analyses.	To be determined following staff approval of model
III.A.1.2	**Staffing Levels for Emergency Situations	Superseded by SECY 82-111	Reference SECY 82-111, Requirements for Emergency Response Capability	To be determined
III.A.1.2	**Upgrade Emergency Support Facilities	""	""	""
III.A.2.2	**Meteorological Data	""	""	""
III.D.3.4	Control Room Habitability	To be determined by licensee	Modify facility as identified by licensee study	Complete

*Where completion date refers to a refueling outage (the estimated date when the outage begins), the item will be completed prior to the restart of the facility.

**Not Part of Confirmatory Order