

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8303280206 DOC DATE: 83/03/24 NOTARIZED: NO DOCKET #: 05000389  
 FACIL: 50-389 St. Lucie Plant, Unit 2, Floridal Power & Light Cbl.  
 AUTH. NAME: AUTHOR: AFFILIATION: Floridal Power & Light Cbl.  
 UHRIG, R. EL. RECIPIENT: AFFILIATION: Division of Licensing  
 RECIPI. NAME: EISENHUT, D. GL.


SUBJECT: Advises that essential apparatus will be installed by end of first refueling to test 8-inch mini-purge valves in containment ventilation sys every 92 days per Tech Spec 4.6.1.7.4.

DISTRIBUTION CODE: 80018 COPIES RECEIVED: LTR. 1 ENCL 1 SIZE: 11111111  
 TITLE: Licensing Submittal: PSAR/FSAR Amdts & Related Correspondence

NOTES:

	RECIPIENT IDI CODE/NAME	COPIES LTR. ENCL	RECIPIENT IDI CODE/NAME	COPIES LTR. ENCL
	A/D LICENSNGI	1 0	LICI BR. #3 BCI	1 0
	LICI BR #3 LAI	1 0	NERSES, V. 01.	1 1
INTERNAL:	ELD/HDS2:	1 0	IEI FILEI	1 1
	IEV/DEPER/EPB 36	3 3	IEV/DEPER/IRB 35	1 1
	NRR/DEV/AEAB 1	1 0	NRR/DEV/CEB 11	1 1
	NRR/DEV/EMEB 1	1 1	NRR/DEV/EQB 13	2 2
	NRR/DEV/GB 28	2 2	NRR/DEV/HGEB 30	1 1
	NRR/DEV/MEB 18	1 1	NRR/DEV/MTEB 17	1 1
	NRR/DEV/QAB 21	1 1	NRR/DEV/SAB 24	1 1
	NRR/DHFS/HFEB 40	1 1	NRR/DHFS/LQB 32	1 1
	NRR/DL/SSPB 1	1 0	NRR/DSI/AEB 26	1 1
	NRR/DSI/ASB 1	1 1	NRR/DSI/CPB 10	1 1
	NRR/DSI/CSB 09	1 1	NRR/DSI/ICSB 16	1 1
	NRR/DSI/MEPB 12	1 1	NRR/DSI/PSB 19	1 1
	NRR/DSI/RAB 22	1 1	NRR/DSI/RSB 23	1 1
	<u>REGI FILEI</u> 04	1 1	RGN2.	3 3
	RM/DDAMI/MI 1	1 0		
EXTERNAL:	ACRS 41	6 6	BNLIC(AMDTS ONLY)	1 1
	DMB/DSS (AMDTS) 1	1 1	FEMA-REPI DIVI 39	1 1
	LPDR 03	1 1	NRCI POR 02	1 1
	NSICI 05	1 1	NTIS	1 1





March 24, 1983  
L-83-171

50-389

Office of Nuclear Reactor Regulations  
Attention: Mr. Darrell G. Eisenhut, Director  
Division of Licensing  
U. S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Dear Mr. Eisenhut:

Re: ST. LUCIE UNIT NO. 2  
DOCKET NO.  
TECHNICAL SPECIFICATIONS  
CONTAINMENT VENTILATION SYSTEM (3/4.6.1.7)

On March 15, 1983, FP&L met with CSB's Mr. M. Fields, to discuss an open Technical Specification regarding the Containment Ventilation System (i.e., 3/4.6.1.7).

In our discussion with Mr. Fields, FP&L noted the standard SURVEILLANCE REQUIREMENT 4.6.1.7.4 for this T.S. required FP&L to leakage test the 8-inch minipurge valves every 92 days. Because of certain valve testing constraints, FP&L requested an interim T.S. change for the minipurge leakrate testing requirement. FP&L's request was reviewed during the meeting by your staff and was found to be acceptable. Therefore, to reflect the meeting's agreement, the SURVEILLANCE REQUIREMENT 4.6.1.7.4 should read as follows:

"Each 8-inch containment purge supply and exhaust isolation valve with resilient material seals shall be demonstrated OPERABLE by verifying that the measured leakage rate is less than or equal to 0.05 L<sub>a</sub> when pressurized to P<sub>a</sub>, prior to entry to MODE 4 from COLD SHUTDOWN, if not tested within the previous 31 days."

The above T.S. change was accepted by the staff under the condition that FP&L install testing capabilities for the 8-inch purge valves which would allow for testing to the requirements of the standard (i.e., every 92 days). FP&L will install by the end of first refueling the essential apparatus to test these valves every 92 days.

Should you have any questions regarding this matter, please do not hesitate to call.

Very truly yours,

*J. A. De Mastry*  
*for*

Robert E. Uhrig  
Vice President  
Advanced Systems and Technology

REU/RJS/PPC/rms

8303280206 830324  
PDR ADOCK 05000389  
A PDR

cc: J. P. O'Reilly, Region II  
Harold F. Reis, Esquire

Boo!

