

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8304010381, DOC. DATE: 83/03/30 NOTARIZED: NO, DOCKET #: 05000389
 FACIL: 50-389 St. Lucie Plant, Unit 2, Florida Power & Light Co.
 AUTH. NAME: UHRIG, R. EL. AUTHOR: AFFILIATION: Florida Power & Light Co.
 RECIPIENT NAME: EISENHUT, D. G. RECIPIENT AFFILIATION: Division of Licensing


SUBJECT: Revises statement on page 2 of 830317, letter Audit Findings A.8.7 & A.8.9 of Abor C to SER Suppl 1, re LPSI & HPSI sys.

DISTRIBUTION CODE: B001S COPIES RECEIVED: LTR 4 ENCL 1 SIZE: 11/11/11
 TITLE: Licensing Submittals: PSAR/FSAR Amdts & Related Correspondence

NOTES:

	RECIPIENT ID: CODE/NAME	COPIES LTR ENCL	RECIPIENT ID: CODE/NAME	COPIES LTR ENCL
	A/DI LICENSNGI	1, 0	LICI BR #3; BCI	1, 0
	LICI BR #3; LAI	1, 0	NERSES, V. 01	1, 1
INTERNAL:	ELD/HDS2	1, 0	IEI FILEI	1, 1
	IE/DEPER/EPB 36	3, 3	IE/DEPER/IRB 35	1, 1
	NRR/DE/AEAB 1	1, 0	NRR/DE/CEB 11	1, 1
	NRR/DE/EQB 13	2, 2	NRR/DE/GB 28	2, 2
	NRR/DE/HGB 30	1, 1	NRR/DE/MEB 18	1, 1
	NRR/DE/MTEB 17	1, 1	NRR/DE/QAB 21	1, 1
	NRR/DE/SAB 24	1, 1	NRR/DHFS/HFEB40	1, 1
	NRR/DHFS/LQB 32	1, 1	NRR/DL/SSPB	1, 0
	NRR/DSI/AEB 26	1, 1	NRR/DSI/ASB	1, 1
	NRR/DSI/CPB 10	1, 1	NRR/DSI/CSB 09	1, 1
	NRR/DSI/ICSB 16	1, 1	NRR/DSI/MEIB 12	1, 1
	NRR/DSI/PSB 19	1, 1	NRR/DSI/RAB 22	1, 1
	NRR/DSI/RSB 23	1, 1	<u>REGI FILEI</u> 04	1, 1
	RGN2	3, 3	RM/DUAMI/MLB	1, 0
EXTERNAL:	ACRS 41	6, 6	BNL(CAMDTS(ONLY))	1, 1
	DMB/DSS (AMDTS)	1, 1	FEMA-REP(DIVI 39)	1, 1
	LPDR 03	1, 1	NRCI POR 02	1, 1
	NSICI 05	1, 1	NTIS	1, 1

TOTAL NUMBER OF COPIES REQUIRED: LTR: 51, ENCL 44



March 30, 1983
L-83-200

Office of Nuclear Reactor Regulations
Attention: Mr. Darrell G. Eisenhut, Director
Division of Licensing
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

Dear Mr. Eisenhut:

Re: ST. LUCIE UNIT NO. 2
DOCKET NO. 50-389
HFEB AUDIT FINDINGS
A.8.7 AND A.8.9

Florida Power & Light Company (FP&L) letter, L-83-145 dated March 17, 1983, provided augmented information concerning the HFEB Audit Findings A.8.7 and A.8.9 of Appendix C to St. Lucie Unit No. 2 SER Supplement No. 1.

On page 2 of the referenced letter, the following statement was made concerning the LPSI and HPSI systems: "In either case, the system performance is not impaired by any error and the risk to the health and safety of the public is not increased."

By this letter, FP&L formally deletes this statement in both paragraphs and replaces it with the following statement in each paragraph: "In the event of an operator error, the operator will take corrective action within 60 seconds. as demonstrated in the Task Analysis and therefore the risk to the health and safety of the public is not increased."

Should you have any questions regarding this submittal, please contact us.

Very truly yours,

Robert E. Uhrig
Vice President
Advanced Systems and Technology

Boo 1

REU/RJS/PPG/rms

cc: J.P. O'Reilly, Region II
Harold F. Reis, Esquire

8304010381 830330
PDR ADOCK 05000389
E PDR

