



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

FLORIDA POWER & LIGHT COMPANY

DOCKET NO. 50-335

ST. LUCIE PLANT UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 58
License No. DPR-67

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Florida Power & Light Company, (the licensee) dated December 10, 1982, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

8305120153 830503
PDR ADOCK 05000335
PDR



2. Accordingly, Facility Operating License No. DPR-67 is amended by changes to the Technical Specifications as indicated in the Attachment to this license amendment, and by amending paragraph 2.C(2) to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 58, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

for Charles M. Tamm
Robert A. Clark, Chief
Operating Reactors Branch #3
Division of Licensing

Attachment:
Changes to the Technical
Specifications

Date of Issuance: May 3, 1983

ATTACHMENT TO LICENSE AMENDMENT NO. 58
TO FACILITY OPERATING LICENSE NO. DPR-67
DOCKET NO. 50-335

Replace the following pages of the Appendix "A" Technical Specifications with the enclosed pages. The revised pages are identified by amendment number and contain vertical lines indicating the area of change. The corresponding overleaf pages are also provided to maintain document completeness.

Pages

3/4 3-11
3/4 7-13
3/4 3-15
3/4 3-19

TABLE 3.3-3 (Continued)

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION

FUNCTIONAL UNIT	TOTAL NO. OF CHANNELS	CHANNELS TO TRIP	MINIMUM CHANNELS OPERABLE	APPLICABLE MODES	ACTION
5. CONTAINMENT SUMP RECIRCULATION (RAS)					
a. Manual RAS (Trip Buttons)	2	1	2	1, 2, 3, 4	8
b. Refueling Water Tank - Low	4	2	3	1, 2, 3	9#
6. LOSS OF POWER					
a. 4.16 kv Emergency Bus Undervoltage (Loss of Voltage)*	2/Bus	2/Bus	1/Bus	1, 2, 3	12
b. 4.16 kv Emergency Bus Under- voltage (Degraded Voltage)					
(1) Undervoltage Device #1*	2/Bus	2/Bus	1/Bus	1, 2, 3	12
(2) Undervoltage Device #2*	2/Bus	2/Bus	1/Bus	1, 2, 3	12
c. 480 V Emergency Bus Under- voltage (Degraded Voltage)*	2/Bus	2/Bus	1/Bus	1, 2, 3	12
7. AUXILIARY FEEDWATER AUTOMATIC START					
Steam Generator (SG) Level Instruments	4/SG	2/SG ^{1/}	2/SG	1, 2, 3	11

^{1/} 2/SG for either steam generator will start one train of AFW.

* This specification will be effective prior to Cycle 7 restart.

ST. LUCIE - UNIT 1

3/4 3-11

Amendment No. 75, 27, 58

TABLE 3.3-3 (Continued)

TABLE NOTATION

- (a) Trip function may be bypassed in this MODE when pressurizer pressure is < 1725 psia; bypass shall be automatically removed when pressurizer pressure is ≥ 1725 psia.
- (b) An SIAS signal is first necessary to enable CSAS logic.
- (c) Trip function may be bypassed in this MODE below 685 psig; bypass shall be automatically removed at or above 685 psig.
- # The provisions of Specification 3.0.4 are not applicable.

ACTION STATEMENTS

- ACTION 8 - With the number of OPERABLE channels one less than the Total Number of Channels, restore the inoperable channel to OPERABLE status within 48 hours or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.
- ACTION 9 - With the number of OPERABLE channels one less than the Total Number of Channels, operation may proceed provided the following conditions are satisfied:
 - a. The inoperable channel is placed in either the bypassed or tripped condition within 1 hour. For the purposes of testing and maintenance, the inoperable channel may be bypassed for up to 48 hours from time of initial loss of OPERABILITY; however, the inoperable channel shall then be either restored to OPERABLE status or placed in the tripped condition.
 - b. Within one hour, all functional units receiving an input from the inoperable channel are also placed in the same condition (either bypassed or tripped, as applicable) as that required by a. above for the inoperable channel.
 - c. The Minimum Channels, OPERABLE requirement is met; however, one additional channel may be bypassed for up to 48 hours while performing tests and maintenance on that channel provided the other inoperable channel is placed in the tripped condition.

TABLE 3.3-3 (Continued)

TABLE NOTATION

- ACTION 10 - With the number of OPERABLE channels one less than the Total Number of Channels, operation may proceed provided the inoperable channel is placed in the bypassed condition and the Minimum Channels OPERABLE requirement is demonstrated within 1 hour; one additional channel may be bypassed for up to 2 hours for surveillance testing per Specification 4.3.2.1.1.
- ACTION 11 - Instrument operability requirements are contained in the Reactor Protection System requirements for Reactor Trip on Steam Generator Level. If an Automatic Start channel is inoperable, operation may continue provided that the affected pump is verified to be OPERABLE per Specification 4.7.1.2.a within 8 hours and at least once per 7 days thereafter; and the Automatic Start channel shall be restored to OPERABLE status within 30 days or the reactor shall be in at least HOT SHUTDOWN within the next 12 hours.
- ACTION 12 - With the number of OPERABLE Channels one less than the Total Number of Channels operation may proceed until performance of the next required CHANNEL FUNCTIONAL TEST provided the inoperable channel is placed in the tripped condition within 1 hour.

TABLE 3.3-4

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION TRIP VALUES

<u>FUNCTIONAL UNIT</u>	<u>TRIP SETPOINT</u>	<u>ALLOWABLE VALUES</u>
1. SAFETY INJECTION (SIAS)		
a. Manual (Trip Buttons)	Not Applicable	Not Applicable
b. Containment Pressure - High	≤ 5 psig	≤ 5 psig
c. Pressurizer Pressure - Low	≥ 1600 psia	≥ 1600 psia
2. CONTAINMENT SPRAY (CSAS)		
a. Manual (Trip Buttons)	Not Applicable	Not Applicable
b. Containment Pressure - High-High	≤ 10 psig	≤ 10 psig
3. CONTAINMENT ISOLATION (CIS)		
a. Manual (Trip Buttons)	Not Applicable	Not Applicable
b. Containment Pressure - High	≤ 5 psig	≤ 5 psig
c. Containment Radiation - High	≤ 10 R/hr	≤ 10 R/hr
d. SIAS	----- (See FUNCTIONAL UNIT 1 above) -----	
4. MAIN STEAM LINE ISOLATION (MSIS)		
a. Manual (Trip Buttons)	Not Applicable	Not Applicable
b. Steam Generator Pressure - Low	≥ 585 psig	≥ 585 psig
5. CONTAINMENT SUMP RECIRCULATION (RAS)		
a. Manual RAS (Trip Buttons)	Not Applicable	Not Applicable
b. Refueling Water Tank - Low	48 inches above tank bottom	48 inches above tank bottom

TABLE 3.3-4 (Continued)

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION TRIP VALUES

<u>FUNCTIONAL UNIT</u>	<u>TRIP VALUE</u>	<u>ALLOWABLE VALUES</u>
6. LOSS OF POWER		
a. (1) 4.16 kv Emergency Bus Undervoltage (Loss of Voltage)*	2900 $\pm$ 29 volts with a 1 $\pm$.5 second time delay	2900 $\pm$ 29 volts with a 1 $\pm$.5 second time delay
b. 4.16 kv Emergency Bus Undervoltage (Degraded Voltage)		
(1) Undervoltage Device #1*	3675 $\pm$ 36 volts with a 7 $\pm$ 1 minute time delay	3675 $\pm$ 36 volts with a 7 $\pm$ 1 minute time delay
(2) Undervoltage Device #2*	3592 $\pm$ 36 volts with a 18 $\pm$ 2 second time delay	3592 $\pm$ 36 volts with a 18 $\pm$ 2 second time delay
c. 480 volts Emergency Bus Undervoltage (Degraded Voltage)*	429 $\pm$ 5-0 volts with a 7 $\pm$ 1 second time delay	429 $\pm$ 5 -0 volts with a 7 $\pm$ 1 second time delay
7. AUXILIARY FEEDWATER	$\geq$ 30% level	$\geq$ 30% level

* This specification will be effective prior to Cycle 7 restart.

ST. LUCIE - UNIT 1

3/4 3-15

Amendment No. 37, 58

TABLE 3.3-5

ENGINEERED SAFETY FEATURES RESPONSE TIMES

<u>INITIATING SIGNAL AND FUNCTION</u>	<u>RESPONSE TIME IN SECONDS</u>
1. <u>Manual</u>	
a. SIAS	
Safety Injection (ECCS)	Not Applicable
Containment Fan Coolers	Not Applicable
Feedwater Isolation	Not Applicable
Containment Isolation	Not Applicable
b. CSAS	
Containment Spray	Not Applicable
c. CIS	
Containment Isolation	Not Applicable
Shield Building Ventilation System	Not Applicable
d. RAS	
Containment Sump Recirculation	Not Applicable
e. MSIS	
Main Steam Isolation	Not Applicable
Feedwater Isolation	Not Applicable
2. <u>Pressurizer Pressure-Low</u>	
a. Safety Injection (ECCS)	$\leq 30.0^*/19.5^{**}$
b. Containment Isolation ***	$\leq 30.5^*/20.5^{**}$
c. Containment Fan Coolers	$\leq 30.0^*/17.0^{**}$
d. Feedwater Isolation	≤ 60.0

TABLE 4.3-2 (Continued)

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>FUNCTIONAL UNIT</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL CALIBRATION</u>	<u>FUNCTIONAL TEST</u>	<u>MODES IN WHICH SURVEILLANCE REQUIRED</u>
6. LOSS OF POWER				
a. 4.16 kv Emergency Bus Under- voltage (Loss of Voltage)*	S	R	M	1, 2, 3
b. 4.16 kv Emergency Bus Under- voltage (Degraded Voltage)				
(1) Undervoltage Device #1*	S	R	M	1, 2, 3
(2) Undervoltage Device #2*	S	R	M	1, 2, 3
b. 480 V Emergency Bus Under- voltage (Degraded Voltage)*	S	R	M	1, 2, 3
7. AUXILIARY FEEDWATER				
a. Auto Start	----- (See Surveillance 4.7.1.2.b) -----			
b. Steam Generator	----- (See RPS Table 4.3-1) -----			

* This specification will be effective prior to Cycle 7 restart.

ST. LUCIE - UNIT 1

3/4 3-19

Amendment No. 27, 58

TABLE 4.3-2 (Continued)

TABLE NOTATION

- (1) The logic circuits shall be tested manually at least once per 31 days.