

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8306130156 DOC. DATE: 83/06/08 NOTARIZED: NO
 FACIL: 50-389 St. Lucie Plant, Unit 2, Florida Power & Light Co.
 AUTH. NAME: UHRIG, R.E. AUTHOR AFFILIATION: Florida Power & Light Co.
 RECIP. NAME: EISENHUT, D.G. RECIPIENT AFFILIATION: Division of Licensing

DOCKET # 05000389

SUBJECT: Advises that sentence in util 810914 response to Human Engineering Discrepancy A.I.3 re key storage stating, "Remote Shutdown Panel SIS block keys will be maintained at RAB control access point," should be deleted.

DISTRIBUTION CODE: B001S COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 1
 TITLE: Licensing Submittal: PSAR/FSAR Amdts & Related Correspondence

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTR ENCL
	A/D LICENSNG	1 0	LIC BR #3 BC	1 0
	LIC BR #3 LA	1 0	NERSES, V. 01	1 0
INTERNAL:	ELD/HDS2	1 0	IE FILE	1 0
	IE/DEPER/EPB 36	3 3	IE/DEPER/IRB 35	1 1
	IE/DEQA/QAB 21	1 1	NRR/DE/AEAB	1 0
	NRR/DE/CEB 11	1 1	NRR/DE/EHEB	1 1
	NRR/DE/eqb 13	2 2	NRR/DE/GB 28	2 2
	NRR/DE/MEB 18	1 1	NRR/DE/MTEB 17	1 1
	NRR/DE/SAB 24	1 1	NRR/DE/SGEB 25	1 1
	NRR/DE/SGEB 30	1 1	NRR/DHFS/HFEB40	1 1
	NRR/DHFS/LQB 32	1 1	NRR/DHFS/PSRB	1 1
	NRR/DL/SSPB	1 0	NRR/DSI/AEB 26	1 1
	NRR/DSI/ASB	1 1	NRR/DSI/CPB 10	1 1
	NRR/DSI/CSB 09	1 1	NRR/DSI/ICSB 16	1 1
	NRR/DSI/METB 12	1 1	NRR/DSI/PSB 19	1 1
	NRR/DSI/RAB 22	1 1	NRR/DSI/RSB 23	1 1
	RES FILE 04	1 1	RGN2	3 1
	RM/DDAMI/MIB	1 0		
EXTERNAL:	ACRS 41	6 6	BNL (AMDTs ONLY)	1 1
	DMB/DSS (AMDTs)	1 1	FEMA-REP DIV 39	1 1
	LPDR 03	1 1	NRC PDR 02	1 1
	NSIC 05	1 1	NTIS	1 1

... ..
... ..
... ..

... ..
... ..
... ..


... ..
... ..
... ..

... ..
... ..
... ..

... ..
... ..
... ..

... ..
... ..
... ..

... ..
... ..
... ..



June 8, 1983
L-83-351

Office of Nuclear Reactor Regulations
Attention: Mr. Darrell G. Eisenhut, Director
Division of Licensing
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

Dear Mr. Eisenhut:

Re: St. Lucie Unit No. 2
Docket 50-389
HED A.1.3

On September 14, 1981, Florida Power & Light Company (FPL) responded to Human Engineering Discrepancy A.1.3 concerning key storage via letter L-81-420. In that letter, it was stated:

"Key storage will be provided as well as the necessary key access control procedures for those keys used in the Control Room and Remote Shutdown Panel prior to fuel load. The Remote Shutdown Panel SIS block keys will be maintained at the RAB control access point."

At the time the initial commitment was made, it was the NRC's understanding that the RAB control access point referenced, was in very close proximity to the Remote Shutdown Panel. This however, is not the case. The actual location of the Remote Shutdown Panel SIS block keys will be in a key locker located in the Remote Shutdown Room. This meets the original understanding of the NRC to have these keys in close proximity to the panel. Therefore, the sentence "The Remote Shutdown Panel SIS block keys will be maintained at the RAB control access point", should be deleted.

Should you have any questions regarding this submittal, please advise.

Very truly yours,

Robert E. Uhrig
Vice President
Advanced Systems & Technology

REU/JES/PPC/cab

15001
1/0

8306130156 830608
PDR ADDCK 05000389
PDR

