

DISTRIBUTION

Document Control 50-335/389

NRC PDR

L PDR

NSIC

PRC System

MAY 10 1983

Docket Nos.: 50-335
and 50-389

Dr. Robert E. Uhrig, Vice President
Advanced Systems and Technology
Florida Power and Light Company
Post Office Box 14000
Juno Beach, Florida 33408

LB#3 Reading

JLee

VNerses

DSells

RClark

Attorney, OELD

Jordan, IE

Taylor, IE

ACRS (16)

TMNovak

Dear Dr. Uhrig:

Subject: Process Control Program for St. Lucie Nuclear Power Station,
Units Nos. 1 and 2

We have reviewed the St. Lucie, Unit Nos. 1 and 2, Process Control Program (PCP) (St. Lucie Administrative Procedure 0520025), Rev. 1 dated March 8, 1983 submitted by Florida Power & Light Company in L 83-229 dated April 13, 1983. We find that the St. Lucie Plant PCP meets the requirements of Branch Technical Position 11-3 (Standard Review Plan Section 11.4), Rev. 2, July 1981, and is therefore acceptable.

The PCP contains necessary process parameters and boundary conditions to assure that dewatering of bead resin will be complete, with essentially no free liquid. This PCP is only applicable to dewatering of spent bead resin for offsite shipment for disposal as the licensee has decided not to solidify spent bead resin.

If there are questions, please contact V. Nerses, Project Manager, St. Lucie 2.

Sincerely,

Original signed by:
George W. Knighton

George W. Knighton, Chief
Licensing Branch No. 3
Division of Licensing

cc: See next page

8306140784 830510
PDR ADOCK 05000335
P PDR

OFFICE	DL:LB#3	ORB#3	ORB#3	DL:LB#3			
SURNAME	VNerses/yt	DSells	RClark	GWKnighton			
DATE	5/9/83	5/9/83	5/9/83	5/9/83			

Mr. Robert E. Uhrig, Vice President
Advanced Systems and Technology
Florida Power & Light Company
P. O. Box 14000
Juno Beach, Florida 33408

Marcia F. Reis, Esq.
Lowenstein, Newman, Reis, Axelrad & Toll
1005 Connecticut Avenue, N.W.
Washington, D. C. 20036

Norman A. Coll, Esq.
Steel Hector & Davis
1400 Southeast First National
Bank Building
Miami, Florida 33131

Mr. Martin H. Hodder
1731 N. E. 56th Street
Miami, Florida 33138

Resident Inspector
St. Lucie Nuclear Power Station
c/o U. S. Nuclear Regulatory Commission
7900 South A1A
Jensen Beach, Florida 33457

Regional Administrator - Region II
U. S. Nuclear Regulatory Commission
101 Marietta Street
Suite 3100
Atlanta, Georgia 30303

