

# REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8312060110 DOC. DATE: 83/11/30 NOTARIZED: NO DOCKET #  
 FACIL: 50-335 St. Lucie Plant, Unit 1, Florida Power & Light Co. 05000335  
 50-389 St. Lucie Plant, Unit 2, Florida Power & Light Co. 05000389  
 AUTH. NAME AUTHOR AFFILIATION  
 WILLIAMS, J.W. Florida Power & Light Co.  
 RECIP. NAME RECIPIENT AFFILIATION  
 EISENHUT, D.G. Division of Licensing

SUBJECT: Forwards corrected Page 1 to util 831108 ltr responding to  
 Generic Ltr 83-28 re qualifications of plant manager.


DISTRIBUTION CODE: A0558 COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2  
 TITLE: OR/Licensing Submittal: Salem ATWS Events GL-83-28

## NOTES:

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		LTTR	ENCL		ID CODE/NAME		LTTR	ENCL
	NRR ORB3 BC	01	3	3		NRR ORB3 BC	01	3	3
INTERNAL:	ELD/HDS2		1	0		IE/DQASIP		1	1
	NRR/DE/EQB		1	1		NRR/DE/MEB		1	1
	NRR/DHFS/HFEB		1	1		NRR/DHFS/LQB		1	1
	NRR/DHFS/PSRB		1	1		NRR/DL DIR		1	1
	NRR/DL/ORAB		1	1		NRR/DL/SSPB		1	1
	NRR/DSI/ASB		1	1		NRR/DSI/ICSB		2	2
	NRR/DSI/PSB		1	1		NRR/DSI/RSB		1	1
	REG FILE	04	1	1		RGN2		1	1
EXTERNAL:	ACRS		6	6		LPDR	03	1	1
	NRC PDR	02	1	1		NSIC	05	1	1
	NTIS		1	1					

TOTAL NUMBER OF COPIES REQUIRED: LTTR 33 ENCL 32





November 30, 1983  
L-83-576

Office of Nuclear Reactor Regulation  
Attention: Mr. Darrell G. Eisenhut, Director  
Division of Licensing  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Dear Mr. Eisenhut:

Re: St. Lucie Units 1 and 2  
Docket Nos. 50-335, 50-389  
Generic Letter 83-28

Please find attached a corrected copy of page one to the attachment to our letter L-83-554 dated November 8, 1983. That letter was in response to Generic Letter 83-28 and this page change corrects the description of the qualifications of the Plant Manager.

Should you or your staff have any questions on the attached information, please contact us.

Very truly yours,

*J. W. Williams, Jr.*  
J. W. Williams, Jr.  
Vice President  
Nuclear Energy Department

JWW/PLP/js

Attachment

cc: Mr. James P. O'Reilly, Region II  
Harold F. Reis, Esquire  
PNS-LI-83-715

8312060110 831130  
PDR ADDCK 05000335  
PDR

A055  
1/1

ATTACHMENT

Re: St. Lucie-Units 1 & 2  
Docket Nos. 50-335, 50-389  
Generic Letter 83-28

1.1 POST-TRIP REVIEW (PROGRAM DESCRIPTION AND PROCEDURE)

The program for ensuring that unscheduled reactor shutdowns are analyzed and a determination is made that the plant can be restarted safely is described for St. Lucie Units 1 & 2 in Operating Procedure 0030119, attached. The following comments address the items in the staff's position:

1. NRC Position

The criteria for determining the acceptability of restart.

Response

Step 19 of the procedure requires that the cause of the trip has been identified, that no abnormal conditions exist, and that the plant can be safely returned to power.

2. NRC Position

The responsibilities and authorities of personnel who will perform the review and analysis of these events.

Response

As shown in the referenced procedure, the Nuclear Plant Supervisor and the Shift Technical Advisor are both required to sign the procedure and to conclude that the plant can safely be returned to power.

3. NRC Position

The necessary qualifications and training for the responsible personnel.

Response

Plant Manager - Meets ANSI/ANS 3.1 1978 standards. He shall have acquired the experience and training normally required for examination by the NRC for an SRO, whether or not the exam is taken.

Operations Superintendent - Meets ANSI/ANS 3.1 1978 standards.

Operations Supervisor or Shift Supervisor - Meets ANSI/ANS 3.1 1978 standards. He shall hold a current SRO license on PSL 1 and 2.

Assistant Nuclear Plant Supervisor (ANPS) - Meets ANSI/ANS 3.1 1978 standards. He shall hold a current SRO license on PSL 1 or 2.