JUL 2 1 1983

NOTE TO:

V. Nerses, Project Manager, Licensing Branch #3

Division of Licensing

THRU:

F. Rosa, Chief, Instrumentation & Control Systems Branch

Division of Systems Integration

FROM:

R. Stevens, Instrumentation & Control Systems Branch

Division of Systems Integration

SUBJECT:

ST. LUCIE 2 - SYSTEMATIC ASSESSMENT OF LICENSEE PERFORMANCE

(SALP) INPUT

Plant Name: St. Lucie Plant No. 2 Docket No.: 50-389 Licensing Status: OL

Responsible Branch: LB #3

Project Manager: V. Nerses

Review Branch: ICSB Review Status: Complete DESIGNATED ORIGINAL

Certified By

The enclosure provides ICSB's response to your memorandum dated July 15, 1983 requesting Systematic Assessment of Licensee Performance (SALP) input for St. Lucie 2.

The categories listed in the attached matrix are those identified in Table 1 of NRC Appendix 0516. The ICSB considers the attributes associated with each category identified in the subject table to be sufficient to indicate performance of the licensee. N/A implies that the evaluation criterion is not applicable.

It should be noted that I have given the licensee a Category 3 rating for the evaluation criteria related to responsiveness and approach to resolution. There has been considerable NRC effort (conference calls and various submittals) expended to obtain acceptable resolutions for two particular issues which are:

- Safety classification of turbine trip circuitry and
- Surveillance requirements for ESFAS subgroup relays.

Contact: R. Stevens, ICSB X29456

	830804 CF AI	40687 830721 00CK 0500038	9		٩		•
OFFICE)		<u>.                                    </u>	- 1 . ( /			P)	•••••
SURNAME)>		ę.					,
<b>✓</b> BTAD	•						- ,
NDC FORM	210 (10.00) NDC14	2040		DECORD CO			



V. Nerses

For the latter issue, there appears to be a lack of understanding on the part of the applicant pertaining to the regulatory guidance (RG 1.22 and IEEE 338) associated with periodic testing of protection systems.

15/

Robert Stevens, Section B Instrumentation & Control Systems Branch Division of Systems Integration

Enclosure: As stated

cc: R. Mattson

R. W. Houston

R. Capra

G. Knighton

**DISTRIBUTION:** 

Docket File

ICSB R/F

R. Stevens (PF)(2)

C. Rossi

F. Rosa

St. Lucie S/F

OFFICE | ICSB/DSI | ICSB/DSI | ICSB/DSI |

SURNAME | Rotevens:ct | CERossi | FRosa | F

•• • 

## EVALUATION MATRIX ...

	•							
, ,	: EVALUATION CRITERIA						:	
ICENSING ACTION/ITEM	REVIEWER	MANAGEMENT INVOLVEMENT	APPROACH TO RESOLUTION	RESPONSIVE- NESS	ENFORCEMENT HISTORY	REPORTABLE EVENTS	·.STAFFING	TRAINING
Various I+C:	stevens	CATEGORY 2	CATEGORY	CATEGORY	CATEGORY . 2	CATEGORY 2	NA	N/A
(ICSB)			Certified By The Teager					