


EVALUATION OF  
SURVEILLANCE FREQUENCY  
OF  
ENGINEERED SAFETY FEATURES ACTUATION SYSTEM  
(ESFAS)  
SUBGROUP RELAYS

JPE-L-83-1  
Rev. 2


POWER PLANT ENGINEERING  
JUNO BEACH, FLORIDA

PREPARED BY:   
J. J. O'Neill, Jr. Cognizant Engineer

Date 20 JAN 84

APPROVED BY:   
R. P. Toscano, Supervising Engineer

Date 23 JAN 84

APPROVED BY:   
G. Fluggger, Manager

Date 23 Jan 84

Issue Date: January, 1984

Page 1 of 14

B405310312 B40522  
PDR ADOCK 05000389  
P PDR

NUCLEAR SAFETY CLASSIFICATION

QL-1 X

Not Safety Related \_\_\_\_\_

QL-2 \_\_\_\_\_

QA Requested \_\_\_\_\_

Verified by Dick Verduin Date Jan 20, 1984  
 D.A. Verduin, Verifying Engineer

NO EPP INTERFACES..... \_\_\_\_\_

<u>Discipline</u>	<u>Yes</u>	<u>No</u>	<u>Lead</u>	<u>Non-Lead Initials/Date</u>
Mechanical/Nuclear	_____	<u>X</u>	_____	<u>GDW 1/20</u>
Electrical	_____	<u>X</u>	_____	<u>W 1/23/84</u>
Instrumentation & Control	<u>X</u>	_____	_____	<u>JHC 1/20/84</u>
Civil	_____	<u>X</u>	_____	<u>ER 1/20/84</u>
Technical Licensing	_____	_____	<u>X</u>	_____

EXTERNAL INTERFACES ( )

No External Interfaces	<u>X</u>	Quality Assurance	_____
General Engineering	_____	Nuclear Analysis	_____
Nuclear Energy	_____	Security	_____
Nuclear Plant	_____	Nuclear Mutual Limited (NML)	_____
Others: _____		Construction	_____
_____		_____	_____
_____		_____	_____

### ABSTRACT

The St. Lucie Plant Unit No. 2 is provided with an Engineered Safety Features Actuation System (ESFAS) designed to automatically actuate plant protective systems in the event of Loss of Coolant, Steam Generator Tube Rupture and Steam or Feedwater Line Break Accidents. The current Technical Specifications require a semi-annual test of the ESFAS subgroup relays.

This analysis compares the change in availability of the system resulting from an extension of the subgroup relay test from once per six months to once per refueling outage (18 months). The analysis models a typical actuation channel (Safety Injection Actuation Signal (SIAS)) utilizing standard reliability techniques and published component failure rates. The results indicate that the availability of an SIAS channel is insensitive to the change in test interval. The 12 month change in test interval results in a 0.03% change in availability.

The ESFAS system, with the exception of the Auxiliary Feedwater Actuation System (AFAS), was designed under contract to Florida Power & Light and built by Consolidated Controls Corporation. The AFAS was provided by the NSSS vendor, Combustion Engineering. This analyses does not address the AFAS.

TABLE OF CONTENTS

<u>SECTION</u>	<u>TITLE</u>	<u>PAGE</u>
I	PURPOSE	1
II	METHODOLOGY	1
III	SUMMARY OF RESULTS	2
IV	DETAILED ANALYSIS	2
V	REFERENCES	5
<u>APPENDIX</u>	<u>TITLE</u>	<u>PAGE</u>
A	SIAS COMPONENT DATA AND UNAVAILABILITY CALCULATIONS	A1

LIST OF FIGURES

<u>FIGURE</u>	<u>TITLE</u>	<u>PAGE</u>
1	CONTAINMENT PRESSURE MEASUREMENT LOOP BLOCK DIAGRAM	6
2	PRESSURIZER PRESSURE MEASUREMENT LOOP BLOCK DIAGRAM	7
3	SIAS ACTUATION LOGIC	8
4	SIAS RELIABILITY BLOCK DIAGRAM LPSI PUMP 2A ACTUATION	9

## I. PURPOSE

The analysis contained herein demonstrates quantitatively the effect of ESFAS subgroup relay testing frequency on the ESFAS availability. This analysis intentionally overestimates ESFAS availability by not evaluating all possible failure modes for portions of the system other than the subgroup relays and by not including common cause failure. This is conservative in that the relative importance of the subgroup relays to the calculated system availability is maximized.

## II. METHODOLOGY

This evaluation was performed using standard reliability/availability modeling and estimation techniques. A typical subsystem of the ESFAS, the Safety Injection Actuation Signal (SIAS) was chosen as the protection system to be analyzed. From plant drawings and the St. Lucie Unit 2 Final Safety Analysis Report (FSAR) block diagrams of the measurement channel instrument loops and actuation logic were developed. The FSAR provided information on component failures which could affect system operation. Additional Failure Modes and Effects Analysis was performed as necessary.

A reliability block diagram was created to show the interrelation of the components. The Boolean expression representing the reliability diagram was written as well as the resulting probability expression for system unavailability. The component unavailabilities were calculated and combined in the system unavailability expression. The unavailability calculation was repeated for the current (semi-annual) interval and the proposed (refueling outage) surveillance interval for the subgroup relays.

Specific assumptions are identified in Section IV, DETAILED ANALYSIS.

General assumptions made are listed below:

- A. Faults in wires or cables connecting SIAS components were not considered. Their contribution to system failure is assumed to be negligible. Note that this is a conservative for the reason stated in Section I.
- B. Contributions to SIAS unavailability due to test or maintenance were not considered. This, again, is a conservative assumption.
- C. Only the automatic actuation circuitry was considered. Manual actuation was not modeled.
- D. For components whose Failure rates are listed per hour of operation a "mission time" of 10 hours is assumed. That is, the component must be operable at the start of the transient and for the first 10 hours of the transient. This assumption does not influence the unavailability calculations greatly, since it is applied mainly to the measurement channel components. These components are not large contributors to system unavailability.

- E. SIAS is initiated by either low Pressurizer pressure or high Containment pressure. Both of these conditions are assumed present for purposes of the model.

### III. SUMMARY OF RESULTS

The Safety Injection Actuation Signal (SIAS) was modeled as typical ESFAS subsystem. Faults contributing to the failure of one of the two actuation channels were identified. The availability of the actuation channel with semi-annual testing of the subgroup relays is estimated to be 0.9987. For testing on a refueling outage basis, the estimated channel availability is 0.9984. The extension of the surveillance interval has the effect of decreasing actuation channel availability by 0.03%. This represents a statistically insignificant change in the ability of the system to perform its function.

### IV. DETAILED ANALYSIS

#### A. System Description

A complete description of St. Lucie Unit 2 ESFAS appears in Section 7.3 of the St. Lucie Unit 2 Final Safety Analysis Report. A brief description of the SIAS subsystem is presented here. The SIAS is initiated by either 2 low Pressurizer pressure signals or 2 high Containment pressure signals. Figures 1 and 2 show the measurement instrument loops for these parameters. There are four independent measurement channels. One channel may be bypassed for test or maintenance. Bistable modules condition these signals and, through isolation modules, provide inputs to the actuation modules. Upon a valid trip signal, the actuation modules' relay drivers de-energize the SIAS subgroup relays which actuate safeguards equipment. The ESFAS is provided with an automatic test circuit as well as manual test capability. Figure 3 shows the actuation logic for the SIAS subsystem.

#### B. SIAS Model Description

A reliability block diagram (Figure 4) was constructed for SIAS. The system boundaries were chosen in accordance with Regulatory Guide 1.22 definitions of Protection System and Actuation Device. Included in the model are the measurement channels, bistable, isolation and actuation modules, associated power supplies, subgroup relay, control circuit and circuit breaker for the Low Pressure Safety Injection (LPSI) Pump 2A, a typical safeguard equipment. The pump and its motor driver are not included in the model since the system boundary occurs at the motor circuit breaker, a part of the actuation device. The component identifiers shown on Figure 4 may be matched to their associated components on Figures 1, 2, and 3.

#### C. SIAS Boolean and Probability Expressions

The SIAS reliability block diagram may be translated directly into a Boolean expression. The event described by the block diagram is

"Failure to automatically close LPSI Pump 2A circuit breaker, given the occurrence of low pressurizer pressure and high containment pressure conditions." The Boolean expression for this event is:

Fail to close LPSI 2A Circ Bkr. = 52- +  
 LPSI 2A Cont. Cir. + K 501 B + Auct. Circuit +  
 (PS-L-I-A x PS-L-2-A) + AM 501 +  
 (Failure of 3 of 4 Pressurizer Press. Channels x  
 Failure of 3 of 4 Containment Press. Channels)

Failure of a Pressurizer Pressure Channel (FPMA) is expressed as:

FPMA = IM 106 A + PS-4-MA + BA-106 + R-5A + PS  
 + PY-1102 A-2 + PY-1102 A + PT-1102 A

Failure of a Containment Pressure Channel (FCMA) is expressed as:

FCMA = IM 101 A + PS-1-MA + BA-101 + R-8A +  
 PS + PY-07-2A-2 + PY-07-2A +  
 PT-07-2A

Since all measurement channels are identical and no common mode failures are postulated, the failure of 3 of 4 measurement channels can be written as:

$$\begin{aligned} \text{Przr. Press.} \quad & \binom{4}{3} (\text{FPMA} \times \text{FPMA} \times \text{FPMA}) = \frac{4!}{3!1!} (\text{FPMA} \times \text{FPMA} \times \text{FPMA}) \\ & = 4 (\text{FPMA} \times \text{FPMA} \times \text{FPMA}) \end{aligned}$$

$$\begin{aligned} \text{Cont. Press.} \quad & \binom{4}{3} (\text{FCMA} \times \text{FCMA} \times \text{FCMA}) = 4 (\text{FCMA} \times \text{FCMA} \times \text{FCMA}) \end{aligned}$$

Note that this is a conservative assumption for this analysis. The ESFAS may be operated for extended periods with one measurement channel in bypass, in which case only two of three channels must fail to cause the event being modeled.

This assumption will tend to increase the importance of the subgroup relay by minimizing the contributions of other SIAS system components.

The system unavailability (Q sys) expression is written directly from the Boolean expression:

$$\begin{aligned} Q_{\text{sys}} = & Q_{52-} + Q_{\text{LPSI 2A}} + \\ & \quad \text{Cont. Cir.} \\ & Q_{K501B} + Q_{\text{Auct.}} + \\ & \quad \text{Circuit} \end{aligned}$$



$$(QPS-L-1-A \times QPS-L-2-A) + QAM 501 +$$

$$(4 Q_{FPMA}^3 \times 4 Q_{FCMA}^3)$$

Q xxx = Unavailability of Component xxx

Note that the rare event approximation is made for the measurement channel unavailabilities.

D. Availability Calculations

Appendix A to this attachment contains the individual component unavailability calculations. The individual components of the Containment pressure measurement channels are essentially the same as those of the Pressurizer pressure channel. The unavailability value calculated below for the Pressurizer pressure channel is thus valid for Containment pressure.

$$Q_{FPMA} = Q_{PT 1102 A} + Q_{PY 1102 A} + Q_{PY-1102 A-2}$$

$$+ Q_{PS} + Q_{R-5A} + Q_{BA-106}$$

$$+ Q_{PS-4-MA} + Q_{IM-106A}$$

$$= 3.4 \times 10^{-4} + 1 \times 10^{-5} + 1 \times 10^{-5}$$

$$+ 2.5 \times 10^{-4} + 1 \times 10^{-5} + 8 \times 10^{-4}$$

$$+ 2.5 \times 10^{-5} + 9 \times 10^{-6}$$

$$= 1.4 \times 10^{-3} / \text{Channel}$$

The SIAS system unavailability is calculated:

$$Q_{sys} = 1 \times 10^{-3*} + 6 \times 10^{-8} \times T$$

$$+ 2.5 \times 10^{-5} + (2.5 \times 10^{-4})^2$$

$$+ 2 \times 10^{-4} + 4 (1.4 \times 10^{-3})^3$$

$$\times 4(1.4 \times 10^{-3})^3.$$

$$Q_{sys} = 1.2 \times 10^{-3} + 6 \times 10^{-8} \times T$$

\*Includes QLPSI 2A + Q52-  
 Cont Cir

The variable T is the fault exposure time (FET) for the subgroup relay K 501 B. The FET depends on the interval between testing of the relay. The FET is calculated by:

$$T = \frac{\text{TEST INTERVAL}}{2}$$

The table shown below calculates SIAS actuation channel availability for the semi-annual (4380 HR) and refueling outage (13140 HR) surveillance intervals.

SURVEILLANCE INTERVAL	$Q_{K501B}$	$Q_{sys}$	$A_{sys}$ ( $1-Q_{sys}$ )
4380 HR	$1.3 \times 10^{-4}$	$1.3 \times 10^{-3}$	.9987
13140 HR	$3.9 \times 10^{-4}$	$1.6 \times 10^{-3}$	.9984

This represents a decrease in SIAS actuation channel availability of 0.03%.

E. Conclusion

The proposed increase in surveillance interval for the subgroup relays has a negligible effect on system availability. In addition, the increased interval should result in a decrease in the risk of inadvertent plant trips due to ESFAS testing.

V. REFERENCES

- A. PRA Procedures Guide, NUREG/CR-2300, Final Report, January 1983.
- B. Reliability Analysis of Engineered Safeguard Panels for St. Lucie Nuclear Power Station, Unit #2, Engineering Report No. 1213, Consolidated Controls Corp., April 26, 1978.
- C. St. Lucie Unit #2 Final Safety Analysis Report, Section 7.3.
- D. Component Failure Rates for Nuclear Plant Safety System Reliability Analysis, Nuclear Regulatory Commission (Draft Report issued 9/23/80 for Interim Reliability Evaluation Program use).
- E. Reactor Safety Study, WASH-1400, Rasmussen et al, October, 1975.




FIGURE 1.  
CONTAINMENT PRESSURE MEASUREMENT LOOP  
BLOCK DIAGRAM




FIGURE 2.  
PRESSURIZER PRESSURE MEASUREMENT LOOP  
BLOCK DIAGRAM

# ACTUATION LOGIC





Figure 4. SIAS RELIABILITY BLOCK DIAGRAM - LPSI PUMP 2A ACTUATION



**APPENDIX A**  
**SIAS COMPONENT DATA**  
**AND**  
**UNAVAILABILITY CALCULATIONS**

COMPONENT: LPSI 2A Cont. Cir.

DESCRIPTION: LPSI PUMP 2A Control Circuit

FAILURE MODE(S): a) Opens, shorts, various component failures

DETECTION: a) monthly pump test

EFFECT: a) Failure to auto actuate LPSI 2A pump

FAILURE RATE:  $1 \times 10^{-3}$  /demand (Wash-1400, APP. II S. 5)

FAULT EXPOSURE TIME: a) 1 month

UNAVAILABILITY:  $1 \times 10^{-3}$

NOTE: This value includes failure of the circuit breaker. See WASH-1400, Figure II 5-17 for fault tree evaluation of control circuit faults



**COMPONENT:** 52-

**DESCRIPTION:** LPSI 2A Circuit Breaker

**FAILURE MODE(S):** a) Fails to close  
b) Fails to remain closed

**DETECTION:** a) monthly pump test  
b) " " "

**EFFECT:** a) No power to LPSI 2A Pump  
b) Loss of power to LPSI 2A Pump

**FAILURE RATE:** See note below

**FAULT EXPOSURE TIME:** a) 1 month  
b) 1 month

**UNAVAILABILITY:** See note below

**NOTE:** The failure probability of the Circuit Breaker is included in the Control Circuit value.

COMPONENT: K501B (cont. 4,11)

DESCRIPTION: Subgroup actuation relay (contact 4, 11)

FAILURE MODE(S): a) coil fails to de-energize  
b) contacts fail to close

DETECTION: a) Channel functional test  
b) Channel functional test

EFFECT: a) Failure of component (LPSI PP 2A) to actuate  
b) Failure of component (LPSI PP 2A) to actuate

FAILURE RATE: 6E-8/hr (See Note 1)

FAULT EXPOSURE TIME: a) variable-T (see Note 2)  
b) variable - T (see Note 2)

UNAVAILABILITY: 6E-8/hr x T

NOTE: 1. Unless otherwise noted the failure rates listed are obtained from Consolidated Controls Corporation Engineering Report No. 1213 (April 26, 1978). The values therein are obtained from MIL-Handbook 217 B, June 1977.

2. The fault exposure time depends on the test interval. Two cases are evaluated:

a)  $T_1 = \frac{4380 \text{ HR}}{2}$  (Semi-Annual Interval)

b)  $T_2 = \frac{13140 \text{ HR}}{2}$  (Refueling Outage Interval)

COMPONENT: Auct. Circuit  
DESCRIPTION: Power supply auctioneering circuit  
FAILURE MODE(S): a) High  
DETECTION: a) Alarms  
EFFECT: a) causes Act. module failure to trip  
FAILURE RATE:  $2.5 \times 10^{-6}/\text{Hr.}$   
FAULT EXPOSURE TIME: a) immediate  
UNAVAILABILITY:  $2.5 \times 10^{-6}/\text{hr} \times 10 \text{ hr (see Note 1)}$   
 $= 2.5 \times 10^{-5}$

NOTE: 1. The only unavailability contribution is that due to failure of the circuit during the transient. Failure during standby conditions is alarmed.

COMPONENT: PS-L-1,2-SA  
DESCRIPTION: Actuation module power supply - 1,2  
FAILURE MODE(S): a) High  
DETECTION: a) Alarms  
EFFECT: a) causes Act. module failure to trip  
FAILURE RATE:  $2.5 \times 10^{-5}$ /Hr/Power Supply  
FAULT EXPOSURE TIME: a) immediate  
UNAVAILABILITY:  $2.5 \times 10^{-5}$ /hr x 10 hr (see Note 1)  
=  $2.5 \times 10^{-4}$ /Power Supply

- NOTE:
1. Failure during standby condition is alarmed. Only unavailability contribution is due to failure during transient.
  2. Failure rate obtained from Consolidated Controls Corp. Engineering Report No. 1213 (CCC-ER1213).

COMPONENT: AM 501

DESCRIPTION: SIAS Actuation module

FAILURE MODE(S): a) Non-trip condition

DETECTION: a) immediate - auto test alarm

EFFECT: a) Failure to actuate ESFAS components

FAILURE RATE:  $2 \times 10^{-5}/\text{Hr}$

FAULT EXPOSURE TIME: a) immediate

UNAVAILABILITY:  $2 \times 10^{-5}/\text{hr} \times 10 \text{ hr}$   
 $= 2 \times 10^{-4}$

NOTE: 1. Failure rate obtained from CCC-ER 1213.

COMPONENT: PT-1102 A, B, C, D

DESCRIPTION: Pressure transmitter

FAILURE MODE(S): a) ASIS, DRIFT  
b) HIGH

DETECTION: a) comparison with remaining channels  
b) RPS pretrip, trip alarms

EFFECT: a) Actuation logic becomes 2 of 3 or  
2 of 2 (with 1 channel bypassed)  
b) Same as above

FAILURE RATE:  $3.4 \times 10^{-5}/\text{Hr}$  (see Note 1)

FAULT EXPOSURE TIME: a) 8HR/2 - Shift channel check  
b) immediate

UNAVAILABILITY:  $3.4 \times 10^{-5}/\text{hr} \times 10 \text{ hr}$   
 $= 3.4 \times 10^{-4}$

Notes: 1. Value obtained from Interim Reliability Evaluation Program (IREP) Data Base.

COMPONENT: PY-1102 A, B, C, D

DESCRIPTION: Current/voltage converter

FAILURE MODE(S): a) HIGH  
b) As is, Drift

DETECTION: a) immediate  
b) comparison with other channels

EFFECT: a) RPS Hi-Przr. trip (1 channel), Alarms  
b) Failure of 1 channel to trip; logic = 2 of 3 or  
2 of 2 (if one channel bypassed)

FAILURE RATE:  $1 \times 10^{-6}/\text{Hr}$  (see Note 1)

FAULT EXPOSURE TIME: a) immediate  
b) 8/hr/2-shift Ch. Chk.

UNAVAILABILITY:  $1 \times 10^{-6}/\text{hr} \times 10 \text{ hr}$   
 $= 1 \times 10^{-5}$

Notes: 1. Value obtained from IREP Data Base.

**COMPONENT:** PY-1102 A-2 (1102 B, C, D also)

**DESCRIPTION:** Voltage to current converter

**FAILURE MODE(S):** a) HIGH  
b) As is, Drift

**DETECTION:** a) immediate  
b) comparison with other channels

**EFFECT:** a) Alarms (P1A1102 All, B, C, D; PI 1102 A, B, C, D)  
b) Failure of 1 channel to trip; logic = 2 of 3 or 2 of 2 (if one channel bypassed)

**FAILURE RATE:**  $1 \times 10^{-6}/\text{Hr}$  (see Note 1)

**FAULT EXPOSURE TIME:** a) immediate  
b)  $8/\text{hr}/2$  - shift Ch. Chk.

**UNAVAILABILITY:**  $1 \times 10^{-6}/\text{hr} \times 10 \text{ hr}$   
 $= 1 \times 10^{-5}$

**Notes:** 1. Value obtained from IREP Data Base.



COMPONENT: PS  
DESCRIPTION: DC Power Supply to Converters  
FAILURE MODE(S): a) HIGH  
DETECTION: a) immediate  
EFFECT: a) SIAS channel fails to trip  
FAILURE RATE:  $2.5 \times 10^{-5}/\text{Hr}$   
FAULT EXPOSURE TIME: a) immediate  
UNAVAILABILITY:  $2.5 \times 10^{-5}/\text{hr} \times 10 \text{ hr}$   
 $= 2.5 \times 10^{-4}$

NOTE: 1. Failure rate obtained from CCC-ER1213.

COMPONENT: R-5A  
DESCRIPTION: Precision Resistor (250Ω)  
FAILURE MODE(S): a) Open  
DETECTION: a) Manual Test, alarms, possible immediate detection  
EFFECT: a) Bistable "HI", Channel fails to trip  
FAILURE RATE:  $1 \times 10^{-6}/\text{Hr}$  (see Note 1)  
FAULT EXPOSURE TIME: a) immediate  
UNAVAILABILITY:  $1 \times 10^{-6}/\text{hr} \times 10 \text{ hr}$   
 $= 1 \times 10^{-5}$   
NOTE: 1. Failure rate obtained from CCC-ER 1213

COMPONENT: BA-106

DESCRIPTION: Lo Przr Pr. Bistable

FAILURE MODE(S): a) Non-trip condition

DETECTION: a) Manual and Auto test

EFFECT: a) 1 Ch. fails to trip, logic = 2of3 or 2of2 (if one channel bypassed)

FAILURE RATE:  $8 \times 10^{-5}/\text{Hr}$

FAULT EXPOSURE TIME: a) immediate (Auto Test)

UNAVAILABILITY:  $8 \times 10^{-5}/\text{hr} \times 10 \text{ hr}$   
 $= 8 \times 10^{-4}$

NOTE: 1. Failure rate obtained from CCC-ER 1213.

COMPONENT: PS-4-MA

DESCRIPTION: Przr Press. Bistable Power Supply

FAILURE MODE(S): a) High

DETECTION: a) Alarms

EFFECT: a) Causes high bistable output, fails bistable circ.,  
logic = 2of3 or 2of2

FAILURE RATE:  $2.5 \times 10^{-6}/\text{Hr}$

FAULT EXPOSURE TIME: a) immediate

UNAVAILABILITY:  $2.5 \times 10^{-6}/\text{hr} \times 10 \text{ hr}$   
 $= 2.5 \times 10^{-5}$

NOTE: 1. Failure rate obtained from CCC-ER 1213.

COMPONENT: IM-106A

DESCRIPTION: "A": Channel Isolation Module

FAILURE MODE(S): a) Non-trip condition

DETECTION: a) Automatic and manual test,  
auto test light and alarm

EFFECT: a) Failure of 1 ch. to trip; logic = 2 of 3  
or 2 of 2 (if one channel bypassed)

FAILURE RATE:  $9 \times 10^{-7}/\text{Hr}$

FAULT EXPOSURE TIME: a) immediate

UNAVAILABILITY:  $9 \times 10^{-7}/\text{hr} \times 10\text{hr}$   
 $= 9 \times 10^{-6}$

- NOTE:
1. Failure rate obtained from CCC-ER 1213.
  2. Failure of isolation module is assumed to be detected by automatic test circuitry.