

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8412100086      DOC. DATE: 84/12/03      NOTARIZED: YES      DOCKET #  
 FACIL: 50-335 St. Lucie Plant, Unit 1, Florida Power & Light Co.      05000335.  
 AUTH. NAME:      AUTHOR AFFILIATION  
 WILLIAMS, J.W.      Florida Power & Light Co.  
 RECIP. NAME:      RECIPIENT AFFILIATION  
 EISENHUT, D.G.      Division of Licensing

SUBJECT: Application for amend to License DPR-67, including Tech Specs  
 for containment water level & containment pressure monitor,  
 per Generic Ltr 83-37 & NUREG-0737.


DISTRIBUTION CODE: A046D      COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2+5  
 TITLE: OR Submittal: TMI Action Plan Rgmt NUREG-0737 & NUREG-0660

NOTES: 05000335  
 OL: 02/01/76

	RECIPIENT		COPIES		RECIPIENT		COPIES	
	ID CODE/NAME		LTR	ENCL	ID CODE/NAME		LTR	ENCL
	NRR ORB3 BC	01	7	7				
INTERNAL:	ACRS	34	10	10	ADM/LFMB		1	0
	ELD/HDS2		1	0	IE/DEPER DIR 33		1	1
	IE/DEPER/EPB		3	3	IE/DEPER/IRB		1	1
	NRR PAULSON, W.		1	1	NRR/DHFS DEPY29		1	1
	NRR/DL DIR 14		1	1	NRR/DL/ORAB 18		3	3
	NRR/DSI/ADRS 27		1	1	NRR/DSI/AEB		1	1
	NRR/DSI/ASB		1	1	<del>NRR/DST/RAB</del>		1	1
	NRR/DST DIR 30		1	1	<u>REG FILE</u> 04		1	1
	RGN2		1	1	RGN2/DRSS/EPRB		1	1
EXTERNAL:	LPDR	03	1	1	NRC PDR	02	1	1
	NSIC	05	1	1	NTIS		1	1

TOTAL NUMBER OF COPIES REQUIRED: LTR 42 ENCL 40





December 3, 1984  
L-84-295

Office of Nuclear Reactor Regulation  
Attention: Mr. Darrell G. Eisenhut, Director  
Division of Licensing  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Dear Mr. Eisenhut:

Reference: St. Lucie Unit Nos. 1 and 2  
Docket Nos. 50-335 and 50-389  
Generic Letter 83-37  
NUREG 0737 Technical Specifications

Florida Power & Light Company has reviewed Generic Letter 83-37 and has determined that for St. Lucie Unit No. 2, only one technical specification is outstanding. That is the technical specifications for the Heated Junction Thermal Couples (HJTC). The resolution of technical specifications for the HJTC is being pursued by the Combustion Engineering Owners Group. Upon completion of this effort by the Owners Group, FPL will submit appropriate technical specifications on this system. All other required technical specifications for St. Lucie Unit 2 were in place at the time of initial licensing.

For St. Lucie Unit 1, it has been determined that four technical specifications are outstanding. They are Automatic Feedwater Actuation System (AFAS), HJTC, Containment Pressure, and Containment Water Level. AFAS is currently scheduled for installation during the next refueling outage (Fall 1985). These technical specifications will be submitted following Cycle 7 startup. For the HJTC, the status is the same as detailed above for St. Lucie Unit 2. For Containment Pressure and Containment Water Level, attached are the proposed changed technical specification pages.

All remaining applicable Generic Letter 83-37 technical specifications are either included in proposed amendments undergoing NRC review, or included in the current technical specifications. Although there are some differences between the Generic Letter technical specifications and those included in the existing technical specifications, FPL has determined that the existing technical specifications are adequate, and therefore, no additional changes are necessary.

In accordance with 10 CFR 50.90, Florida Power & Light Company submits herewith three (3) signed originals and forty (40) copies of a request to amend Appendix A of Facility Operating License DPR-67.

8412100086 841203  
PDR ADOCK 05000335  
P PDR

*A046*  
*11*

Page 2

Mr. Darrell G. Eisenhut  
U. S. Nuclear Regulatory Commission

This amendment is submitted to include technical specifications for Containment Water Level and Containment Pressure Monitor in accordance with Generic Letter 83-37.

The proposed changes are shown on the accompanying Technical Specification pages 3/4 3-42 and 3/4 3-44.

In accordance with 10 CFR 50.91 (a) (1), it has been determined that the proposed amendment involves no significant hazards considerations in that the proposed amendment is in response to NRC's request. Therefore, no specific No Significant Hazards Considerations Determination or Safety Evaluation is attached.

In accordance with 10 CFR 50.91 (b) (1), a copy of the proposed amendment is being forwarded to the State Designee for the State of Florida.

The proposed amendment has been reviewed by the St. Lucie Facility Review Group and the Florida Power & Light Company Nuclear Review Board.

Because this proposed amendment is being made at NRC's request per Generic Letter 83-37, no application fee is required.

Very truly yours,



J. W. Williams, Jr.  
Group Vice President  
Nuclear Energy

JWW/RJS/cab

Attachments

cc: J. P. O'Reilly  
Regional Administrator, Region II  
U. S. Nuclear Regulatory Commission  
101 Marietta Street, N.W., Suite 2900  
Atlanta, GA 30303

Lyle Jerrett, Ph.D., Director  
Office of Radiation Control  
Dept. Health & Rehabilitative Services  
1317 Winewood Boulevard  
Tallahassee, FL 32301