



ST. LUCIE - UNIT 1

3/4 3-44

Amendment No. 37

TABLE 4.3-7

ACCIDENT MONITORING INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>INSTRUMENT</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL CALIBRATION</u>
1. Pressurizer Water Level	M	R
2. Auxiliary Feedwater Flow Rate	M	R
3. Reactor Coolant System Subcooling Margin Monitor	M	R
4. PORV Position Indicator	M	R
5. PORV Block Valve Position Indicator	M	R
6. Safety Valve Position Indicator	M	R
7. Containment Pressure Monitor	M	R
8. Containment Water Level	M	R

[Handwritten signature]

STATE OF FLORIDA)
) ss.
COUNTY OF DADE)

C. O. Woody, being first duly sworn, deposes and says:

That he is Vice President Nuclear Operations of Florida Power & Light Company, the licensee herein;

That he has executed the foregoing document; that the statements made in this document are true and correct to the best of his knowledge, information, and belief, and that he is authorized to execute the document on behalf of said Licensee.

C. O. Woody
C. O. Woody

Subscribed and sworn to before me this

3 day of DECEMBER, 1984.

[Signature]
NOTARY PUBLIC, in and for the County of
Dade, State of Florida.
NOTARY PUBLIC STATE OF FLORIDA
MY COMMISSION EXP. FEB 14, 1988
BONDED THRU GENERAL INS. UND.
My commission expires: 2/14/88

RECEIVED
MAY 10 1964
U.S. DEPARTMENT OF
HEALTH, EDUCATION &
WELFARE