



Commonwealth Edison
One First National Plaza, Chicago, Illinois
Address Reply to: Post Office Box 767
Chicago, Illinois 60690

Regulatory Docket File

December 3, 1976

Director of Nuclear Reactor Regulation
Attn: Mr. Dennis L. Ziemann, Chief
Operating Reactors - Branch 2
Division of Operating Reactors
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555



Subject: Dresden Station Unit 3
Diesel Generator Flood Protection
NRC Docket No. 50-249

Reference (a): G. A. Abrell Letter to D. L. Ziemann
dated October 22, 1976 - NRC Docket No. 50-249.

Dear Mr. Ziemann:

Reference (a) reported the Unit 3 diesel generator cooling water pump was expected to be installed prior to the completion of the 1976 refueling outage.

The delivery date for the replacement pump has slipped to January, 1977. The manufacturer has been unable to obtain the appropriate materials for the canned rotor pump. The installation will be completed as soon as practicable following delivery.

You will be advised of any further changes in this schedule.

One (1) signed original and 39 copies are provided for your use.

Very truly yours,

G. A. Abrell
Nuclear Licensing Administrator
Boiling Water Reactors



12488