

ATTACHMENT 2

OPERATING PROCEDURE NO. 0030119

REVISION 2

"POST TRIP REVIEW"

8510180090	851011
PDR	ADOCK 05000335
P	PDR

FLORIDA POWER & LIGHT COMPANY  
ST. LUCIE PLANT  
OPERATING PROCEDURE NO. 0030119  
REVISION 2

**FOR INFORMATION ONLY**  
This document is not controlled. Before use,  
verify information with a controlled document.

1.0 TITLE:

POST TRIP REVIEW

2.0 REVIEW AND APPROVAL:

Reviewed by Facility Review Group \_\_\_\_\_ July 25, 1983

Approved by J. H. Barrow (for) Plant Manager August 11, 1983

Revision 2 Reviewed by F R G \_\_\_\_\_ 6-20 19 85

Approved by *DA Sagan* Plant Manager 6-26 19 85

3.0 PURPOSE:

This procedure will identify any abnormal circumstances associated with a plant trip by evaluating plant conditions immediately prior to and immediately after the trip.

4.0 LIMITS AND PRECAUTIONS:

4.1 It is important that the First Out annunciator reset, RPS Trip Unit indicating lights, and any electrical system protection relay flags not be reset until their status is noted in this Post Trip Review Check List. This data is particularly important if the plant Sequence of Events Recorder has malfunctioned.

/R2

5.0 RELATED SYSTEM STATUS:

N/A

6.0 REFERENCES:

N/A

7.0 RECORDS REQUIRED:

A signed copy of this procedure with the applicable strip charts and printouts attached shall be retained as QA records in accordance with QI 17-PR/PSL-1.

/R2

S	OPS
DATE	_____
DOCT	Procedure
DOCN	0030119
SYS	_____
COMP	Completed
ITM	2

ST. LUCIE PLANT  
OPERATING PROCEDURE NO. 0030119, REVISION 2  
POST TRIP REVIEW

8.0 INSTRUCTIONS:

- 8.1 This procedure will be performed following any unplanned reactor trip after plant conditions have been stabilized. The procedure need not be performed following a planned shutdown.
- 8.2 Input from all plant personnel is vital to the correct identification of the cause of the plant trip and of any related malfunctions.
- 8.3 All data pertinent to the plant trip should be collected and kept with this procedure. If recorder charts are used in this evaluation, a clear copy should be made, and the chart returned to its recorder.
- 8.4 All blanks on the "POST-TRIP REVIEW CHECK LIST" should be filled in, use N/A where not applicable.

ST. LUCIE PLANT  
 OPERATING PROCEDURE NO. 0030119, REVISION 2  
POST TRIP REVIEW

POST TRIP REVIEW CHECK LIST

UNIT: \_\_\_\_\_

DATE / /

TIME: \_\_\_\_\_

PART 1: INITIAL CONDITIONS

A. Plant status prior to reactor trip (circle):

- (1) Unit Startup Operations
- (2) Steady State Operations
- (3) Load Changes During Routine Power Operations
- (4) Unit Shutdown Operations
- (5) Other: \_\_\_\_\_

B. Reactor Power: \_\_\_\_\_ %

C. PORV Block Valves:

MV-1403 (1476) (Circle) OPEN CLOSED  
 MV-1405 (1477) (Circle) OPEN CLOSED

D. Status of Control Stations (Circle):

- |                |     |      |
|----------------|-----|------|
| (1) DEH        | MAN | AUTO |
| (2) "A" MFRV   | MAN | AUTO |
| (3) "B" MFRV   | MAN | AUTO |
| (4) SBCS       | MAN | AUTO |
| (5) PZR. LEVEL | MAN | AUTO |
| (6) PZR. SPRAY | MAN | AUTO |
| (7) PZR. PRESS | MAN | AUTO |

E. Off-Normal status of any Trains/Portions of Safety Systems (If NORMAL mark "N/A")

- (1) REACTOR PROTECTIVE SYSTEM \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_
- (2) SAFETY INJECTION SYSTEM \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

ST. LUCIE PLANT  
OPERATING PROCEDURE NO. 0030119, REVISION 2  
POST TRIP REVIEW

POST TRIP REVIEW CHECK LIST

PART 1: (continued)

- (3) CONTAINMENT SPRAY SYSTEM \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_
- (4) CONTAINMENT ISOLATION SYSTEM \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_
- (5) MAIN STEAM ISOLATION SYSTEM \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_
- (6) AUXILIARY FEEDWATER SYSTEM \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_
- (7) EMERGENCY DIESEL GENERATORS \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

F. Test Surveillances In Progress (If NONE Mark "N/A")

<u>TEST NUMBER</u>	<u>STATUS/STEP</u>
_____	_____
_____	_____
_____	_____
_____	_____

ST. LUCIE PLANT  
OPERATING PROCEDURE NO. 0030119, REVISION 2  
POST TRIP REVIEW

POST TRIP REVIEW CHECK LIST

PART 2: PLANT RESPONSE

A. Safety System Actuation and Performance

(1) Reactor Protection System

(a) Trip actuated by:

MANUAL

REASON: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

AUTOMATIC

RPS TRIP UNITS ACTUATED: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

(b) First Out annunciator RTGB 102/202:  
\_\_\_\_\_

(c) RPS Actuation Time:

Time Last TCB Opened \_\_\_\_\_ SOE

Time Trip Logic Satisfied \_\_\_\_\_ SOE

Actuation Time (Difference) \_\_\_\_\_ (0.043 Sec. MAX)

(d) TCB-1 through TCB-8 OPEN  YES  NO

(e) All rod bottom lights energized  YES  NO

(2) ENGINEERED SAFETY FEATURE ACTUATION (CHECK):

(a) SIAS \_\_\_\_\_

(b) CIAS \_\_\_\_\_

(c) CSAS \_\_\_\_\_

(d) MSIS \_\_\_\_\_

(e) AFAS \_\_\_\_\_

(f) If any ESF was required, did it function properly?

YES  NO

(3) Did PZR Code Safety Valves lift:

NO

YES, Reseating Confirmed by: \_\_\_\_\_

ST. LUCIE PLANT  
 OPERATING PROCEDURE NO. 0030119, REVISION 2  
POST TRIP REVIEW

POST TRIP REVIEW CHECK LIST

PART 2: (continued)

(4) Did Main Steam Code Safety Valves Lift?

NO  
 YES, Reseating Confirmed by: \_\_\_\_\_

B. Control System Response:

(1) Pressurizer pressure and level control responded normally to this transient.

YES  
 NO. Did the PZR PORVs open (two or more High Pressurizer Pressure Bistables tripped at any time during transient.)

NO  
 YES. Did the PZR PORVs reclose?

NO  
 YES. Reseating Confirmed by: \_\_\_\_\_

(2) Did the following secondary systems function as required for this transient?

(a) SBCS	<input type="checkbox"/> YES	<input type="checkbox"/> NO
(b) Feedwater Control System	<input type="checkbox"/> YES	<input type="checkbox"/> NO
(c) Generator Lockout	<input type="checkbox"/> YES	<input type="checkbox"/> NO

C. Plant Electrical Alignment (Check)	<u>BEFORE TRIP</u>	<u>AFTER TRIP</u>
*Auxiliary Transformer	_____	_____
*Startup Transformer	_____	_____
Diesel Generator	_____	_____

\*Satisfactory automatic transfer of Auxiliary to Startup transformers meets the requirements of Unit 2 Tech. Spec. 4.8.1.1.1.b for automatic transfer. Sign off appropriate paragraph in AP 2-0010125, Check Sheet #12.

D. Manual Actions:

(1) Were any control stations taken from auto to manual?

NO.  
 YES. Specify station and time/sequence.

\_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

ST. LUCIE PLANT  
OPERATING PROCEDURE NO. 0030119, REVISION 2  
POST TRIP REVIEW

POST TRIP REVIEW CHECK LIST

PART 2. (continued)

(2) Other Manual Actions: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

E. Radiological Response (Include abnormal ARMS and PRMS indications): \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

F. Plant Response Comments: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

G. Attach DDPS, SOE Printouts, and any other printout or chart used to determine cause of reactor trip or to show any abnormal condition during trip.

- NO ATTACHMENTS  
 ATTACHMENTS (LIST)

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_



ST. LUCIE PLANT  
OPERATING PROCEDURE NO. 0030119, REVISION 2  
POST TRIP REVIEW

POST TRIP REVIEW CHECK LIST

PART 3: PLANT PERSONNEL STATEMENTS

A. Operations Personnel on Duty During Event:

The following personnel were directly involved with the event and may be able to supplement the information in this report if clarification is needed.

_____	_____
_____	_____
_____	_____

- B. For complicated transients, or situations where the Sequence of Events Recorder fails, attach statements from personnel involved with the trip concerning the events that preceded and followed the trip. Each individual should submit a statement concerning the way they remember the event.

If handwritten statements are prepared, include the plant conditions prior to the trip, your indications that a problem existed, your action as a result of those indications, noted equipment malfunctions or inadequacies, any unusual plant conditions or annunciators, and any identified procedure deficiencies. Also, include any information you consider important for review of this unscheduled reactor trip and any actions necessary to prevent recurrence. (Use additional sheet if necessary)

Personnel statements attached? (circle one) YES NO

Example

Name: \_\_\_\_\_ Position: \_\_\_\_\_

\_\_\_\_\_/\_\_\_\_\_/\_\_\_\_\_  
Signature Date Time



ST. LUCIE PLANT  
OPERATING PROCEDURE NO. 0030119, REVISION 2  
POST TRIP REVIEW

POST TRIP REVIEW CHECK LIST

PART 5: PRELIMINARY SAFETY ASSESSMENT: (Circle)

RCS PRESSURE REMAINED ABOVE SETPOINT FOR SIAS.	YES	NO
RCS PRESSURE REMAINED BELOW SETPOINT FOR PZR CODE SAFETY ACTUATION.	YES	NO
RCS TEMP.. DECREASE LESS THAN 100°F/HR.	YES	NO
REACTOR COOLANT WAS CONTAINED WITHIN THE RCS AND QUENCH TANK.	YES	NO
INDICATED PZR LEVEL REMAINED ON SCALE.	YES	NO
INDICATED WIDE RANGE STEAM GENERATOR LEVEL REMAINED ON SCALE.	YES	NO

PART 6: TRANSIENT DATA FOR KEY PLANT PARAMETERS:

	<u>MINIMUM</u>	<u>MAXIMUM</u>
RCS PRESSURE	_____	_____
RCS TEMPERATURE	_____	_____
PZR LEVEL	_____	_____
S/G LEVEL	_____	_____

PART 7: UNEXPECTED ASPECT OF TRANSIENT BEHAVIOR:

A. Compared with:

Previous Trip on: \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_  
Unit Date IHE #

CEN-128 or FSAR Transient: \_\_\_\_\_  
Vol # Page #

Significant Differences in Plant Response:

NO.  
 YES. Notify NPS.

EXPLAIN: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

Resolution of Differences Noted Above:

\_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

ST. LUCIE PLANT  
OPERATING PROCEDURE NO. 0030119, REVISION 2  
POST TRIP REVIEW

POST TRIP REVIEW CHECK LIST

PART 8: PROBABLE CAUSE OF TRIP:

---

---

---

---

Comments: \_\_\_\_\_

---

---

PART 9: IDENTIFICATION OF SYSTEMS WITH INADEQUATE PERFORMANCE

<u>SYSTEM/COMPONENT</u>	<u>DESCRIPTION OF PROBLEM</u>
_____	_____
_____	_____
_____	_____
_____	_____
_____	_____
_____	_____
_____	_____
_____	_____
_____	_____
_____	_____

PART 10: CORRECTIVE ACTIONS:

Ensure both cause(s) of reactor trip (Part 8) and system(s) with identified inadequate performance (Part 9) are thoroughly addressed.

---

---

---

---

---

---

ST. LUCIE PLANT  
OPERATING PROCEDURE NO. 0030119, REVISION 2  
POST TRIP REVIEW

POST TRIP REVIEW CHECK LIST

PART 11: NOTIFICATIONS

- A. ENS Notification to NRC within four hours for all Reactor Trips per 10 CFR 50.72.

Time Notified: \_\_\_\_\_

NRC Contact: \_\_\_\_\_

- B. Emergency Plan Implemented?

NO.

YES. (If YES, give classification and explain.)

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

PART 12: RESTART AUTHORIZATION:

If the cause of the plant trip cannot be determined by the Nuclear Plant Supervisor the unit will not be returned to power until an Independent Review of the event has been performed by the Facility Review Group.

- A. Based upon the information available and this review, the cause of the Reactor Trip has been identified, no unsafe conditions exist. The Plant Manager or his designee authorizes restart.

\_\_\_\_\_  
NUCLEAR PLANT SUPERVISOR

\_\_\_\_\_  
SHIFT TECHNICAL ADVISOR