



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION

RELATED TO AMENDMENT NO. 71

TO FACILITY OPERATING LICENSE NO. DPR-67

FLORIDA POWER & LIGHT COMPANY

ST. LUCIE PLANT, UNIT NO. 1

DOCKET NO. 50-335

INTRODUCTION

Florida Power & Light Company (FP&L), by letter from J. W. Williams, Jr. (FP&L) to H. L. Thompson (NRC) dated July 19, 1985, has requested two revisions to St. Lucie Plant, Unit No. 1 Technical Specification 3/4.1.3, "Movable Control Assemblies." The first revision would permit full power operation for a specified period of time following an inadvertent single dropped control element assembly (CEA). This specified amount of time depends on the initial pre-drop value of the integrated radial peaking factor ( $F_R$ ), which is measured at the plant during normal power distribution surveillances. The present Technical Specifications require a prompt and significant reduction in thermal power prior to attempting realignment of the dropped CEA. The second revision is merely a reformulation of existing Action Statement C into two separate action statements, C and H, to more clearly associate any required operator action with the applicable analysis assumptions requiring that action.

SAFETY EVALUATION

In order to allow continued full power operation for a specified period of time in the event of a single dropped CEA, the licensee performed analyses to determine the increase in assembly peak  $F_R$  values following a dropped CEA event. The CEA drop initially causes a decrease in reactor power with a resulting decrease in average reactor coolant temperature.

The reactor protection system inhibits automatic CEA withdrawal during the event. However, because of the negative value of the moderator temperature coefficient at end of cycle, this temperature decrease may cause the reactor power level to return to its initial power level. The presence of the dropped CEA would then result in a distorted core power distribution and increased power peaking factors.

8601230545 860115  
PDR ADOCK 05000335  
P PDR





For St. Lucie 1, margin was designed into the departure from nucleate boiling (DNB) limiting condition of operation (LCO) by selecting a 10% greater input value (1.87) of  $F_R$ , including uncertainties, than the maximum allowed Technical Specification limit of 1.70. Even using the input value of 1.87 in the thermal margin analysis, the resulting DNBR values were greater than the DNB specified acceptable fuel design limits (SAFDL). Therefore, the margin between the permissible normal operation limit of 1.70 and the 1.87 thermal margin input value can be utilized as available overpower margin for the single CEA drop analysis.

The results of the dropped CEA analyses show that the increase in assembly peak  $F_R$  values following a dropped CEA event is a function of the reactivity worth of the dropped CEA and the assembly's distance from the dropped CEA. Because of this, an assembly other than the one with the initial core maximum  $F_R$  can have a larger percent increase than the core maximum  $F_R$  assembly. The licensee has shown that the maximum  $F_R$  increase anywhere in the core immediately following a CEA drop would be less than 10% for cycles 5 or 6, thereby meeting the available overpower margin. One hour following a CEA drop, the maximum increase in  $F_R$  anywhere in the core could be as high as 11.7%. This means that an initial  $F_R$  of no greater than 1.67 would be required in order to meet the 1.87 thermal margin input value mentioned above.

The licensee has proposed to incorporate the attached Figure 3.1-1a into the St. Lucie 1 Technical Specifications showing the allowable time to realign a dropped CEA as a function of the initial value of  $F_R$ . The figure permits only 15 minutes of full power operation when the pre-drop value of  $F_R$  equals 1.70 even though the analyses show that at least 1 hour would be permissible. As the pre-drop value of  $F_R$  decreases to 1.67, operation at full power for up to 1 hour is allowed. Based on the CEA drop analyses mentioned previously, the staff finds this acceptable.

The second proposed change reformulates the present action statement in Technical Specification 3/4.1.3 into two separate action statements; one with applicability when CEAs are above the long term insertion limit (LTIL) and a separate one when CEAs are inserted beyond the LTIL. Since this reformulation will aid the reactor operators to better understand the underlying technical basis of each specification and action statement and will also tend to standardize the specifications between St. Lucie 1 and 2, the staff finds it acceptable.

#### ENVIRONMENTAL CONSIDERATION

This amendment involves a change in the installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20. The staff has determined that the amendment involves no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously published a proposed finding that the amendment involves no significant hazards consideration and there has been no public comment on such finding. Accordingly,

the amendment meets the eligibility criteria for categorical exclusion set forth in 10 CFR §51.22(c)(9). Pursuant to 10 CFR §51.22(b), no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendment.

#### CONCLUSION

We have concluded, based on the considerations discussed above, that (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, and (2) such activities will be conducted in compliance with the Commission's regulations, and the issuance of the amendment will not be inimical to the common defense and security or to the health and safety of the public.

Date: January 15, 1986

Principal Contributors:

L. Kopp  
D. Sells

December 12, 1985

Docket No. 50-335

Mr. J. W. Williams, Jr.  
Vice President  
Nuclear Energy Department  
Florida Power & Light Company  
P. O. Box 14000  
Juno Beach, Florida 33408

DISTRIBUTION:

Docket File	LFMB
NRC PDR	LTremper
L PDR	OPA
PBD#8 Rdg	ACRS-10
FMiraglia	WRegan
PMKreutzer-3	WJones
DSells	TBarnhart-4
JPartlow	EJordan
LJHarmon	OELD
SECY	PS Files +4

Dear Mr. Williams:

The Commission has issued the enclosed Amendment No. 70 to Facility Operating License No. DPR-67 for the St. Lucie Plant, Unit No. 1. This amendment consists of changes to the Technical Specifications in response to your application dated October 17, 1985 as supplemented by letter dated December 2, 1985.

This amendment revises the Technical Specifications to change the Linear Heat Generation Rate (LHGR) Limiting Condition for Operation (LCO) from a constant value of 15.0 Kw/ft to an axially dependent limit. In addition, the Local Power Density LCO curve and the associated Bases are changed. The fuel densification and thermal expansion uncertainty factor of 1.01 is deleted. Added is a license condition requiring the submittal of a supplement to EXXON Report XN-NF-85-117 for the Commission staff's review and approval. This supplement is to cover the complete large break LOCA spectrum results to demonstrate full compliance with the criteria of 10 CFR 50.46 and Appendix K to 10 CFR Part 50 with 15% tube plugging which will be considered following receipt of the supplement. Action on your request to allow you to exceed the limits of Figure 3.2-1 during the performance of Specification 4.1.1.4.2 is deferred until further justification is provided that shows that you can verify that the limit of 10 CFR 50.46 is not exceeded.

A copy of the related Safety Evaluation is also enclosed. The notice of issuance will be included in the Commission's next bi-weekly Federal Register notice.

Sincerely,

/S/

Donald E. Sells, Project Manager  
PWR Project Directorate #8  
Division of PWR Licensing-B

Enclosures:

1. Amendment No. 70 to DPR-67
2. Safety Evaluation

cc w/enclosures:

See next page

PBD#8\*

PKreutzer  
12/9/85

PBD#8

DSells;ef  
12/12/85

Signed

PBD#8\*

ATHadani  
12/9/85

OELD\*

JMcGurren  
12/10/85

\*See previous white for concurrences

ML013540271

1. The first part of the document discusses the importance of maintaining accurate records of all transactions and activities. It emphasizes that proper record-keeping is essential for transparency and accountability, particularly in financial matters.

2. The second part outlines the various methods and tools used to collect and analyze data. This includes the use of surveys, interviews, and statistical analysis to gather information and draw conclusions.

3. The third part focuses on the ethical considerations surrounding data collection and analysis. It highlights the need to protect individual privacy and ensure that data is used responsibly and for its intended purpose.

4. The fourth part discusses the challenges and limitations of data analysis. It acknowledges that while data can provide valuable insights, it is not always perfect and may be subject to various biases and errors.

5. The fifth part concludes the document by summarizing the key findings and recommendations. It stresses the importance of ongoing monitoring and evaluation to ensure that the data remains relevant and useful over time.

1. *Chlorophyll a* (Chl *a*) is the primary photosynthetic pigment in most plants and algae. It is a green pigment that absorbs light energy in the blue and red regions of the visible spectrum.

Docket No. 50-335

Mr. J. W. Williams, Jr.  
Vice President  
Nuclear Energy Department  
Florida Power & Light Company  
P. O. Box 14000  
Juno Beach, Florida 33408

DISTRIBUTION:

Docket File	LFMB
NRC PDR	LTremper
L PDR	OPA
PBD#8 Rdg	ACRS-10
FMiraglia	WRagan
PMKreutzer-3	WJones
DSells	TBarnhart-4
JPartlow	EJordan
LJHarmon	OELD
SECY	PS Files +4

Dear Mr. Williams:

The Commission has issued the enclosed Amendment No. to Facility Operating License No. DPR-67 for the St. Lucie Plant, Unit No. 1. This amendment consists of changes to the Technical Specifications in response to your application dated October 17, 1985 as supplemented by letter dated December 2, 1985.

This amendment revises the Technical Specifications to change the Linear Heat Generation Rate (LHGR) Limiting Condition for Operation (LCO) from a constant value of 15.0 Kw/ft to an axially dependent limit. In addition, the Local Power Density LCO curve and the associated Bases are changed. The fuel densification and thermal expansion uncertainty factor of 1.01 is deleted. Added is a license condition requiring the submittal of a supplement to EXXON Report XN-NF-85-117 for the Commission staff's review and approval. This supplement is to cover the complete large break LOCA spectrum results to demonstrate full compliance with the criteria of 10 CFR 50.46 and Appendix K to 10 CFR Part 50.

A copy of the related Safety Evaluation is also enclosed. The notice of issuance will be included in the Commission's next bi-weekly Federal Register notice.

Sincerely,

Donald E. Sells, Project Manager  
PWR Project Directorate #8  
Division of PWR Licensing-B

Enclosures:

1. Amendment No. to DPR-67
2. Safety Evaluation

cc w/enclosures:  
See next page

PBD#8  
PKreutzer  
12/9/85

PBD#8  
DSells;ef  
12/9/85

PBD#8  
ATHadani  
12/9/85

OELD

12/10/85

*No legal objection  
has been taken  
noted*  
*McGuire*





Mr. J. W. Williams, Jr.  
Florida Power & Light Company

St. Lucie Plant

CC:

Mr. Jack Shreve  
Office of the Public Counsel  
Room 4, Holland Building  
Tallahassee, Florida 32304

Resident Inspector  
c/o U.S. NRC  
7585 S. Hwy A1A  
Jensen Beach, Florida 33457

State Planning & Development  
Clearinghouse  
Office of Planning & Budget  
Executive Office of the Governor  
The Capitol Building  
Tallahassee, Florida 32301

Harold F. Reis, Esq.  
Newman & Holtzinger  
1615 L Street, N.W.  
Washington, DC 20036

Norman A. Coll, Esq.  
McCarthy, Steel, Hector and Davis  
14th Floor, First National Bank Building  
Miami, Florida 33131

Administrator  
Department of Environmental Regulation  
Power Plant Siting Section  
State of Florida  
2600 Blair Stone Road  
Tallahassee, Florida 32301

Mr. Weldon B. Lewis, County  
Administrator  
St. Lucie County  
2300 Virginia Avenue, Room 104  
Fort Pierce, Florida 33450

Mr. Charles B. Brinkman, Manager  
Washington - Nuclear Operations  
Combustion Engineering, Inc.  
7910 Woodmont Avenue  
Bethesda, Maryland 20814

Mr. Allan Schubert, Manager  
Public Health Physicist  
Department of Health and  
Rehabilitative Services  
1323 Winewood Blvd.  
Tallahassee, Florida 32301

Regional Administrator, Region II  
U.S. Nuclear Regulatory Commission  
Executive Director for Operations  
101 Marietta Street N.W., Suite 2900  
Atlanta, Georgia 30323