

18. Reactor Trip Breakers Post-Trip Review Procedures (Section 7.2.3.2., SSER 4)

Within 60 days of issuance of this amendment, the licensee shall provide the upgraded post-trip review procedures for NRC staff review.

DELETE

19. Prior to storing extended burnup fuel in the modified spent fuel pool (greater than 38,000 Mw-days/Metric ton) the licensee must submit and obtain approval of a new analysis that addresses the potential of large gap releases for the extended burnup fuel.

- D. The licensees shall fully implement and maintain in effect all the provisions of the Commission-approved physical security, guard training and qualification and safeguards contingency plans including amendments made pursuant to the authority of 10 CFR Section 50.54(p). The approved plans, which contain information described in 10 CFR Section 73.21, are collectively entitled "Florida Power and Light Company, St. Lucie Plant Security Plan," Revision 6, dated August 9, 1982; St. Lucie Plant Safeguards Contingency Plan" dated June 19, 1980; and "St. Lucie Plant Training and Qualification Plan" dated April 29, 1981, as revised by pages dated June 23, 1981. Prior to initial criticality, the licensees shall satisfy the commitments in FP&L's letters L-83-215 dated April 5, 1983 and L-83-217 dated April 6, 1983. Also prior to initial criticality, the licensees shall perform a reevaluation of vital areas with due regard to the safety-safeguards interface, and provide the NRC the results of their reevaluation.
- E. Before engaging in additional construction or operational activities which may result in a significant adverse environmental impact that was not evaluated or that is significantly greater than that evaluated in the Final Environmental Statement dated April 1982, the licensees shall provide written notification to the Office of Nuclear Reactor Regulation.
- F. - The licensees shall report any violations of the requirements contained in Section 2, Items C.(1), C.(3) through C.(17), D. and E. of this license within 24 hours by telephone and confirm by telegram, mailgram or facsimile transmission to the NRC Regional Administrator, Region II, or his designee, no later than the first working day following the violation, with a written followup report within fourteen (14) days.
- G. The licensees shall notify the Commission, as soon as possible but not later than one hour, of any accident at this facility which could result in an unplanned release of quantities of fission products in excess of allowable limits for normal operation established by the Commission.
- H. The licensees shall have and maintain financial protection of such type and in such amounts as the Commission shall require in accordance with Section 170 of the Atomic Energy Act of 1954, as amended, to cover public liability claims.

8604280078 860421  
PDR ADDCK 05000389  
P PDR