

REGULARY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: B610100426      DOC. DATE: 86/10/07      NOTARIZED: NO      DOCKET #  
 FACIL: 50-389 St. Lucie Plant, Unit 2, Florida Power & Light Co.      05000389  
 AUTH. NAME      AUTHOR AFFILIATION  
 WOODY, C. O.      Florida Power & Light Co.  
 RECIP. NAME      RECIPIENT AFFILIATION  
 THADANI, A. C.      PWR Project Directorate B

SUBJECT: Forwards response to NRC B60903 request for addl info re  
 util B60421 proposal to delete License Condition 2. C. 19 from  
 License NPF-16. Condition requires NRC approval of new  
 analysis addressing potential gas-gap burnup fuel release.

DISTRIBUTION CODE: A001D      COPIES RECEIVED: LTR 1 ENCL 1      SIZE: 3  
 TITLE: OR Submittal: General Distribution

NOTES:

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		LTR	ENCL		ID CODE/NAME		LTR	ENCL
	PWR-B EB		1	1		PWR-B PEICSB		2	2
	PWR-B FOB		1	1		PWR-B PDB LA		1	0
	PWR-B PDB PD 01		5	5		TOURIGNY, E		1	1
	PWR-B PEICSB		1	1		PWR-B RSB		1	1
INTERNAL:	ADM/LFMB		1	0		ELD/HDS2		1	0
	NRR/DHET/TSCB		1	1		NRR/ORAS		1	0
	<u>REG FILE</u> 04		1	1		RGN2		1	1
EXTERNAL:	EG&G BRUSKE, S		1	1		LPDR	03	1	1
	NRC PDR 02		1	1		NSIC	05	1	1

CONFIDENTIAL

CONFIDENTIAL

CONFIDENTIAL

CONFIDENTIAL

CONFIDENTIAL - SECURITY INFORMATION

CONFIDENTIAL - SECURITY INFORMATION

CONFIDENTIAL	CONFIDENTIAL	CONFIDENTIAL	CONFIDENTIAL	CONFIDENTIAL	CONFIDENTIAL
1	2	3	4	5	6
7	8	9	10	11	12
13	14	15	16	17	18
19	20	21	22	23	24
25	26	27	28	29	30
31	32	33	34	35	36
37	38	39	40	41	42
43	44	45	46	47	48
49	50	51	52	53	54
55	56	57	58	59	60
61	62	63	64	65	66
67	68	69	70	71	72
73	74	75	76	77	78
79	80	81	82	83	84
85	86	87	88	89	90
91	92	93	94	95	96
97	98	99	100	101	102
103	104	105	106	107	108
109	110	111	112	113	114
115	116	117	118	119	120
121	122	123	124	125	126
127	128	129	130	131	132
133	134	135	136	137	138
139	140	141	142	143	144
145	146	147	148	149	150
151	152	153	154	155	156
157	158	159	160	161	162
163	164	165	166	167	168
169	170	171	172	173	174
175	176	177	178	179	180
181	182	183	184	185	186
187	188	189	190	191	192
193	194	195	196	197	198
199	200	201	202	203	204
205	206	207	208	209	210
211	212	213	214	215	216
217	218	219	220	221	222
223	224	225	226	227	228
229	230	231	232	233	234
235	236	237	238	239	240
241	242	243	244	245	246
247	248	249	250	251	252
253	254	255	256	257	258
259	260	261	262	263	264
265	266	267	268	269	270
271	272	273	274	275	276
277	278	279	280	281	282
283	284	285	286	287	288
289	290	291	292	293	294
295	296	297	298	299	300



OCTOBER 07 1986

L-86-400

Office of Nuclear Reactor Regulation  
Attention: Mr. Ashok C. Thadani, Director  
PWR Project Directorate #8  
Division of PWR Licensing-B  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Dear Mr. Thadani:


Re: St. Lucie Unit 2  
Docket No. 50-389  
NPF-16 License Condition 2.C.19

By letter L-86-173, dated April 21, 1986, Florida Power & Light Company (FPL) submitted a proposal and supporting analysis to delete License Condition 2.C.19 from Facility Operating License NPF-16. This License Condition requires FPL to submit and obtain NRC approval of a new analysis that addresses potential gas-gap release for extended burnup fuel.

By letter dated September 3, 1986 (E. G. Tourigny to C. O. Woody), the NRC identified additional information required to continue its review of the proposed License Condition deletion. The attached responds to the staff's request for additional information.

Please contact us if you have any questions about this submittal.

Very truly yours,

  
C. O. Woody  
Group Vice President  
Nuclear Energy

COW/EJW/gp

Attachment

cc: Dr. J. Nelson Grace, Region II, USNRC  
Mr. Alan Schubert, Florida Dept. of Health and Rehabilitative Services  
Harold F. Reis, Esquire

8610100426 861007  
PDR ADOCK 05000389  
P PDR

A001  
1/1

ATTACHMENT

QUESTIONS FOR PROPOSED ST. LUCIE UNIT NO. 2  
OPERATING LICENSE CONDITION AMENDMENT  
DOCKET NO. 50-389, NPF-16 LICENSE CONDITION 2.C.19  
TAC NO. 61332

1. How was the peak rod power history in Figure 1 determined? Does the power history bound normal operational transients? What conservatisms have been included to assure that this history is bounding? This is of particular concern because the rod linear powers allowed by the Technical Specifications exceed those in Figure 1.

Response:

The peak rod power history shown on Figure 1 is based on St. Lucie Unit 2 Cycle 3 steady-state kw/ft fuel performance data. These data were generated in a manner to assure that future cycles are bounded, including necessary conservatisms. The fuel temperatures shown on Figure 1 were calculated at the indicated peak steady-state kw/ft values and include the gap conductance degradation due to fission gas release attributable to short-term transient power variations associated with operational transients which take the linear heat rate up to the allowed Technical Specification kw/ft limits. It is important to note that the assemblies of concern for this analysis are those with high burnup (> 38,000 MWD/MTU) and consequently low power generation. As a result, the possibility of achieving the rod linear power allowed by Technical Specifications with these high burnup assemblies is unrealistic and conservative. In addition, since the release fraction and fission product concentration of the controlling isotope is proportional to the kw/ft (and associated fuel temperature), the assemblies with the lower burnup (and hence higher reactivities) are more limiting as far as the fuel handling accidents are concerned. These accidents are more limiting early in life before the initiation of fuel pellet-clad contact.

Any normal operational transients that would impact the rod linear heat rate will preferentially affect fuel below 38 GWD/MTU. This is due to the low reactivity/power associated with the higher burnup fuel. The latter, in conjunction with the conservatisms included in the generation of the fuel rod power history, provides a strong basis of confidence that the power history bounds normal operational transients.

2. Has the ANSI/ANS 5.4 model been incorporated in the FATES3A code and used for the fuel temperature calculations provided in Figures 2 and 3?

**Response:**

The ANSI/ANS 5.4 model is not incorporated in FATES3A. As stated in paragraph 2 of the safety analysis report, the fuel rod radial temperature distributions shown on Figures 2 and 3 were generated with the NRC approved FATES3A code using bounding fuel rod power histories. These temperature distributions, which are a function of fuel rod burnup and local power level, were then used as an input to the applicable equations found in ANSI/ANS-5.4-1982 to calculate the I-131 release fractions.

3. The approach used in this analysis to calculate an average release for a rod based on the average linear power and one axial node assumes that fission gas release is linear in relation to local power and temperature when in fact it is a very non-linear phenomena. (The use of the factor between assembly to peak rod power in this analysis also assumes linearity.) Fuel performance codes such as FATES3A were developed with the capability to model several axial nodes at different powers and temperatures in order to account for this non-linearity. Please show that this one axial node approach used to calculate fission gas release for a rod is conservative in relation to an analysis with several axial nodes.

**Response:**

A bounding axial distribution of kw/ft was used. The axial distribution of the peak kw/ft was calculated for each of the burnup ranges. This peak axial kw/ft was then conservatively assumed to extend over the entire length of the fuel in each burnup interval. That is, the decrease in kw/ft near the top and bottom ends of the fuel was not credited in computing the release fraction. This is conservative because:

1. the release fraction decreases as fuel temperatures decrease due to decreasing linear heat rates near the bottom and top of the fuel rods (as shown in Figures 2 and 3), and,
2. the equilibrium limiting isotope concentration also decreases as a function of decreasing kw/ft.