

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8612150308 DDC. DATE: 86/12/12 NOTARIZED: YES DOCKET #
 FACIL: 50-335 St. Lucie Plant, Unit 1, Florida Power & Light Co. 05000335
 AUTH. NAME AUTHOR AFFILIATION
 WOODY, C. O. Florida Power & Light Co.
 RECIP. NAME RECIPIENT AFFILIATION
 THADANI, A. C. PWR Project Directorate 8

SUBJECT: Application for amend to License DPR-67, changing Tech Specs to specify steam generator tube plugging limit of 54% for all regions except limit of 50% for locations at or above top support plate for tube rows 117 through 120.

SEE PROPOSED CHANGES TO TECH SPECS.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 3 ENCL 40 SIZE: 3+106
 TITLE: DR Submittal: General Distribution

NOTES:

RECIPIENT ID CODE/NAME	COPIES		RECIPIENT ID CODE/NAME	COPIES	
	LTR	ENCL		LTR	ENCL
PWR-B EB	1	1	PWR-B PEICSB	2	2
PWR-B FOB	1	1	PWR-B PDB LA	1	0
PWR-B PDB PD 01	5	5	TOURIGNY, E	1	1
PWR-B PEICSB	1	1	PWR-B RSB	1	1

INTERNAL: ADM/LEMR	1	0	ELD/HDS2	1	0
NRR/DHFT/TSCB	1	1	NRR/ORAS	1	0
REG FILE 04	1	1	RGN2	1	1
EXTERNAL: EG&G BRUSKE, S	1	1	LPDR 03	1	1
NRC PDR 02	1	1	NSIC 05	1	1

Rec'd w/ check \$150.00



1950


1950

1950

1950

1950

1950



DECEMBER 12 1986

L-86-502

Office of Nuclear Reactor Regulation
Attention: Mr. Ashok C. Thadani, Director
PWR Project Directorate #8
Division of PWR Licensing - B
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Dear Mr. Thadani:

Re: St. Lucie Unit I
Docket No. 50-335
Proposed License Amendment
Steam Generator Tube Plugging Limit

In accordance with 10 CFR 50.90, Florida Power & Light Company (FPL) submits herewith three signed originals and forty copies of a request to amend Facility Operating License DPR-67.

The proposed amendment revises the steam generator tube plugging limit as defined in Section 4.4.5.4 of the St. Lucie Unit I Technical Specifications. The current steam generator tube plugging limit is 40% of the nominal tube wall thickness. The proposed change will specify a tube plugging limit of 54% for all regions except that a limit of 50% will apply to locations at or above the top support plate for tube rows 117 through 120, inclusive. In addition, justification for uncertainty values assigned to eddy current testing (ECT) and growth rates during the operating cycle are also presented.

It should be noted that results of FPL's previous ECT examinations and destructive examination of pulled tubes revealed very good correlation between detected and actual indications. These results also demonstrated that there was no significant growth in the indications. FPL will continue to monitor and trend the growth of the inter-granular attack for all future examinations. These results will be compared to the assumed rate in the attachment to ensure that we remain within the limits of the analysis.

Marked up copies of the affected Technical Specification pages are included as Attachment A. A Safety Evaluation in support of the proposed amendment is included as Attachment B. Attachment C is a justification for 10% uncertainty allowance for Eddy Current Testing (ECT) error and continued operation for the duration of the next cycle. Attachment D is a discussion of St. Lucie Unit I allowable tube wall degradation. A "Determination of No Significant Hazards Consideration" is provided as Attachment E.

8612150308 861212
PDR ADOCK 05000335
PDR

A001
3/40

Rec'd w/check #150.00

EJW2/024/1

... ..
... ..
... ..
... ..

... ..

... ..

... ..

... ..

... ..

... ..

... ..

Mr. Ashok C. Thadani, Director
L-86-502
Page two


The proposed amendment has been reviewed by the St. Lucie Facility Review Group and the Florida Power & Light Company Nuclear Review Board.

In accordance with 10 CFR 50.91(b)(1), a copy of the proposed amendment is being forwarded to the state designee for the State of Florida.

In accordance with 10 CFR 170.21, FPL Check No. 2947 is attached as remittance for the license amendment application fee.

Please contact us if you have any questions about this submittal.

Very truly yours,


C. O. Woody
Group Vice President
Nuclear Energy

COW/EJW/cab

Attachments (6)

cc: Dr. J. Nelson Grace, USNRC, Region II
Mr. Alan Schubert, Florida Dept. of Health and Rehabilitative Services
Harold F. Reis, Esquire, Newman & Holtzinger

The first part of the document discusses the importance of maintaining accurate records of all transactions. It emphasizes that every entry should be supported by a valid receipt or invoice. This ensures transparency and allows for easy verification of the data.

Furthermore, it is noted that regular audits are essential to identify any discrepancies or errors early on. By conducting these checks frequently, the organization can prevent small mistakes from escalating into larger financial issues.

In addition, the document highlights the need for clear communication between all departments involved in the financial process. This includes the accounting, sales, and procurement teams. Ensuring that everyone is on the same page helps to streamline operations and reduce the risk of miscommunication.

The second section of the document focuses on the implementation of robust internal controls. These controls are designed to safeguard the organization's assets and ensure that all financial activities are conducted in accordance with established policies and procedures.

Key elements of these controls include the separation of duties, which prevents any single individual from having too much control over a financial process. This is particularly important in areas like cash handling and asset management.

Another critical component is the use of secure information systems. Investing in reliable software and hardware helps to protect sensitive financial data from unauthorized access or loss. Regular updates and security audits are also necessary to maintain the integrity of these systems.


Finally, the document stresses the importance of training and education for all employees. Ensuring that staff members understand their roles and responsibilities regarding financial matters is crucial for the overall success of the organization's internal control system.

STATE OF FLORIDA)
)
COUNTY OF PALM BEACH) ss.

C. O. Woody being first duly sworn, deposes and says:

That he is a Group Vice President of Florida Power & Light Company, the Licensee herein;


That he has executed the foregoing document; that the statements made in this document are true and correct to the best of his knowledge, information, and belief, and that he is authorized to execute the document on behalf of said Licensee.



C. O. Woody

Subscribed and sworn to before me this

12 day of December, 1986.



L. M. Dulinos

NOTARY PUBLIC, in and for the County
of Palm Beach, State of Florida

My Commission expires: NOTARY PUBLIC STATE OF FLORIDA
MY COMMISSION EXP SEPT 18, 1989
BONDED THRU GENERAL INS. UND.

THE
OFFICE OF THE
ATTORNEY GENERAL
STATE OF TEXAS
AUSTIN, TEXAS



—