

ATTACHMENT I

Marked-up Technical Specification Page:

3/4 2-3

8612310352 861223  
PDR ADOCK 05000335  
P PDR

1. 1944

2. 1945

ALLOWABLE PEAK LINEAR HEAT RATE, KW/FT  
(FUEL + CLAD + MODERATOR)





FIGURE 3.2-1  
ALLOWABLE PEAK LINEAR HEAT RATE VS. BURNUP



ATTACHMENT 2  
SAFETY EVALUATION

Background

The proposed change to the Linear Heat Rate Limiting Condition for Operation (LHR LCO), Technical Specification 3.2.1, Figure 3.2-1, Allowable Peak Linear Heat Rate vs. Burnup, is to raise the allowable peak linear heat generation rate to 15 kw/ft for all axial elevations for all times in life. The basis for this change is found in Reference 1.

Discussion

The key changes in the analysis found in Reference 1 from the previous LOCA analysis (Reference 2) are: 1) Steam Generator Tube Plugging limit raised from 11% to 15%, 2) Use of the recently approved FCTF reflood correlations instead of the FLECHT reflood correlations, and 3) Use of less conservative, though still bounding, combinations of stored energy and axial shapes.

Of the three changes, two of them have been previously reviewed and approved by the NRC. The effects of 15% Steam Generator Tube Plugging have been previously analyzed (Reference 3) and approved for St. Lucie Unit 1 and the use of the FCTF reflood correlations has been generically approved for the Exxon Nuclear Company, Inc. (ENC) (Reference 4). The other change, use of less conservative combinations of stored energy and axial shape, has been examined by using two ranges of exposure rather than simply combining the bounding stored energy value, found near Beginning of Life (BOL), and the bounding axial shape found at End of Life (EOL). Within the exposure range, the combination of worst stored energy and axial shape were used. The two ranges of exposure were: 1) from 0.0 to 10.0 MWD/kg hot rod average burnup and 2) 10.0 MWD/kg to EOL. The axial shapes chosen are limiting in that there are no calculated axial power distributions which peak higher in the core and whose shape about the peak falls off slower. This technique, therefore, uses a more realistic approach to evaluating burnup effects while still retaining significant conservatism.

The analyses described in Reference 1 have been used to demonstrate that, with a 15 kw/ft LCO on LHR, all criteria are satisfied. A review of these results indicates the following.

- (a) The calculated peak fuel element clad temperature does not exceed the 2200°F limit.
- (b) The amount of fuel element cladding that reacts chemically with water or steam does not exceed 1% of the total amount of zircaloy in the reactor.
- (c) The cladding temperature transient is terminated at a time when the core geometry is still amenable to cooling. The hot fuel rod cladding oxidation limits of 17% are not exceeded during or after quenching.
- (d) The system long term cooling capabilities provided for previous cores remain applicable for ENC fuel.

The Acceptance Criteria as presented in 10 CFR 50.46(b)(1), (b)(2), (b)(3), (b)(4), and (b)(5) are satisfied based on these results.

The first part of the document discusses the importance of maintaining accurate records of all transactions. It emphasizes that every entry should be supported by proper documentation and that the books should be kept up-to-date at all times.

In the second section, the author details the various methods used to collect and analyze data. This includes the use of questionnaires, interviews, and focus groups to gather information from a diverse range of participants. The data is then analyzed using statistical techniques to identify trends and patterns.

The third section describes the results of the study and the conclusions drawn from the data. It highlights the key findings and discusses their implications for practice and policy. The author also acknowledges the limitations of the study and suggests areas for further research.

Finally, the document concludes with a summary of the main points and a call to action for stakeholders to take the findings into account. The author expresses hope that the research will contribute to a better understanding of the issues at hand and lead to positive change.

## References

1. "St. Lucie Unit I LOCA-ECCS Analysis with 15% Steam Generator Tube Plugging", XN-NF-86-137, Exxon Nuclear Company, November 1986.
2. "St. Lucie Unit I LOCA-ECCS Analysis with 11% Steam Generator Tube Plugging", XN-NF-86-23, Revision 1, Exxon Nuclear Company, March, 1986.
3. "St. Lucie Unit I Revised LOCA-ECCS Analysis with 15% Steam Generator Tube Plugging", XN-NF-86-117, Exxon Nuclear Company, November 1985.
4. U. S. Nuclear Regulatory Commission letter to G. N. Ward from D. M. Crutchfield, "Safety Evaluation of Exxon Nuclear Company's Large Break ECCS Evaluation Model", EXEM/PWR and Acceptance for Referencing Related Topical Reports, July 8, 1986.

The following information was obtained from the files of the  
 FBI, New York Office, on October 10, 1952, regarding the  
 activities of the Communist Party, USA, in the New York  
 area, during the period from 1945 to 1952. The  
 information was obtained from the files of the  
 New York Office, and is being furnished to you for  
 your information. The information is being furnished  
 to you in confidence, and is not to be  
 disseminated outside of your office.



## ATTACHMENT 3

### DETERMINATION OF NO SIGNIFICANT HAZARDS CONSIDERATION

The standards used to arrive at a determination that a request for amendment involves no significant hazards consideration are included in the Commission's regulations, 10 CFR 50.92, which states that no significant hazards considerations are involved if the operation of the facility in accordance with the proposed amendment would not (1) involve a significant increase in the probability or consequences of an accident previously evaluated; or (2) create the possibility of a new or different kind of accident from any accident previously evaluated or (3) involve a significant reduction in a margin of safety. Each standard is discussed as follows:

- (1) Operation of the facility in accordance with the proposed amendment would not involve a significant increase in the probability or consequences of an accident previously evaluated.

The plant will be operated in essentially the same manner as before and no change in plant configuration has occurred. Therefore, there is no increase in the probability of accidents previously evaluated.

The accident analyses have been evaluated and have been found to be bounded by the consequences of accidents previously analyzed.

- (2) Use of the modified specification would not create the possibility of a new or different kind of accident from any accident previously evaluated.

The plant will be operated in essentially the same manner as before and no change in plant configuration is involved. Therefore, there will be no possibility of a new or different accident.

- (3) Use of the modified specification would not involve a significant reduction in a margin of safety.

The Acceptance Criteria for emergency core cooling systems for light water nuclear power reactors is specified by 10 CFR 50.46. The input changes that result from this amendment provide results within the Acceptance Criteria of 10 CFR 50.46.

Based on the above, we have determined that the amendment request does not (1) involve a significant increase in the probability or consequences of an accident previously evaluated, (2) create the probability of a new or different kind of accident from any accident previously evaluated, or (3) involve a significant reduction in a margin of safety; and therefore does not involve a significant hazards consideration.

Handwritten title or header text, possibly a date or location.

First paragraph of handwritten text, starting with a capital letter.

Second paragraph of handwritten text, continuing the narrative.

Third paragraph of handwritten text, shorter than the previous ones.

Fourth paragraph of handwritten text, starting with a capital letter.

Fifth paragraph of handwritten text, continuing the narrative.

Sixth paragraph of handwritten text, shorter than the previous ones.

Seventh paragraph of handwritten text, continuing the narrative.

Eighth paragraph of handwritten text, continuing the narrative.