

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8701130163      DOC. DATE: 87/01/09      NOTARIZED: NO      DOCKET #  
 FACIL: 50-389 St. Lucie Plant, Unit 2, Florida Power & Light Co.      05000389  
 AUTH. NAME      AUTHOR AFFILIATION  
 WOODY, C. O.      Florida Power & Light Co.  
 RECIP. NAME      RECIPIENT AFFILIATION  
    Record Services Branch (Document Control Desk)

SUBJECT: Forwards confirmatory analysis per 861016 Amend 16 to License NPF-16 re low temp overpressure protection. Confirmatory analysis, "Possible Low Temp Overpressure Protection Sys Alignments... included in 861016 ltr.


DISTRIBUTION CODE: A001D      COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 7  
 TITLE: OR Submittal: General Distribution

NOTES:

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		LTR	ENCL		ID CODE/NAME		LTR	ENCL
	PWR-B EB		1	1		PWR-B PEICSB		2	2
	PWR-B FOB		1	1		PWR-B PDB LA		1	0
	PWR-B PDB PD 01		5	5		TOURIGNY, E		1	1
	PWR-B PEICSB		1	1		PWR-B RSB		1	1
INTERNAL:	ADM/LFMB		1	0		ELD/HDS2		1	0
	NRR/DHFT/TSCB		1	1		NRR/ORAS		1	0
	<u>REG FILE</u> 04		1	1					
EXTERNAL:	EG&G BRUSKE, S		1	1		LPDR 03		1	1
	NRC PDR 02		1	1		NSIC 05		1	1

TOTAL NUMBER OF COPIES REQUIRED: LTR 22 ENCL 18

1942  
1943  
1944  
1945  
1946  
1947  
1948  
1949  
1950  
1951  
1952  
1953  
1954  
1955  
1956  
1957  
1958  
1959  
1960  
1961  
1962  
1963  
1964  
1965  
1966  
1967  
1968  
1969  
1970  
1971  
1972  
1973  
1974  
1975  
1976  
1977  
1978  
1979  
1980  
1981  
1982  
1983  
1984  
1985  
1986  
1987  
1988  
1989  
1990  
1991  
1992  
1993  
1994  
1995  
1996  
1997  
1998  
1999  
2000  
2001  
2002  
2003  
2004  
2005  
2006  
2007  
2008  
2009  
2010  
2011  
2012  
2013  
2014  
2015  
2016  
2017  
2018  
2019  
2020  
2021  
2022  
2023  
2024  
2025



JANUARY 09 1987

L-87-4

U. S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, D. C. 20555

Gentlemen:


Re: St. Lucie Unit 2  
Docket No. 50-389  
Confirmatory Analyses for  
Low Temperature Overpressure Protection

By letter dated October 16, 1986 (E. G. Tourigny to C. O. Woody) the NRC issued Amendment No. 16 to Facility Operating License No. NPF-16 for St. Lucie Unit 2. This amendment consisted of changes requested by Florida Power & Light Company (FPL) to the reactor coolant system pressure/temperature limit figures. The amendment also added the shutdown cooling system (SDCS) relief valves as Low Temperature Overpressure Protection (LTOP) devices.

In the Safety Evaluation issued with Amendment No. 16, the staff required FPL to submit confirmatory analyses by January 15, 1987. The confirmatory analyses, entitled "Possible LTOP System Alignments and the Required Supporting Analyses" were included as an attachment to the staff's October 16, 1986 letter. Attached to this letter are the above required confirmatory analyses.

Please contact us if you have any question about these analyses.

Very truly yours,

  
C. O. Woody  
Group Vice President  
Nuclear Energy

COW/EJW/gp

Attachment

cc: Dr. J. Nelson Grace, Region II, USNRC  
Mr. Alan Schubert, Florida Dept. of Health and Rehabilitative Services  
Harold F. Reis, Esquire

8701130163 870109  
PDR ADOCK 05000389  
P PDR

*Adol*

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

26

27

28

29

30

31

32

33

34

35

36

37

38

39

40

41

42

43

44

45

46

47

48

49

50

51

52

53

54

55

56

57

58

59

60

61

62

63

64

65

66

67

68

69

70

71

72

73

74

75

76

77

78

79

80

81

82

83

84

85

86

87

88

89

90

91

92

93

94

95

96

97

98

99

100

ATTACHMENT

CONFIRMATORY ANALYSES REQUIRED  
PER ST. LUCIE UNIT 2  
AMENDMENT No. 16 TO FACILITY OPERATING LICENSE NPF-16

Response to 1.a.

A mass addition transient due to simultaneous operation of two High Pressure Safety Injection (HPSI) and three charging pumps was considered as one of the two most limiting pressure transients which provided a basis for the original St. Lucie Unit 2 Low Temperature Overpressure Protection (LTOP) system. (See Reference (1), Subsection 5.2.6.2.1). The original LTOP system was also based on the Pressure/ Temperature (P/T) limits for 0 to 2 years and included two Power Operated Relief Valves (PORVs) with the LTOP setpoints of 460 psia and 490 psia which were designated for transient mitigation over the entire LTOP temperature range.

To preclude violation of the P/T limits for 5 Effective Full Power Years (EFPY), 10 EFPY, etc., in the case of a pressure transient at the lower Reactor Coolant System (RCS) temperatures, a lower relief valve setpoint was required. It was determined that reducing the setpoint would not, by itself, preclude violation of new P/T limits if the limiting pressure transients previously assumed were also used as a basis for a new LTOP analysis.

As a result, less severe overpressurization events were assumed for the new St. Lucie Unit 2 LTOP system. (See Reference (2), Response to Question 1). These assumptions, although less conservative than those used previously, meet the requirements for LTOP systems, specified in Reference (3), and the Limiting Conditions for Operation (LCOs) of Reference (4), paragraphs 3.1.2.3, 3.1.2.4, 3.5.2, and 3.5.3.

CONFIDENTIAL

CONFIDENTIAL  
CONFIDENTIAL  
CONFIDENTIAL

CONFIDENTIAL

CONFIDENTIAL

CONFIDENTIAL

CONFIDENTIAL

CONFIDENTIAL

CONFIDENTIAL

CONFIDENTIAL

CONFIDENTIAL

In the most recent LTOP evaluation, no HPSI pumps were assumed to be operable at Tc 200°F. However, a mass addition transient due to simultaneous operation of one HPSI and three charging pumps at these temperatures was analyzed. The peak RCS pressure in this transient, if mitigated by one Shutdown Cooling System (SDCS) relief valve, was calculated to be 345 psia.

An analysis was performed to determine if one HPSI pump can be operable to Tc 185°F if the RCS is depressurized with a vent of greater than or equal to 3.58 square inches. The analysis confirmed that one HPSI pump can be operable under the above conditions. As a result Technical Specifications 3.1.2.1 and 3.1.2.3 requiring HPSI pump operation were satisfied.

An additional evaluation revealed a marginal difference between the peak pressure of 345 psia discussed above and the controlling pressure of 343 psia which was used to identify heatup and cooldown rates. (This controlling pressure was assumed to equal the rounded off peak pressure in the Reactor Coolant Pump (RCP) start transient with one SDCS relief valve.) Using  $P_{cont} = 345$  psia instead of  $P_{cont} = 343$  psia does not significantly change the identified heatup and cooldown rates.

Consequently, it was concluded that, based on LTOP considerations, one HPSI pump can be aligned to the RCS during the entire LTOP mode including the RCS temperatures below 185°F.

#### Response to I.c.

Following are the sequences of events during the most limiting pressure transients which were used as a basis for the St. Lucie Unit 2 LTOP analysis.

[The text in this block is extremely faint and illegible. It appears to be a multi-paragraph document with several lines of text per paragraph. The content is not discernible.]



I. RCP Start in Water-Solid RCS  
With Secondary-to-Primary T = 40°F

IA. With a PORV

<u>Time (sec)</u>	<u>Event</u>	<u>Analysis Setpoint or Value (psia)</u>
0.0	Operator starts a RCP. RCS pressure begins to rise from the initial value	300
6.4	PORV opens at the specified setpoint	470
6.5	RCS pressure reaches a peak (at the PORV inlet) and starts decreasing	473.3
7.1	PORV closes at the reseal pressure and RCS pressure begins to rise	462
6.4 - 600	PORV cycles open and closed. Peak pressures at the PORV inlet	471.0 to 474.5

IB. With a SDCS Relief Valve (SDCSR)

<u>Time (sec)</u>	<u>Event</u>	<u>Analysis Setpoint or Value (psia)</u>
0.0	Operator starts a RCP. RCS pressure begins to rise from the initial value	300
3.0	SDCSR starts opening at 3% accumulation	360
3.1	RCS pressure reaches a peak (at the SDCSR inlet) and starts decreasing	362.1
3.7	RCS pressure reaches a minimum, and starts increasing	359.8
9.0	RCS pressure reaches a maximum (at the SDCSR inlet) and starts decreasing slowly	362.1
9.0-600 <sup>(1)</sup>	RCS pressure continues to decrease with the SDCSR partially open, or until the valve closes at 10% blowdown	316.5

(1) The transient was not analyzed up to t = 600 sec. However, in either case, the peak pressure of 362.1 psia will not be exceeded, because the intensity of the transient diminishes with time.

THE UNIVERSITY OF CHICAGO  
DIVISION OF THE PHYSICAL SCIENCES

PHYSICS DEPARTMENT

Chicago, Illinois

1954

Dear Mr. [Name]:

I have received your letter of [Date] regarding [Subject]. The information you provided is being reviewed by the appropriate committees. We will contact you again once a decision has been reached.

I am sorry that I cannot provide a more definitive answer at this time. The process of review is ongoing, and we are committed to a thorough evaluation of all applications.

If you have any further questions or need additional information, please do not hesitate to contact me. We appreciate your interest in our institution and the time you have spent in the application process.

Sincerely,  
[Signature]

II. Mass Addition Due to One HPSI and Three Charging Pump Operation  
in Water-Solid RCS, with a PORV

<u>Time (sec)</u>	<u>Event</u>	<u>Analysis Setpoint or Value (psia)</u>
0.0	Inadvertent safety injection actuation. RCS pressure begins to rise from the initial value	300
3.3*	PORV opens at the specified setpoint and RCS pressure starts decreasing	470
4.0*	PORV closes at the reseal pressure and RCS pressure begins to rise	462
3.3 - 600	PORV cycles open and closed. Peak pressures at the PORV inlet	470**

---

\* Estimated

\*\* Based on comparison between the setpoint and the equilibrium pressure of 375 psia which was calculated for this transient.

1944

1945

1946

Response to I.d

Three overpressurization events were chosen and analyzed, as indicated in Reference (2), Response I. These are:

- RCP Start
- Two charging pump operation
- Inadvertent actuation of a HPSI pump, with simultaneous operation of three charging pumps.

These events were assumed to be mitigated by either one PORV, with a setpoint of 470 psia, or one SDCS relief valve, with a setpoint of 350 psia. The pressure transient analyses result in the peak (maximum) RCS pressures in each transient. These pressures are provided below:

	<u>w/PORV</u> <u>(psia)</u>	<u>w/SDCS Relief</u> <u>Valve (psia)</u>
(1) RCP Start	535	342.7
(2) Two Charging Pumps	473	341.0
(3) 1 HPSIs and 3 Charging Pumps	492	345.0

The identified controlling pressures (i.e. the most limiting pressures) were as follows:

$P_{cont} = 535$  psia, when LTOP is provided by the PORVs.

$P_{cont} = 343$  psia, when LTOP is provided by the SDCS relief valves.

It should be noted that a controlling pressure generally identifies an RCS pressure limit which will not be exceeded during any overpressurization event that could occur in the corresponding temperature region while being mitigated by an applicable relief valve. When applied to 10 CFR 50 Appendix G P/T limit curves, a controlling pressure also provides a lower bound pressure limit for these curves. In other words, a controlling pressure is generally more limiting than the P/T limits above it. Therefore, no P/T limits above the controlling pressure will be exceeded during normal operation or an overpressurization event.

... ..

... ..

... ..

... ..

... ..

... ..

... ..

... ..

... ..

P/T limits below the controlling pressure are considered theoretical since restrictions on heatup and cooldown rates (which are a part of LTOP requirements) prevent operation based on these limits.

#### REFERENCES

- 1) St. Lucie Unit 2 Final Safety Analysis Report
- 2) FPL Letter L-86-353 dated September 4, 1986
- 3) NRC Branch Technical Position RSB 5-2, Overpressurization Protection of Pressurized Water Reactors While Operating at Low Temperatures
- 4) St. Lucie Unit 2 Technical Specifications

... of the ...  
... of the ...  
... of the ...

... of the ...  
... of the ...  
... of the ...