

PLANT SYSTEMS

3/4 7.10 SNUBBERS

LIMITING CONDITION FOR OPERATION

3.7.10 ^{safety related} All snubbers listed in Tables 3.7-2a and 3.7-2b shall be OPERABLE.

APPLICABILITY: MODES 1, 2, 3 and 4. (MODES 5 and 6 for snubbers located on systems required OPERABLE in those MODES).

ACTION:

With one or more ^{safety related} snubbers inoperable, within 72 hours replace or restore the inoperable snubber(s) to OPERABLE status or declare the supported system inoperable and follow the appropriate ACTION statement for that system.

SURVEILLANCE REQUIREMENTS

4.7.10 Each snubber shall be demonstrated OPERABLE by performance of the following augmented inservice inspection program.

a. Visual Inspections

~~The first inservice visual inspection of snubbers shall be performed after four months but within 10 months of commencing POWER OPERATION and shall include all snubbers listed in Tables 3.7-2a and 3.7-2b. If less than two (2) snubbers are found inoperable during the first inservice visual inspection, the second inservice visual inspection shall be performed 12 months ± 25% from the date of the first inspection. Otherwise, subsequent Visual inspections shall be performed in accordance with the following schedule:~~

<u>No. Inoperable Snubbers per Inspection Period</u>	<u>Subsequent Visual Inspection Period*#</u>
0	18 months ± 25%
1	12 months ± 25%
2	6 months ± 25%
3, 4	123 days ± 25%
5, 6, 7	62 days ± 25%
8 or more	31 days ± 25%

The snubbers may be categorized into two groups: Those accessible and those inaccessible during reactor operation. Each group may be inspected independently in accordance with the above schedule.

*The inspection interval shall not be lengthened more than one step at a time unless a generic problem has been identified and corrected; in that event the inspection may be lengthened one step the first time and two steps thereafter if no inoperable snubbers are found.

#The provisions of Specification 4.0.2 are not applicable.

PLANT SYSTEMS

SURVEILLANCE REQUIREMENTS (Continued).

b. Visual Inspection Acceptance Criteria

Visual inspections shall verify (1) that there are no visible indications of damage or impaired OPERABILITY and (2) attachments to the foundation or supporting structure are secure. Snubbers which appear inoperable as a result of visual inspections may be determined OPERABLE for the purpose of establishing the next visual inspection interval, providing that (1) the cause of the rejection is clearly established and remedied for that particular snubber and for other snubbers that may be generically susceptible; and/or (2) the affected snubber is functionally tested in the as found condition and determined OPERABLE per Specifications 4.7.10.d or 4.7.10.e, as applicable.

c. Functional Tests

At least once per 18 months during shutdown, a representative sample (10% of the ^{safety related} snubbers) ~~listed in Tables 3.7-2a and 3.7-2b~~ shall be functionally tested either in place or in a bench test. For each snubber that does not meet the functional test acceptance criteria of Specification 4.7.10.d or 4.7.10.e, an additional 10% of that type of snubber shall be functionally tested. Functional testing shall continue until no additional snubbers are found inoperable or all ^{safety related} snubbers ~~listed in Tables 3.7-2a and 3.7-2b~~ have been tested.

The representative sample selected for functional testing shall include the various configurations, operating environments and the range of size and capacity of snubbers.

Snubbers identified in ~~Tables 3.7-2a and 3.7-2b~~ as "Especially Difficult to Remove" or in "High Exposure Zones During Shutdown" shall also be included in the representative sample. ~~* Tables 3.7-2a and 3.7-2b may be used jointly or separately as the basis for the sampling plan.~~

In addition to the regular sample, snubbers which failed the previous functional test shall be retested during the next test period. If a spare snubber has been installed in place of a failed snubber, then both the failed snubber (if it is repaired and installed in another position) and the spare snubber shall be retested. Test results of these snubbers shall not result in additional functional testing due to failure.

~~*The requirements of this section for functionally testing mechanical snubbers may be waived until startup following the fifth refueling outage for Unit-1.~~

*Permanent or other exemptions from the functional testing for individual snubbers in these categories may be granted by the Commission only if justifiable basis for exemption is presented and/or snubber life destructive testing was performed to qualify snubber operability for all design conditions at either the completion of their fabrication or at a subsequent date.

safety related Hydraulic snubber listings and safety related mechanical snubber listings



[Faint, illegible text scattered across the page, possibly bleed-through from the reverse side. Some faint markings are visible, including a small '1' on the left side and a horizontal line of dots near the bottom.]

PLANT SYSTEMS

SURVEILLANCE REQUIREMENTS (Continued)

If any snubber selected for functional testing either fails to lockup or fails to move, i.e., frozen in place, the cause will be evaluated and if caused by manufacturer or design deficiency, all snubbers of the same design subject to the same defect shall be functionally tested. This testing requirement shall be independent of the requirements stated above for snubbers not meeting the functional test acceptance criteria.

d. Hydraulic Snubbers Functional Test Acceptance Criteria

The hydraulic snubber functional test shall verify that:

1. Activation (restraining action) is achieved within the specified range of velocity or acceleration in both tension and compression.
2. Snubber bleed, or release rate, where required, is within the specified range in compression or tension.

e. Mechanical Snubbers Functional Test Acceptance Criteria

The mechanical snubber functional test shall verify that:

1. The force that initiates free movement of the snubber rod in either tension or compression is less than the specified maximum drag force.
2. Activation (restraining action) is achieved in both tension and compression.

f. Snubber Service Life Monitoring

A record of the service life of each snubber, the date at which the designated service life commences and the installation and maintenance records on which the designed service life is based shall be maintained as required by Specification 6.10.2.1.

Concurrent with the first inservice visual inspection and at least once per 18 months thereafter, the installation and maintenance records for each snubber listed in Tables 3.7-2a and 3.7-2b shall be reviewed to verify that the indicated service life has not been exceeded or will not be exceeded by more than 10% prior to the next scheduled snubber service life review. If the indicated service life will be exceeded by more than 10% prior to the next scheduled snubber service life review, the snubber service life shall be reevaluated or the snubber shall be replaced or reconditioned so as to extend its service life beyond the date of the next scheduled service life review. The results of the reevaluation may be used to justify a change to the service life of the snubber. This reevaluation, replacement or reconditioning shall be indicated in the records.

TABLE 3.7-2a
SAFETY RELATED HYDRAULIC SNUBBERS*

<u>FPL</u> <u>LOCATION</u> <u>NO.</u>	<u>MARK</u> <u>NO.</u>	<u>SYSTEM SNUBBER INSTALLED</u> <u>ON, LOCATION AND ELEVATION</u>	<u>ACCESSIBLE OR</u> <u>INACCESSIBLE</u> <u>(A or I)</u>	<u>HIGH RADIATION</u> <u>ZONE**</u> <u>(Yes or No)</u>	<u>ESPECIALLY DIFFICULT</u> <u>TO REMOVE</u> <u>(Yes or No)</u>
001	SS-1 1A	MS, Steam Gen. 1A, Elev. 62'	I	No	Yes
002	SS-2 1A	MS, Steam Gen. 1A, Elev. 62'	I	No	Yes
003	SS-3 1A	MS, Steam Gen. 1A, Elev. 62'	I	No	Yes
004	SS-4 1A	MS, Steam Gen. 1A, Elev. 62'	I	No	Yes
005	SS-5 1A	MS, Steam Gen. 1A, Elev. 62'	I	No	Yes
006	SS-6 1A	MS, Steam Gen. 1A, Elev. 62'	I	No	Yes
007	SS-7 1A	MS, Steam Gen. 1A, Elev. 62'	I	No	Yes
008	SS-8 1A	MS, Steam Gen. 1A, Elev. 62'	I	No	Yes
009	SS-1 1B	MS, Steam Gen. 1B, Elev. 62'	I	No	Yes
010	SS-2 1B	MS, Steam Gen. 1B, Elev. 62'	I	No	Yes
011	SS-3 1B	MS, Steam Gen. 1B, Elev. 62'	I	No	Yes
012	SS-4 1B	MS, Steam Gen. 1B, Elev. 62'	I	No	Yes
013	SS-5 1B	MS, Steam Gen. 1B, Elev. 62'	I	No	Yes
014	SS-6 1B	MS, Steam Gen. 1B, Elev. 62'	I	No	Yes
015	SS-7 1B	MS, Steam Gen. 1B, Elev. 62'	I	No	Yes
016	SS-8 1B	MS, Steam Gen. 1B, Elev. 62'	I	No	Yes
017	1A1	RC, RCP Motor 1A1, Elev. 57'	I	No	No
018	1A2	RC, RCP Motor 1A1, Elev. 57'	I	No	No
019	1B1	RC, RCP Motor 1A1, Elev. 57'	I	No	No
020	1B2	RC, RCP Motor 1A1, Elev. 57'	I	No	No

DELETE

Sc. Lucie Unit 1

3/4 7-32

Amendment No. 27 27 AA

Approved by _____

TABLE 3.7-2a (CONTINUED)
SAFETY RELATED HYDRAULIC SNUBBERS*

<u>NPL</u> <u>LOCATION</u> <u>NO.</u>	<u>MARK</u> <u>NO.</u>	<u>SYSTEM SNUBBER INSTALLED</u> <u>ON, LOCATION AND ELEVATION</u>	<u>ACCESSIBLE OR</u> <u>INACCESSIBLE</u> <u>(A or I)</u>	<u>HIGH RADIATION</u> <u>ZONE**</u> <u>(Yes or No)</u>	<u>ESPECIALLY DIFFICULT</u> <u>TO REMOVE</u> <u>(Yes or No)</u>
033	MS 649-319	MS, Reactor Bldg. Elev. 82'	A	No	No
034	MS 548-5	MS, Reactor Bldg. Elev. 82'	A	No	No
035	MS 1076-3164	MS, M.S. Trestle, Elev. 62'	A	No	No
036	MS 649-314	MS, Reactor Bldg. Elev. 55'	I	No	No
037	MS 649-314	MS, Reactor Bldg. Elev. 82'	I	No	No
038	MS 649-310	MS, Reactor Bldg. Elev. 50'	I	No	No
039	MS 649-304A	MS, Reactor Bldg. Elev. 30'	A	No	Yes
040	MS 548-9	MS, Reactor Bldg. Elev. 50'	I	No	Yes
041	MS 548-9	MS, Reactor Bldg. Elev. 50'	I	No	Yes
042	BF 549-7	BF, Reactor Bldg. Elev. 40'	I	No	No
043	BF 549-7	BF, Reactor Bldg. Elev. 40'	I	No	No
044	BF 549-8	BF, Reactor Bldg. Elev. 40'	I	No	Yes
047	BF 549-17	BF, Reactor Bldg. Elev. 36'	A	No	Yes
052	BF 549-17	BF, Reactor Bldg. Elev. 36'	A	No	No
053	SI 968210	SI, Reactor Bldg. Elev. 16'	I	No	No
050	SI 969 1216	SI, Reactor Bldg. Elev. 18'	A	No	No
061	MS 549-11	SI, Reactor Bldg. Elev. 18'	A	No	No
066	MS 549-11	SI, Reactor Bldg. Elev. 20'	I	No	No
073	SI 972-6240	SI, Reactor Bldg. Elev. 16'	I	No	No
074	SI 973-240	SI, Reactor Bldg. Elev. 18'	A	No	No
076	SI 973-6224	SI, Reactor Bldg. Elev. 18'	A	No	No
077	SI 868 64	SI, RAB, Elev. 4'	A	No	No
079	SI 868-163	SI, RAB, Elev. 4'	A	No	No
080	SI 868 410	SI, RAB, Elev. 4'	A	No	No
081	SI 676-67	SI, RAB, Elev. 4'	A	No	No
082	SI 676 67	SI, RAB, Elev. 4'	A	No	No
083	SI 676-105	SI, RAB, Elev. 4'	A	No	No

DELETE

Sec. Incode Unit 1

3/4 7-33

Amendment No. 27, 27, 44

TABLE 3.7-2a (CONTINUED)
SAFETY RELATED HYDRAULIC SNUBBERS*

<u>FPL</u> <u>LOCATION</u> <u>NO.</u>	<u>MARK</u> <u>NO.</u>	<u>SYSTEM SNUBBER INSTALLED</u> <u>ON, LOCATION AND ELEVATION</u>	<u>ACCESSIBLE OR</u> <u>INACCESSIBLE</u> <u>(A or I)</u>	<u>HIGH RADIATION</u> <u>ZONE**</u> <u>(Yes or No)</u>	<u>ESPECIALLY DIFFICULT</u> <u>TO REMOVE</u> <u>(Yes or No)</u>
084	SI 676-105	SI, RAB, Elev. 4'	A	No	No
086	SI 676 129	SI, RAB, Elev. 4'	A	No	No
087	SI 676-2481	SI, RAB, Elev. 24'	A	No	No
110	SI 676 247	SI, RAB, Elev. 30'	A	No	No
111	SI 676-2475A	SI, RAB, Elev. 30'	A	No	No
112	SI 676 4505	SI, RAB, Elev. 7'	A	No	No
114	SI 972-6240	SI, RAB, Elev. 4'	A	No	No
091	SPS-417	Pressurizer Spray, Reactor Bldg. Elev. 50'	I	No	No
090	SPS-27	Pressurizer Spray, Reactor Bldg. Elev. 50'	I	No	No
092	SPS-467	Pressurizer Spray, Reactor Bldg. Elev. 80'	A	No	No
093	SPS-777	Pressurizer Spray, Reactor Bldg. Elev. 80'	A	No	No

DELETE

TABLE 3.7-2a (CONTINUED)
SAFETY RELATED HYDRAULIC SNUBBERS*

<u>PRL</u> <u>LOCATION</u> <u>NO.</u>	<u>MARK</u> <u>NO.</u>	<u>SYSTEM SNUBBER INSTALLED</u> <u>ON, LOCATION AND ELEVATION</u> (A or I)	<u>ACCESSIBLE OR</u> <u>INACCESSIBLE</u> (<u>"A"</u> or <u>"I"</u>)	<u>HIGH RADIATION</u> <u>ZONE**</u> (<u>Yes</u> or <u>No</u>)	<u>ESPECIALLY DIFFICULT</u> <u>TO REMOVE</u>
096	CC-1865-9	CC, Reactor Bldg, Elev. 25'	A	No	No
088	CC-1899-48	CC, Reactor Bldg, Elev. 25'	A	No	No
089	CC-1852-6241	CC, Reactor Bldg, Elev. 25'	A	No	No
101	CC-17-1	CC, RAB, Elev. 20'	A	No	No
102	MS-649-313	CC, RAB, Elev. 26'	A	No	No
104	CC-21-1	CC, RAB, Elev. 20'	A	No	No
103	BF-549-7	CC, RAB, Elev. 26'	A	No	No
105	CC-23-2	CC, RAB, Elev. 26'	A	No	No
106	CH-3-40	CH, RAB, Elev. 34'	A	No	No
107	CH-3-75	CH, RAB, Elev. 23'	A	No	No
108	MS-649-313	MS, Reactor Bldg, Elev. 80'	I	No	No
109	MS-649-313	MS, Reactor Bldg, Elev. 80'	I	No	No
097	MS-649-314	MS, Reactor Bldg, Elev. 80'	I	No	No
099	MS-649-314	MS, Reactor Bldg, Elev. 80'	I	No	No

DELETE

~~*Snubbers may be added to or removed from safety-related systems without prior License Amendment to Table 3.7-2a provided a revision to Table 3.7-2a is included with the next License Amendment request.~~

~~**Modifications to this column due to changes in high-radiation areas may be made without prior License Amendment provided that a revision to Table 3.7-2a is included with the next License Amendment request.~~

TABLE 3.7-2b
SAFETY RELATED MECHANICAL SNUBBERS*

<u>RPL</u> <u>LOCATION</u> <u>NO.</u>	<u>MARK</u> <u>NO.</u>	<u>SYSTEM SNUBBER INSTALLED</u> <u>ON, LOCATION AND ELEVATION</u> (A or I).	<u>ACCESSIBLE OR</u> <u>INACCESSIBLE</u> (Yes or No)	<u>HIGH RADIATION</u> <u>ZONE**</u> (Yes or No)	<u>ESPECIALLY DIFFICULT</u> <u>TO REMOVE</u>
021	RC 005-34A	RC, Reactor Bldg, Elev. 68'	A	NO	NO
022	RC 005-34B	RC, Reactor Bldg, Elev. 68'	A	NO	NO
023	RC 005-36	RC, Reactor Bldg, Elev. 68'	A	NO	NO
025	RC 005-12B	RC, Reactor Bldg, Elev. 80'	A	NO	NO
026	RC 005-12B	RC, Reactor Bldg, Elev. 80'	A	NO	NO
024	RC 005-12A	RC, Reactor Bldg, Elev. 80'	A	NO	NO
028	RC 005-55C	RC, Reactor Bldg, Elev. 80'	A	NO	NO
027	RC 005-55B	RC, Reactor Bldg, Elev. 80'	A	NO	NO
029	RC 005-62A	RC, Reactor Bldg, Elev. 80'	A	NO	NO
030	RC 005-89	RC, Reactor Bldg, Elev. 80'	A	NO	NO
031	RC 005-90	RC, Reactor Bldg, Elev. 80'	A	NO	NO
032	RC 005-98	RC, Reactor Bldg, Elev. 80'	A	NO	NO
045	BF 549-11	BF, Reactor Bldg, Elev. 50'	I	NO	NO
046	BF 549-11	BF, Reactor Bldg, Elev. 50'	I	NO	NO
048	BF 661-407	BF, Reactor Bldg, Elev. 40'	I	NO	NO
049	BF 661 0407	BF, Reactor Bldg, Elev. 40'	I	NO	NO
050	BF 661-416	BF, Reactor Bldg, Elev. 50'	I	NO	NO
051	BF 661-416	BF, Reactor Bldg, Elev. 50'	I	NO	NO
054	SI 968-565	SI, Reactor Bldg, Elev. 25'	A	NO	NO
055	SI 989 1205	SI, Reactor Bldg, Elev. 30'	A	NO	NO
056	SI 968-1207	SI, Reactor Bldg, Elev. 18'	A	NO	NO
057	SI 969-1190	SI, Reactor Bldg, Elev. 20'	I	NO	NO
059	SI 969-6193	SI, Reactor Bldg, Elev. 18'	A	NO	NO
060	SI 969 6195	SI, Reactor Bldg, Elev. 18'	A	NO	NO
062	SI 969-6201	SI, Reactor Bldg, Elev. 18'	A	NO	NO
063	SI 696-6217	SI, Reactor Bldg, Elev. 18'	A	NO	NO
064	SI-696-6217	SI, Reactor Bldg, Elev. 18'	A	NO	NO
065	SI-970-1210	SI, Reactor Bldg, Elev. 33'	I	NO	NO

DELETE

3/4 7-36

Amendment No. 44

TABLE 3.7-2b (CONTINUED)
SAFETY RELATED MECHANICAL SNUBBERS*

<u>FPL</u> <u>LOCATION</u> <u>NO.</u>	<u>MARK</u> <u>NO.</u>	<u>SYSTEM SNUBBER INSTALLED</u> <u>ON, LOCATION AND ELEVATION</u>	<u>ACCESSIBLE OR</u> <u>INACCESSIBLE</u> <u>(A or I)</u>	<u>HIGH RADIATION</u> <u>ZONE**</u> <u>(Yes or No)</u>	<u>ESPECIALLY DIFFICULT</u> <u>TO REMOVE</u> <u>(Yes or No)</u>
067	SI 970-1251	SI, Reactor Bldg, Elev. 20'	A	NO	NO
068	SI 971-6	SI, Reactor Bldg, Elev. 20'	I	NO	NO
069	SI 971-1229	SI, Reactor Bldg, Elev. 20'	I	NO	NO
070	SI 971-6229	SI, Reactor Bldg, Elev. 20'	I	NO	NO
071	SI 971-6236	SI, Reactor Bldg, Elev. 20'	I	NO	NO
072	SI 972-1243	SI, Reactor Bldg, Elev. 25'	A	NO	NO
075	SI 973-6219	SI, Reactor Bldg, Elev. 36'	I	NO	NO
078	SI 868 111	SI, RAB, Elev. 4'	A	NO	NO
095	SI 676-127	SI, RAB, Elev. 4'	A	NO	NO
113	SI 971-6236	SI, RAB, Elev. 4'	A	NO	NO
094	CS-832-118	CS, Reactor Bldg, Elev. 125'	A	NO	YES
085	CS-878 115	CS, Reactor Bldg, Elev. 18'	A	NO	YES
098	CC-1899-2208	CC, Reactor Bldg, Elev. 59'	A	NO	NO
100	CC-1865-2207	CC, Reactor Bldg, Elev. 59'	A	NO	NO

DELETE

St. Lucie Unit 1

3/4 7-37

Amendment No. 44

TABLE 3.7-2b (CONTINUED)
SAFETY RELATED MECHANICAL SNUBBERS*

FPL LOCATION NO.	MARK NO.	SYSTEM SNUBBER INSTALLED ON, LOCATION AND ELEVATION	ACCESSIBLE OR INACCESSIBLE (A or I)	HIGH RADIATION ZONE** (Yes or No)	ESPECIALLY DIFFICULT TO REMOVE (Yes or No)
115	RC164-11	RC RCB Elev. 36'	I	NO	NO
116	RC162-11	RC RCB Elev. 35'	I	NO	NO
117	RC-1-221A	RC RCB Elev. 31'	I	NO	NO
118	RC-1-124B	RC RCB Elev. 19'	I	NO	NO
119	RC162-11	RC RCB Elev. 35'	I	NO	NO
120	RC-1-192A	RC RCB Elev. 19'	I	NO	NO
121	RC-5-475	RC RCB Elev. 77'	I	NO	NO
122	CH-129-99	CH RCB Elev. 33'	I	NO	NO
123	RC-217-5	RC RCB Elev. 75'	I	NO	NO
124	CH-65-54C	CH RAB Elev. 21'	I	NO	NO
125	CH-142-9	CH RCB Elev. 20'	I	NO	NO
126	CH143-30C	CH RCB Elev. 17'	I	NO	NO
127	RC-215-9A	RC RCB Elev. 73'	I	NO	NO
128	MSI-22-3A	MS RCB Elev. 57'	I	NO	NO
129	RC-1-124C	RC RCB Elev. 19'	I	NO	NO
130	MSI-20-3A	MS RCB Elev. 58'	I	NO	NO
131	MSI-16-3A	MS RCB Elev. 57'	I	NO	NO
132	CH-125-35B	CH RCB Elev. 30'	I	NO	NO
133	MSI-14-3A	MS RCB Elev. 52'	I	NO	NO
134	CH-129-339	CH RCB Elev. 32'	I	NO	NO
135	RC-220-105	RC RCB Elev. 72'	I	NO	NO
136	RC-217-5	RC RCB Elev. 75'	I	NO	NO
137	CH 129-339	CH RCB Elev. 32'	I	NO	NO
138	RC 114-129	RC RCB Elev. 68'	I	NO	NO
139	RC 221-162	RC RCB Elev. 68'	I	NO	NO
140	CH-187-38A	CH RCB Elev. 24'	I	NO	NO
141	CH-143-26C	CH RCB Elev. 17'	I	NO	NO
142	CH-141-74	CH RCB Elev. 24'	I	NO	NO
143	B-2-H1	B RCB Elev. 38'	I	NO	NO
144	RC 128-99	RC RCB Elev. 67'	I	NO	NO
145	CH-143-34C	CH RCB Elev. 17'	I	NO	NO
146	RC-1-25C	RC RCB Elev. 31'	I	NO	NO
147	CH-141-36=C	CH RCB Elev. 32'	I	NO	NO

DELETE

ST. LUCIE UNIT 1

3/4 7-38

Amendment No. 44

115
116
117
118
119
120
121
122
123
124
125
126
127
128
129
130
131
132
133
134
135
136
137
138
139
140
141
142
143
144
145
146
147

TABLE 3.7-2b (CONTINUED)
SAFETY RELATED MECHANICAL SNUBBERS*

FPL LOCATION NO.	MARK. NO.	SYSTEM SNUBBER INSTALLED ON, LOCATION AND ELEVATION	ACCESSIBLE OR INACCESSIBLE (A or I)	HIGH RADIATION ESPECIALLY DIFFICULT ZONE** TO REMOVE	
				(Yes or No)	(Yes or No)
148	RC-1-124A	RC RCB Elev. 17'	I	NO	NO
149	MSI-10-3A	MS RCB Elev. 57'	I	NO	NO
150	MSI-8-3A	MS RCB Elev. 57'	I	NO	NO
151	CH 142-17	CH RCB Elev. 21'	I	NO	NO
152	RC-163-11	RC RCB Elev. 35'	I	NO	NO
153	RC 165-11	RC RCB Elev. 35'	I	NO	NO
154	MSI-18-3A	MS RCB Elev. 57'	I	NO	NO
155	RC 128-99	RC RCB Elev. 68'	I	NO	NO
156	MSI-12-3A	MS RCB Elev. 57'	I	NO	NO
157	RC 219-6B	RC RCB Elev. 71'	I	NO	NO
158	CH 142-18	CH RCB Elev. 21'	I	NO	NO
159	RC 163-11	RC RCB Elev. 35'	I	NO	NO
160	CH 142-18	CH RCB Elev. 21'	I	NO	NO
161	RC 165-11	RC RCB Elev. 35'	I	NO	NO
162	RC-217-5	RC RCB Elev. 75'	I	NO	NO
163	SI-69-58	SI RCB Elev. 62'	I	NO	NO
164	SI-39-6	SI RAB Elev. 12'	I	NO	NO
165	RC 221-148	RC RCB Elev. 72'	I	NO	NO
166	RC 164-11	RC RCB Elev. 36'	I	NO	NO
167	CH-67-81	CH RAB Elev. 21'	I	NO	NO
168	RC 114-129	RC RCB Elev. 68'	I	NO	NO
169	RC-44-26	RC RCB Elev. 40'	I	NO	NO
170	RC 220-112	RC RCB Elev. 71'	I	NO	NO
171	RC 218-26	RC RCB Elev. 76'	I	NO	NO
172	RC 44-11	RC RCB Elev. 35'	I	NO	NO
173	CH 67-81	CH RAB Elev. 21'	I	NO	NO
174	CH-65-54A	CH RAB Elev. 12'	I	NO	NO
175	RC 220-112	RC RCB Elev. 72'	I	NO	NO
176	MSI-2-HI	MS RCB Elev. 78'	I	NO	NO
177	RC 222-43	RC RCB Elev. 70'	I	NO	NO
178	MSI-4-HI	MS RCB Elev. 78'	I	NO	NO

DELETE

TABLE 3.7-2b (CONTINUED)
SAFETY RELATED MECHANICAL SNUBBERS*

FPL LOCATION NO.	MARK NO.	SYSTEM SNUBBER INSTALLED ON, LOCATION AND ELEVATION	ACCESSIBLE OR INACCESSIBLE (A or I)	HIGH RADIATION ESPECIALLY DIFFICULT ZONE** TO REMOVE	
				(Yes or No)	(Yes or No)
180	RC 220-114	RC RCB Elev. 71'	I	NO	NO
181	RC 215-9B	RC RCB Elev. 74'	I	NO	NO
182	RC 219-6A	RC RCB Elev. 73'	I	NO	NO
182	MS1-3-III	MS RCB Elev. 78'	I	NO	NO
184	RC 218-26	RC RCB Elev. 76'	I	NO	NO
185	CH-64-45A	CH RAB Elev. 30'	I	NO	NO
186	B-1-III3A	B RCB Elev. 38'	I	NO	NO
187	SI-69 60B	SI RCB Elev. 57'	I	NO	NO
188	RC 150-H7	RC RCB Elev. 50'	I	NO	NO
189	SI-69 60	SI RCB Elev. 57'	I	NO	NO
190	CH-141-44A	CH RCB Elev. 32'	I	NO	NO
191	CH-141-44A	CH RCB Elev. 32'	I	NO	NO
192	B-3-795	B RAB Elev. 36'	I	NO	NO
193	CH 130-66	CH RAB Elev. 26'	I	NO	NO
194	MSII-7B	MS Steam Trestle Elev. 38'	A	NO	NO
195	MPR-200-250	MP RCB Elev. 34'	I	NO	NO
196	MSII-7A	Sm Stream Trestle Elev. 38'	A	NO	NO
197	MPR-201-16	MP RCB Elev. 35'	I	NO	NO
198	MPR 200-20	MP RCB Elev. 35'	I	NO	NO
199	B-21-311	B-RAB Elev. 36'	A	NO	NO
200	B-21-3110	B-RAB Elev. 35'	A	NO	NO
201	B-21-3240	B-RAB Elev. 38'	A	NO	NO
202	CC-1899-2200	CC-RCB Elev. 57'	I	NO	NO

DELETE

~~*Snubbers may be added to or removed from safety-related systems without prior License Amendment to Table 3.7-2b provided a revision to Table 3.7-2b is included with the next License Amendment request.~~

~~**Modifications to this column due to changes in high radiation areas may be made without prior License Amendment provided that a revision to Table 3.7-2b is included with the next License Amendment request.~~

St. Lucie Unit 1

3/4 7-39a

Amendment No. 44

PLANT SYSTEMS

BASES

3/4.7.7 CONTROL ROOM EMERGENCY VENTILATION SYSTEM (Continued)

for operations personnel during and following all credible accident conditions. The OPERABILITY of this system in conjunction with control room design provisions is based on limiting the radiation exposure to personnel occupying the control room to 5 rem or less whole body, or its equivalent. This limitation is consistent with the requirements of General Design Criteria 10 of Appendix "A", 10 CFR 50.

3/4.7.8 ECCS AREA VENTILATION SYSTEM

The OPERABILITY of the ECCS area ventilation system ensures that radioactive materials leaking from the ECCS equipment following a LOCA are filtered prior to reaching the environment. The operation of this system and the resultant effect on offsite dosage calculations was assumed in the accident analyses.


3/4.7.9 SEALED SOURCE CONTAMINATION

The limitations on sealed source removable contamination ensure that the total body or individual organ irradiation does not exceed allowable limits in the event of ingestion or inhalation of the probable leakage from the source material. The limitations on removable contamination for sources requiring leak testing, including alpha emitters, is based on 10 CFR 70.39(c) limits for plutonium. Quantities of interest to this specification which are exempt from the leakage testing are consistent with the criteria of 10 CFR Parts 30.11-20 and 70.19. Leakage from sources excluded from the requirements of this specification is not likely to represent more than one maximum permissible body burden for total body irradiation if the source material is inhaled or ingested.

3/4.7.10 SNUBBERS

^{safety related}
All snubbers are required to be OPERABLE to ensure that the structural integrity of the reactor coolant system and all other safety related systems is maintained during and following a seismic or other event initiating dynamic loads. Snubbers excluded from this inspection program are those installed on nonsafety-related systems and then only if their failure or failure of the system on which they are installed would have no adverse effect on any safety-related system.

The visual inspection frequency is based upon maintaining a constant level of snubber protection to systems. Therefore, the required inspection interval varies inversely with the observed snubber failures and is determined by the number of inoperable snubbers found during an inspection. Inspections performed



ADMINISTRATIVE CONTROLS

- g. Records of training and qualification for current members of the unit staff.
- h. Records of in-service inspections performed pursuant to these Technical Specifications.
- i. Records of Quality Assurance activities required by the QA Manual.
- j. Records of reviews performed for changes made to procedures or equipment or reviews of tests and experiments pursuant to 10 CFR 50.59.
- k. Records of meetings of the FRG and the CNRB.
- l. Records of the service lives of all ^{safety related} snubbers ~~listed in Tables 3-7-2a and 3-7-2b~~ including the date at which the service life commences and associated installation and maintenance records.
- m. Records of secondary water sampling and water quality.
- n. Annual Radiological Environmental Operating Reports and records of analyses transmitted to the licensee which are used to prepare the Annual Radiological Environmental Monitoring Report.
- o. Meteorological data, summarized and reported in a format consistent with the recommendation of Regulatory Guides 1.21 and 1.23.
- p. Records of audits performed under the requirements of Specifications 6.5.2.8 and 6.8.4.

6.11 RADIATION PROTECTION PROGRAM

Procedures for personnel radiation protection shall be prepared consistent with the requirements of 10 CFR 20 and shall be approved, maintained and adhered to for all operations involving personnel radiation exposure.

ATTACHMENT 2
EVALUATION/DETERMINATION OF
NO SIGNIFICANT HAZARDS CONSIDERATION

Background

In May 1984, the NRC issued Generic Letter 84-13 (Technical Specification for Snubbers) which reassessed the inclusion of snubber listings within the Technical Specifications. It was concluded in the Generic Letter that such listings are not necessary provided the snubber Technical Specification is modified to specify which snubbers are required to be OPERABLE. The Limiting Condition for Operation (LCO), surveillance requirements, and recordkeeping requirements will be maintained within the Technical Specifications. The snubber listings, when deleted from the Technical Specifications, will be maintained per controlled documents. Changes in snubber quantities, type, or locations would be a change to the facility and would, therefore, be subject to the provisions of 10 CFR Part 50.59.

Discussion

This proposed change to the Technical Specifications is being processed to delete snubber Tables 3.7-2a, "Safety Related Hydraulic Snubbers" and 3.7-2b, "Safety Related Mechanical Snubbers," from the Technical Specifications. This change closely follows NRC guidance (GL 84-13) for implementation. However, we have tailored the recommended LCO wording as described in the following discussion.

Generic Letter 84-13 recommended the following LCO wording:

All snubbers shall be OPERABLE, the only snubbers excluded from this requirement are those installed on nonsafety-related systems and then only if their failure or failure of the system on which they are installed, would have no adverse effect on any safety-related system.

Our proposed Technical Specification would simply state: "All safety related snubbers shall be OPERABLE." All snubbers currently listed in the Technical Specification tables are safety related. Additionally, St. Lucie Unit 1 and Unit 2 Technical Specifications already contain the statement as written in the second sentence of the NRC suggested LCO. This statement, concerning snubber failures which may impact safety related systems, is currently contained in both Unit 1 and 2 Technical Specification Bases.

In addition to deleting the snubber tables from the Technical Specifications, the following changes are also proposed:

- (A) Tables 3.7-2a and 3.7-2b: All references to Tables 3.7-2a and 3.7-2b have been deleted since these tables have been removed.

THE UNIVERSITY OF CHICAGO
DEPARTMENT OF CHEMISTRY
CHICAGO, ILLINOIS

Dear Sir:

I have the pleasure to inform you that your application for admission to the Ph.D. program in Chemistry for the fall semester of 1964 has been approved. You will receive a letter from the Registrar regarding the admission process and the requirements for the program.

Very truly yours,
[Signature]

Enclosed for you are the following documents:

- 1. A copy of the University Catalog for 1963-64.
- 2. A copy of the Department of Chemistry Bulletin.
- 3. A copy of the Graduate School Bulletin.

If you have any questions regarding the admission process or the requirements for the program, please contact the Registrar's Office at (312) 574-3100.

Sincerely,
[Signature]

- (B) First Inservice Visual Inspection: The first inservice visual inspection of snubbers at St. Lucie Unit 1 has been performed and reference to this inspection is not required since this one time Surveillance Requirement has been completed.
- (C) Safety Related: This change incorporates the words "safety related" in various locations (prior to the word "snubber") in order to maintain consistency with the LCO.
- (D) Footnote: The footnote concerning the waiving of mechanical snubber functional test requirements until startup following the fifth refueling outage has been deleted since the fifth refueling outage has been completed.
- (E) Snubber Service Life Monitoring: Records of the service life of each snubber shall be maintained as required by Administrative Controls Section 6.10.2.l (Amendment 69 to Facility Operating License DPR-67 changed the alphabetical location of this requirement from 6.10.2.m to 6.10.2.l. This change reflects the correction of the alphabetical location of this requirement from 6.10.2.m to 6.10.2.l).

Determination of No Significant Hazards Consideration

The standards used to arrive at a determination that proposed changes do not involve a significant hazards consideration are included in 10 CFR 50.92(c), which states that the Commission may make such a determination if operation of the facility in accordance with the proposed amendment would not:

- (1) Involve a significant increase in the probability or consequences of an accident previously evaluated; or
- (2) Create the possibility of a new or different kind of accident from any accident previously evaluated; or
- (3) Involve a significant reduction in a margin of safety.

With respect to criterion (1), the changes being proposed by FPL are administrative; they do not affect assumptions contained in plant safety analyses, nor do they affect Technical Specifications that do preserve safety analysis assumptions. Safety related snubbers will continue to be controlled and surveilled according to Technical Specifications. Changes in snubber quantities, types, or locations would be a change to the facility and would be adequately controlled per the provisions of 10 CFR 50.59. Therefore, the proposed changes do not affect the probability or consequences of accidents previously analyzed.

With respect to criterion (2), the changes being proposed by FPL are administrative; they will not lead to physical modifications. These changes do not add to, or delete from, the total number of plant snubbers available to provide dynamic load support during and following a seismic event or other initiating dynamic loads. Therefore, the proposed changes do not create the possibility of a new or different kind of accident.

The first part of the document is a letter from the Secretary of the State to the President, dated January 1, 1865. The letter is addressed to the President and is signed by the Secretary of the State.

The second part of the document is a letter from the President to the Secretary of the State, dated January 1, 1865. The letter is addressed to the Secretary of the State and is signed by the President.

The third part of the document is a letter from the Secretary of the State to the President, dated January 1, 1865. The letter is addressed to the President and is signed by the Secretary of the State.

The fourth part of the document is a letter from the President to the Secretary of the State, dated January 1, 1865. The letter is addressed to the Secretary of the State and is signed by the President.

The fifth part of the document is a letter from the Secretary of the State to the President, dated January 1, 1865. The letter is addressed to the President and is signed by the Secretary of the State.

The sixth part of the document is a letter from the President to the Secretary of the State, dated January 1, 1865. The letter is addressed to the Secretary of the State and is signed by the President.

The seventh part of the document is a letter from the Secretary of the State to the President, dated January 1, 1865. The letter is addressed to the President and is signed by the Secretary of the State.

The eighth part of the document is a letter from the President to the Secretary of the State, dated January 1, 1865. The letter is addressed to the Secretary of the State and is signed by the President.

The ninth part of the document is a letter from the Secretary of the State to the President, dated January 1, 1865. The letter is addressed to the President and is signed by the Secretary of the State.

The tenth part of the document is a letter from the President to the Secretary of the State, dated January 1, 1865. The letter is addressed to the Secretary of the State and is signed by the President.

With respect to criterion (3), the changes being proposed by FPL are administrative; they do not modify the safety margins defined in and maintained by the Technical Specifications. The NRC has concluded that snubber listings are not necessary provided the snubber Technical Specification specifies which snubbers are required to be OPERABLE. The snubber LCO has been clarified to show that all safety related snubbers must be OPERABLE. This change does not involve a significant reduction in a margin of safety since: 1) the LCO clearly specifies which snubbers are required to be OPERABLE, and 2) the snubber listing will be maintained via controlled documents.

In addition, the Commission has provided guidance (48 FR 14870) concerning the application of standards for determining whether a significant hazards consideration exists by presenting examples of amendments that are considered not likely to involve a significant hazards consideration. Example (i) relates to a purely administrative change to the Technical Specifications: for example, a change to achieve consistency throughout the Technical Specifications, correction of an error, or a change in nomenclature. The changes being proposed by FPL are similar to example (i) in 48 FR 14870 in that they are administrative changes designed to:

- o Remove snubber listings from Tables 3.7-2a and 3.7-2b as per Generic Letter 84-13.
- o Remove outdated material.
- o Correction of an error.

1. The first part of the document discusses the importance of maintaining accurate records of all transactions. It emphasizes that this is crucial for ensuring the integrity of the financial statements and for providing a clear audit trail.

2. The second part of the document outlines the various methods used to collect and analyze data. It describes how different types of information are gathered and how they are processed to identify trends and anomalies.

3. The final part of the document provides a summary of the findings and conclusions. It highlights the key insights gained from the analysis and offers recommendations for future improvements.