

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8704070019 DOC. DATE: 87/03/31 NOTARIZED: YES DOCKET # 05000389
 FACIL: 50-389 St. Lucie Plant, Unit 2, Florida Power & Light Co.
 AUTH. NAME: WOODY, C. O. AUTHOR AFFILIATION: Florida Power & Light Co.
 RECIP. NAME: RECIP. AFFILIATION: Document Control Branch (Document Control Desk)

SUBJECT: Application for amend to License NPF-16, updating Tech Specs to make minor text changes & to correct typos. Fee paid.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR ___ ENCL ___ SIZE: _____
 TITLE: OR Submittal: General Distribution

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTR ENCL
	PD2-2 LA TOURIGNY, E	1 0 1 1	PD2-2 PD	5 5
INTERNAL:	ADM/LFMB	1 0	NRR/DEST/ADE	1 1
	NRR/DEST/ADS	1 1	NRR/DLPQ/HFB	1 1
	NRR/DOEA/TSB	1 1	NRR/PMAS/ILRB	1 1
	OGC/HDS2	1 0	<u>REG FILE</u> 01	1 1
EXTERNAL:	EG&G BRUSKE, S	1 1	LPDR	1 1
	NRC PDR	1 1	NSIC	1 1

1. The following information was obtained from a review of the files of the [redacted] and is being furnished to you for your information. It is to be used only for the purpose for which it was obtained and is not to be disseminated outside of your office.

(Name of contact person and address of contact person)

2. The following information was obtained from a review of the files of the [redacted] and is being furnished to you for your information. It is to be used only for the purpose for which it was obtained and is not to be disseminated outside of your office.

3. The following information was obtained from a review of the files of the [redacted] and is being furnished to you for your information. It is to be used only for the purpose for which it was obtained and is not to be disseminated outside of your office.

NAME	ADDRESS	PHONE	DATE
[redacted]	[redacted]	[redacted]	[redacted]
[redacted]	[redacted]	[redacted]	[redacted]
[redacted]	[redacted]	[redacted]	[redacted]
[redacted]	[redacted]	[redacted]	[redacted]
[redacted]	[redacted]	[redacted]	[redacted]
[redacted]	[redacted]	[redacted]	[redacted]
[redacted]	[redacted]	[redacted]	[redacted]
[redacted]	[redacted]	[redacted]	[redacted]
[redacted]	[redacted]	[redacted]	[redacted]



MARCH 31 1987

L-87-145

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

Gentlemen:

Re: St. Lucie Unit 2
Docket No. 50-389
Proposed License Amendment
Administrative Update

In accordance with 10 CFR 50.90, Florida Power & Light Company (FPL) submits herewith a request to amend Appendix A of Facility Operating License NPF-16.

This amendment is submitted to make administrative changes to the St. Lucie Unit 2 Technical Specifications to remove outdated material, make minor text changes, and correct typographical errors. Certain items identified in the staff's letter dated August 28, 1986 (E. G. Tourigny to C. O. Woody) are included in this submittal.

Attachment 1 to this letter includes the proposed Technical Specification changes. Attachment 2 is the Safety Evaluation in support of the proposed amendment. A "Determination of No Significant Hazards Consideration" is provided as Attachment 3.


In accordance with 10 CFR 50.91(b)(1), a copy of the proposed amendment is being forwarded to the State Designee for the State of Florida.

In accordance with 10 CFR 170, FPL Check No. 4537 is attached as remittance for the license amendment application fee.

The proposed amendment has been reviewed by the St. Lucie Facility Review Group and the Florida Power & Light Company Nuclear Review Board.

Please contact us if you have questions about this submittal.

Very truly yours,


C. O. Woody
Group Vice President
Nuclear Energy

COW/EJW/gp
Attachment

8704070019 870331
PDR ADOCK 05000389
P PDR

*Foot
" w/check
4150
#4537*

cc: Dr. J. Nelson Grace, Regional Administrator, Region II, USNRC
USNRC Senior Resident Inspector, St. Lucie Plant
Mr. Lyle Jerrett, Florida Dept. of Health and Rehabilitative Services

The first part of the document discusses the importance of maintaining accurate records of all transactions. It emphasizes that every entry should be supported by a valid receipt or invoice. This ensures transparency and allows for easy verification of the data.

In the second section, the author details the various methods used to collect and analyze the data. This includes both manual and automated processes. The manual process involves reviewing each entry individually, while the automated process uses software to identify patterns and anomalies.

The third section describes the results of the analysis. It shows that there are several areas where the data is inconsistent or incomplete. These areas need to be investigated further to determine the cause of the discrepancies.


Finally, the document concludes with a list of recommendations. These include implementing stricter controls over data entry, improving the accuracy of the automated systems, and conducting regular audits to ensure the integrity of the data.

STATE OF FLORIDA)
) ss.
COUNTY OF PALM BEACH)

J. W. Dickey being first duly sworn, deposes and says:

That he is Vice President of Nuclear Operations of Florida Power & Light Company, the Licensee herein;


That he has executed the foregoing document; that the statements made in this document are true and correct to the best of his knowledge, information, and belief, and that he is authorized to execute the document on behalf of said Licensee.



J. W. Dickey

Subscribed and sworn to before me this

31 day of March, 1987.




Bernice M. Salinas

NOTARY PUBLIC, in and for the County
of Palm Beach, State of Florida

NOTARY PUBLIC STATE OF FLORIDA
MY COMMISSION EXP SEPT 18, 1989
BONDED THRU GENERAL INS. UND.

My Commission expires: _____



ATTACHMENT 1

PROPOSED TECHNICAL SPECIFICATION CHANGES

This Attachment includes (1) a summary listing of revised Technical Specification pages for St. Lucie Unit 2, (2) a description of the proposed changes, and (3) marked up Technical Specification pages.

(1) Summary Listing of Revised Technical Specification Pages

<u>PAGE</u>	<u>REMARKS</u>
3/4 1-1	Change % Delta-k/k to pcm
3/4 1-2	Change % Delta-k/k to pcm
3/4 1-3	Change % Delta-k/k to pcm
3/4 1-5	Change Delta-k/k / ^o F to pcm/ ^o F
3/4 1-8	Change % Delta-k/k to pcm
3/4 1-10	Change % Delta-k/k to pcm
3/4 1-12	Change % Delta-k/k to pcm
3/4 1-14	Change % Delta-k/k to pcm
3/4 3-25	Remove outdated footnote*
3/4 3-26	Remove outdated footnote*
3/4 3-34	Correct surveillance periodicities
3/4 3-39	Correct typographical error
3/4 3-53	Correct typographical error
3/4 3-57	Correct typographical errors
3/4 4-27	Correct typographical errors*
3/4 4-38	Remove outdated footnote*



3/4 5-6	Correct typographical errors
3/4 6-5	Remove outdated footnotes
3/4 6-15	Correct typographical error
3/4 6-21	Adds valve resulting from plant modification
3/4 6-23	Remove outdated footnotes and correct valve number to reflect plant modification
3/4 7-4	Remove outdated footnote*
3/4 7-39	Remove outdated footnote*
3/4 8-1	Correct typographical error
3/4 8-2	Correct typographical error
3/4 9-5	Remove outdated footnote*
3/4 11-6	Correct typographical errors
3/4 11-10	Correct typographical error
B 3/4 0-3	Correct typographical error
B 3/4 1-1	Change % Delta-k/k to pcm
B 3/4 1-2	Change % Delta-k/k to pcm
B 3/4 1-4	Correct typographical error
B 3/4 2-1	Correct typographical error
B 3/4 3-4	Correct typographical error
6-10	Update CNRB composition
6-15	Remove outdated footnote*
6-16	Revise report addressee to reflect rule change (10 CFR 50.4)
6-17	Revise report addressee to reflect rule change (10 CFR 50.4)

6-20 Revise report addressees to reflect rule
change (10 CFR 50.4)

6-23 Remove outdated Specifications 6.13.1 and
6.14.1*

* Changes recommended in letter dated August 28, 1986 from
E. G. Tourigny (NRC) to C. O. Woody (FPL).



ATTACHMENT 1 (Con't)

(2) Description of Proposed Changes

<u>SPECIFICATION</u>	<u>PAGE</u>	<u>DESCRIPTION</u>
3.1.1.1	3/4 1-1	5.0% delta-k/k is changed to the equivalent 5000 pcm in two places.
4.1.1.1.1	3/4 1-1	5.0% delta-k/k is changed to the equivalent 5000 pcm in one place.
4.1.1.1.2	3/4 1-2	1.0% delta-k/k is changed to the equivalent 1000 pcm in one place.
3.1.1.2	3/4 1-3	3.0% delta-k/k is changed to the equivalent 3000 pcm in two places.
4.1.1.2	3/4 1-3	3.0% delta-k/k is changed to the equivalent 3000 pcm in one place.
3.1.1.4.a	3/4 1-5	$+0.5 \times 10^{-4}$ delta-k/k/degree-F is changed to the equivalent +5 pcm/degree-F.
3.1.1.4.b	3/4 1-5	$+0.3 \times 10^{-4}$ delta-k/k/degree-F is changed to the equivalent +3 pcm/degree-F.
3.1.1.4.c	3/4 1-5	-2.7×10^{-4} delta-k/k/degree-F is changed to the equivalent -27 pcm/degree-F.
3.1.2.2	3/4 1-8	3.0% delta-k/k is changed to the equivalent 3000 pcm in one place.



3.1.2.4	3/4 1-10	3.0% delta-k/k is changed to the equivalent 3000 pcm in one place.
3.1.2.6	3/4 1-12	3.0% delta-k/k is changed to the equivalent 3000 pcm in one place.
3.1.2.8	3/4 1-14	3.0% delta-k/k is changed to the equivalent 3000 pcm in one place.
Table 3.3-6	3/4 3-25	The fourth footnote at the bottom of this page, which applies to the Containment Area (HI Range) Radiation Monitoring Instrumentation, states that "monitors shall be completely installed and OPERABLE prior to exceeding 5% of RATED THERMAL POWER." As documented in FPL letter L-83-348, dated June 6, 1983, the monitors were installed and OPERABLE prior to exceeding 5% RATED THERMAL POWER; therefore, the footnote can be deleted.
Table 3.3-6	3/4 3-26	The third footnote at the bottom of this page, which applies to the Radiation Monitoring Instrumentation Noble Gas Effluent Monitors for the Atmospheric Steam Dump Valve Discharge and the Reactor Auxiliary Building Exhaust System (Plant Vent High Range Monitor), states that "monitors shall be completely installed and OPERABLE prior to exceeding 5% of RATED THERMAL POWER." As documented in NRC Inspection Reports 50-389/83-25, dated April 6, 1983 and 50-389/83-59, dated September 27, 1983, the monitors were installed and OPERABLE prior to exceeding 5% RATED THERMAL POWER, therefore, the footnote can be deleted.



Table 4.3-4	3/4 3-34	Peak shock recorders SMR-42-9 and SMR-42-10, located in St. Lucie Unit 1, cannot be channel checked or have a channel functional test performed. As a result these surveillance periodicities are changed to NA. This is consistent with the surveillance requirements for these identical instruments identified in the St. Lucie Unit 1 Technical Specification Table 4.3-4 and identified in the St. Lucie Unit 2 Technical Specification Table 4.3-4 as "(Instrumentation located in St. Lucie Unit 1)".
Table 3.3-9	3/4 3-39	There is only one channel for the steam generator pressure instruments on the hot shutdown panel (PI-8113 and PI-8123). Therefore, the "Required Number of Channels" column is corrected accordingly.
4.3.3.11	3/4 3-53	This Surveillance Requirement, corresponding to Limiting Condition for Operation 3.3.3.10, is numbered incorrectly, It should be renumbered 4.3.3.10.
Table 4.3-9	3/4 3-57	The "CHANNEL CALIBRATION" column for Item 2, Waste Gas Decay Tanks Explosive Gas Monitoring System, should refer to Note (4); there is no Note (5) to Table 4.3-9.
Table 4.4-4	3/4 4-27	Within Table 4.4-4, under Item 4.a in the "Sample and Analysis Frequency" column, the notation for microcurie/gram is incorrect. In the fourth and sixth lines, "mCi/gram" should be corrected to "micro-Ci/gram."

3.4.10

3/4 4-38

The footnote at the bottom of the page requires that "the Reactor Coolant System vents shall be completely installed and OPERABLE prior to exceeding 5% of RATED THERMAL POWER." As documented in FPL letter L-83-348, dated June 6, 1983, the reactor coolant system vents were installed and OPERABLE prior to exceeding 5% RATED THERMAL POWER, therefore, the footnote can be deleted.

4.5.2.h.2

3/4 5-6

The prefix "HVC" for items "a" through "d" in the "HPSI System Valve Number" column should be corrected to "HCV."

Table 3.6-1

3/4 6-5

The footnotes at the bottom of this page no longer apply. The modification described in FPL letter L-84-266, dated September 28, 1984, has been completed as reported in FPL letter L-87-112, dated March 13, 1987. Valve tag number/type is corrected accordingly.

4.6.2.1.c.2

3/4 6-15

A typographical error is corrected. The word "on" is changed to "an."



[The page contains extremely faint and illegible text, likely bleed-through from the reverse side. The text is scattered across the page and cannot be transcribed accurately.]

Table 3.6-2

3/4 6-21

Containment isolation valve I-HCV-18-2 is added to "Section A) Containment Isolation". The modification described in FPL letter L-84-266, dated September 28, 1984, and reflected in the footnotes on page 3/4 6-23, has been completed as reported in FPL letter L-87-112, dated March 13, 1987.

Table 3.6-2

3/4 6-23

The footnotes at the bottom of this page no longer apply. The modification described in FPL letter L-84-266, dated September 28, 1984, has been completed as reported in FPL letter L-87-112, dated March 13, 1987.

3.7.1.2

3/4 7-4

The footnote at the bottom of this page states that "the Auxiliary Feedwater System automatic initiation system shall be completely installed and OPERABLE prior to initial criticality." As documented in NRC Inspection Report 50-389/83-47, dated July 28, 1983, the subject system was installed and OPERABLE as required; therefore, the footnote can be deleted.



[The page contains extremely faint and illegible text, likely bleed-through from the reverse side of the document. The text is scattered across the page and cannot be transcribed accurately.]

3.7.12

3/4 7-39

The footnote at the bottom of this page states that "all fire rated assemblies shall be completely installed and OPERABLE prior to exceeding 5% of RATED THERMAL POWER, with the exception of the permanent flame impingement shields in containment which shall be completely installed and OPERABLE prior to STARTUP following the first refueling outage." As documented in FPL letter L-84-333, dated November 20, 1984, the fire rated assemblies and flame impingement shields were installed and OPERABLE as required; therefore, the footnote can be deleted.

3.8.1.1

3/4 8-1

A typographical error is corrected. The word "a" in Action c.2. is changed to "in."

3.8.1.1

3/4 8-2

A typographical error is corrected. A comma is inserted in the second sentence of Action c.2.

3.9.5

3/4 9-5

The footnote at the bottom of this page states that "the sound powered telephone system shall be completely installed and OPERABLE prior to exceeding 5% of RATED THERMAL POWER." As documented in NRC Inspection Report 50-389/83-47, dated July 28, 1983, the subject system was installed and OPERABLE as required; therefore, the footnote can be deleted.



3.11.1.3	3/4 11-6	Three typographical errors are corrected. These three typos were made during NRC's retype of this ACTION Statement to delete the Tech Spec 6.9.1 reporting requirements.
Table 4.11-2	3/4 11-10	A typographical error is corrected. In Table Notation c, the word "or" is changed to "of."
B4.0.5	B 3/4 0-3	A typographical error in the word "throughout" is corrected.
B3/4.1.1.1 & B3/4.1.1.2	B 3/4 1-1	5% delta-k/k is change to the equivalent 5000 pcm in two places in the BASES section on SHUTDOWN MARGIN.
B3/4.1.2	B 3/4 1-2	3% delta-k/k is changed to the equivalent 3000 pcm in two places in the BASES section on BORATION SYSTEMS.
B3/4.1.3	B 3/4 1-4	A typographical error is corrected; the word "to" is changed to "for."
B 3 / 4 . 2 . 2 , B3/4.2.3 & 3/4.2.4	B 3/4 2-1	A typographical error in the word "AZIMUTHAL" is corrected.
B3/4.3.3.10	B 3/4 3-4	A typographical error in the word "GASEOUS" is corrected.
6.5.2.2	6-10	The CNRB composition is expanded from eight to ten members, and the list of titles is revised to reflect the current organization.



- 6.8.4.e 6-15 The footnote at the bottom of this page states that "the post-accident sampling system (PASS) shall be completely installed and OPERABLE prior to initial criticality." As documented in FPL L-84-333, dated November 20, 1984, the Post Accident Sampling System was installed and OPERABLE as required; therefore, the footnote can be deleted.
- 6.9.1 6-16 The text is revised to reflect a recent change to 10 CFR 50.4 on procedures for communicating with the NRC Staff (51FR40303).
- 6.9.1.6 6-17 The text is revised to reflect a recent change to 10 CFR 50.4 on procedures for communicating with the NRC Staff (51FR40303).
- 6.9.1.9 6-20 The text is revised to reflect a recent change to 10 CFR 50.4 on procedures for communicating with the NRC Staff (51FR40303).
- 6.9.1.10 6-20 The text is revised to reflect a recent change to 10 CFR 50.4 on procedures for communicating with the NRC Staff (51FR40303).
- 6.9.2 6-20 The text is revised to reflect a recent change to 10 CFR 50.4 on procedures for communicating with the NRC Staff (51FR40303).

6.13.1

6-23

This Specification applies to the Process Control Program (PCP) and states that "the PCP shall be approved by the Commission prior to implementation." The Commission approved the PCP on May 10, 1983 by letter from G. W. Knighton (NRC) to R. E. Uhrig (FPL). Therefore it is proposed that Specification 6.13.1 be deleted and the subsequent sections be renumbered accordingly.

6.14.1

6-23

This Specification applies to the Offsite Dose Calculation Manual (ODCM) and states that the ODCM shall be approved by the Commission prior to implementation." The Commission approved the ODCM on July 28, 1983 by letter from G. W. Knighton (NRC) to R. E. Uhrig (FPL). Therefore, it is proposed that Specification 6.14.1 be deleted and the subsequent sections be renumbered accordingly.

ATTACHMENT I (con't)

(3) Marked-Up Technical Specifications Pages

3/4 1-1
3/4 1-2
3/4 1-3
3/4 1-5
3/4 1-8
3/4 1-10
3/4 1-12
3/4 1-14
3/4 3-25
3/4 3-26
3/4 3-34
3/4 3-39
3/4 3-53
3/4 3-57
3/4 4-27
3/4 4-38
3/4 5-6
3/4 6-5
3/4 6-15
3/4 6-21
3/4 6-23
3/4 7-4
3/4 7-39
3/4 8-1
3/4 8-2
3/4 9-5
3/4 11-6
3/4 11-10
B 3/4 0-3
B 3/4 1-1
B 3/4 1-2
B 3/4 1-4
B 3/4 2-1
B 3/4 3-4
6-10
6-10 (proposed insert)
6-15
6-16
6-17
6-20
6-23

(1954) 10/10/54

10/10/54

10/10/54

10/10/54