

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8705260002      DOC. DATE: 87/05/13      NOTARIZED: YES      DOCKET #  
 FACIL: 50-335 St. Lucie Plant, Unit 1, Florida Power & Light Co.      05000335  
 AUTH. NAME      AUTHOR AFFILIATION  
 WOODY, C. D.      Florida Power & Light Co.  
 RECIP. NAME      RECIPIENT AFFILIATION  
                                  Document Control Branch (Document Control Desk)

SUBJECT: Application for amend to License DPR-67, changing Tech Spec 3/4.6.4, "Combustible Gas Control-Hydrogen Analyzers," to clarify calibr & surveillance requirements & grab sample sys for containment hydrogen determination. Fee paid.

DISTRIBUTION CODE: A001D      COPIES RECEIVED: LTR 1 ENCL 1      SIZE: 2 + 6  
 TITLE: DR Submittal: General Distribution

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD2-2 LA	1 0	PD2-2 PD	5 5
	TOURIGNY, E	1 1		
INTERNAL:	ARM/DAF/LFMB	1 0	NRR/DEST/ADE	1 1
	NRR/DEST/ADS	1 1	NRR/DOEA/TSB	1 1
	NRR/PMAS/ILRB	1 1	OGC/HDS2	1 0
	<u>REG FILE</u> 01	1 1		
EXTERNAL:	EG&G BRUSKE, S	1 1	LPDR	1 1
	NRC PDR	1 1	NSIC	1 1

TOTAL NUMBER OF COPIES REQUIRED: LTTR 18 ENCL 15

DECEMBER 10 1963

CLARENCE M. BROWN

VS

UNITED STATES

IN RE: CLARENCE M. BROWN

RETURNED TO SENDER BY ADDRESSEE  
NO POSTAGE NECESSARY IF MAILED IN THE UNITED STATES

RECEIVED BY ADDRESSEE  
NO POSTAGE NECESSARY IF MAILED IN THE UNITED STATES

COPIES  
10

EXHIBIT  
10

EXHIBIT  
10

EXHIBIT  
10

COPIES  
10

EXHIBIT  
10

EXHIBIT  
10

EXHIBIT  
10

COPIES  
10

EXHIBIT  
10

EXHIBIT  
10

EXHIBIT  
10



MAY 13 1987

L-87-209

Office of Nuclear Reactor Regulation  
Attn: "Document Control Desk  
Washington, D. C. 20555

Gentlemen:

Re: St. Lucie Unit I  
Docket No. 50-335  
Proposed License Amendment  
Combustible Gas Control - Hydrogen Analyzers

In accordance with 10 CFR 50.90, Florida Power & Light Company (FPL) submits herewith a request to amend Facility Operating License DPR-67.

The proposed amendment involves a change to Technical Specification 3/4.6.4 "Combustible Gas Control-Hydrogen Analyzers". The proposed change provides clarification as to calibration and surveillance required for the two hydrogen analyzers and their grab sample systems for containment hydrogen determination.

A marked up copy of the affected Technical Specification page is included as Attachment 1. A Safety Evaluation in support of the proposed amendment is included as Attachment 2. A "Determination of No Significant Hazards Consideration" is provided as Attachment 3.


The proposed amendment has been reviewed by the St. Lucie Facility Review Group and the Florida Power & Light Company Nuclear Review Board.

In accordance with 10 CFR 50.91(b)(1), a copy of the proposed amendment is being forwarded to the state designee for the State of Florida.

In accordance with 10 CFR 170.21, FPL Check No. 4540 is attached as remittance for the license amendment application fee for St. Lucie Unit I.

Please contact us if you have any questions about this submittal.

Very truly yours,

  
C. O. Woody  
Group Vice President  
Nuclear Energy

8705260002 870513  
PDR ADOCK 05000335  
PDR

COW/MSD/gp  
Attachments (5)

cc: Dr. J. Nelson Grace, Regional Administrator, USNRC, Region II  
Mr. Lyle Jerrett, Florida Dept. of Health and Rehabilitative Services  
Senior Resident Inspector, USNRC, St. Lucie Plant

ADD  
1/1

000000

no 1000 1000 1000 1000 1000  
1000 1000 1000 1000 1000  
1000 1000 1000 1000 1000

1000 1000

1000 1000

1000 1000

1000 1000

1000 1000

1000 1000 1000 1000 1000  
1000 1000 1000 1000 1000

1000 1000 1000 1000 1000  
1000 1000 1000 1000 1000  
1000 1000 1000 1000 1000  
1000 1000 1000 1000 1000

1000 1000 1000 1000 1000  
1000 1000 1000 1000 1000  
1000 1000 1000 1000 1000  
1000 1000 1000 1000 1000

1000 1000 1000 1000 1000  
1000 1000 1000 1000 1000

1000 1000 1000 1000 1000  
1000 1000 1000 1000 1000

1000 1000 1000 1000 1000  
1000 1000 1000 1000 1000

1000 1000 1000 1000 1000

1000 1000


1000 1000 1000 1000 1000  
1000 1000 1000 1000 1000  
1000 1000 1000 1000 1000

STATE OF FLORIDA            )  
  )    ss.  
COUNTY OF PALM BEACH )

C. O. Woody being first duly sworn, deposes and says:


That he is a Group Vice President of Florida Power & Light Company, the Licensee herein;

That he has executed the foregoing document; that the statements made in this document are true and correct to the best of his knowledge, information, and belief, and that he is authorized to execute the document on behalf of said Licensee.

  
C. O. Woody

Subscribed and sworn to before me this

13 day of May, 1987.



NOTARY PUBLIC, in and for the County  
of Palm Beach, State of Florida

NOTARY PUBLIC STATE OF FLORIDA  
MY COMMISSION EXP SEPT 18, 1989  
BONDED THRU GENERAL INS. UND.  
My Commission expires: \_\_\_\_\_



Small, illegible handwritten marks or characters in the top right corner.

Faint, illegible text scattered across the upper middle section of the page, possibly representing a header or introductory paragraph.



Faint, illegible text located below the circular stamp.