

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8706160457 DDC DATE: 87/06/09 NOTARIZED: NO
 FACIL: 50-389 St. Lucie Plant, Unit 2, Florida Power & Light Co.
 AUTH. NAME: WOODY, C. O. AUTHOR AFFILIATION: Florida Power & Light Co.
 RECIP. NAME: RECIPIENT AFFILIATION: Document Control Branch (Document Control Desk)

DOCKET #
05000389

SUBJECT: Advises that util will propose amend to License NPF-16 by 870930 to surveillance requirements of Tech Spec 4.7.1.5 to change time required for full MSIV closure. Amend will make MSIV Spec consistant w/philosophy used in MFIV Spec.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 2
 TITLE: OR Submittal: General Distribution

NOTES:

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		LTTR	ENCL		ID CODE/NAME		LTTR	ENCL
	PD2-2 LA		1	0		PD2-2 PD		5	0
	TOURIGNY, E		1	1					
INTERNAL:	ARM/DAF/LFMB		1	0		NRR/DEST/ADE		1	1
	NRR/DEST/ADS		1	1		NRR/DOEA/TSB		1	1
	NRR/PMAS/ILRB		1	1		OGC/HDS2		1	0
	<u>REG FILE</u> 01		1	1					
EXTERNAL:	EG&G BRUSKE, S		1	1		LPDR		1	1
	NRC PDR		1	1		NSIC		1	1

TOTAL NUMBER OF COPIES REQUIRED: LTTR 18 ENCL 0



7

1. The first part of the document discusses the importance of maintaining accurate records of all transactions. It emphasizes that this is crucial for ensuring the integrity of the financial system and for providing a clear audit trail.

2. The second part of the document outlines the specific procedures for recording transactions. It details the steps involved in entering data into the system, from initial recording to final verification.

3. The third part of the document addresses the issue of data security. It discusses the various measures that should be taken to protect the information stored in the system, including the use of encryption and access controls.

4. The fourth part of the document discusses the importance of regular backups. It explains how backups can help to prevent data loss in the event of a system failure or disaster.

5. The fifth part of the document discusses the importance of training. It explains that all users of the system should be properly trained to ensure that they are able to use the system effectively and to follow the established procedures.


6. The sixth part of the document discusses the importance of documentation. It explains that all procedures and policies should be clearly documented to ensure that they are consistent and can be easily followed.

7. The seventh part of the document discusses the importance of communication. It explains that all users should be kept informed of any changes to the system or procedures, and that there should be a clear channel for reporting any problems.

8. The eighth part of the document discusses the importance of monitoring. It explains that the system should be regularly monitored to ensure that it is operating correctly and that any issues are identified and resolved as quickly as possible.

9. The ninth part of the document discusses the importance of evaluation. It explains that the system should be regularly evaluated to ensure that it is meeting the needs of the organization and that any necessary improvements are made.

10. The tenth part of the document discusses the importance of compliance. It explains that the system must be designed and operated in a way that complies with all relevant laws and regulations.



U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

Gentlemen:


Re: St. Lucie Unit 2
Docket No. 50-389
Main Feedwater Isolation Valve Closure Time

By letter L-83-349, dated June 17, 1983, Florida Power & Light Company proposed a license amendment requesting various administrative/editorial changes and a change to the steam generator pressure/temperature limit. By letter L-84-148 dated June 4, 1984, FPL proposed a license amendment for Cycle 2 operation which bounded "stretch" power operation (i.e. to upgrade rated core power from 2560 MWt to 2700 MWt). "Stretch" power operation was proposed subsequently by FPL letter L-84-354, dated November 21, 1984. The bounding operation proposal of June 4, 1984, was issued as Amendment No. 8 on November 9, 1984, and "stretch" power was approved by Amendment No. 9 dated March 1, 1985. By letter dated March 11, 1987, (E. G. Tourigny to C. O. Woody) the NRC issued Amendment No. 18 to the St. Lucie Unit 2 Facility Operating License No. NPF-16. This amendment consisted of changes requested in FPL's June 17, 1983, application, with the exception of the proposal to revise the main feedwater isolation valve (MFIV) closure time to 4.2 seconds. The staff noted that it believes the MFIV closure time of Technical Specification 4.7.1.6 should be 4.0 seconds instead of 4.2 seconds and took no action on this aspect of the application. FPL was requested to respond to its intended disposition of this issue.

The issue of MFIV closure time proposed in our June 17, 1983, submittal had been superseded by our "stretch" power amendment proposals. The MFIV full closure time of 5.15 seconds currently specified in the Technical Specifications continues to be a correct value as determined by St. Lucie Unit 2 accident analyses. As a result, FPL does not propose to revise this Technical Specification.

FPL believes that the OPERABILITY of the MFIVs is verified by performance of testing which confirms the ability of these valves to shut within the time limit required by the "stretch" power accident analyses. This value is 5.15 seconds for St. Lucie Unit 2. If full valve closure is accomplished within this time frame, regardless of valve stroke time, then the accident analyses, which assume MFIV closure, are confirmed. The ability of the MFIVs to isolate within 5.15 seconds is conducted and verified periodically in accordance with Specification 4.3.2.3.

EJW4/029/1



an FPL Group company

100-100000

100-100000

100-100000

100-100000

100-100000

100-100000

100-100000

100-100000

U. S. Nuclear Regulatory Commission
L-87-227
Page two

Main Steam Isolation Valve (MSIV) Technical Specification 4.7.1.5 requires full MSIV closure within 5.6 seconds, considering only valve stroke time. The MSIV full closure time assumed by the "stretch" power accident analyses is 6.75 seconds. If full valve closure of the MSIVs is accomplished within this time frame, regardless of valve stroke time, then the accident analyses which assume MSIV closure are confirmed. The ability of the MSIVs to isolate within 6.75 seconds is conducted and verified periodically in accordance with Specification 4.3.2.3.

Based on the above, FPL will propose an amendment by September 30, 1987 to the St. Lucie Unit 2 Facility Operating License to revise the Surveillance Requirements of Specification 4.7.1.5 to change the time required for full MSIV closure to 6.75 seconds. This amendment will make MSIV Specification consistent with the philosophy used in establishing the MFIV Specification.

If additional information is required on this topic, please contact us.

Very truly yours,



C. O. Woody
Group Vice President
Nuclear Energy

COW/EJW/gp

cc: J. Nelson Grace, Regional Administrator, Region II, USNRC
Senior Resident Inspector, USNRC, St. Lucie Plant

11

1. The first step is to identify the problem. This involves understanding the current situation and the goals that need to be achieved.

Page 10

1. *Author's name*
 2. *Author's address*
 3. *Author's phone number*
 4. *Author's email address*

[illegible]