

REGULATOR INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8707170144 DOC. DATE: 87/06/25 NOTARIZED: NO DOCKET #
 FACIL: 50-335 St. Lucie Plant, Unit 1, Florida Power & Light Co. 05000335
 50-389 St. Lucie Plant, Unit 2, Florida Power & Light Co. 05000389
 AUTH. NAME AUTHOR AFFILIATION
 ROBERTS, E. W. EG&G Idaho, Inc. (subs. of EG&G, Inc.)
 ROBERTS, E. W. Idaho National Engineering Laboratory
 RECIP. NAME RECIPIENT AFFILIATION
 CARRINGTON, M. Office of Nuclear Reactor Regulation, Director (Post 870411)

SUBJECT: Forwards EGG-NTA-7657, "Conformance to Generic Ltr 83-28, Item 2.2.2, 'Vendor Interface Programs for All Other Safety-Related ...,' final rept. Plant does not conform to item. Description of contact w/supplier & vendors requested.

DISTRIBUTION CODE: H001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 1+17
 TITLE: File Location Distribution: NRR Docket 50

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
INTERNAL:	REG FILE 01	1 1		
EXTERNAL:	LPDR	1 1	NRC PDR	1 1

Add'. E. Touregay Ltr ENCL
 1 1

TOTAL NUMBER OF COPIES REQUIRED: LTR 4 ENCL 4

100

100
100
100



Idaho National Engineering Laboratory

50-335, 389

June 25, 1987

Mr. M. Carrington, Project Manager
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

50-389

TRANSMITTAL OF FINAL REPORT, "CONFORMANCE TO GENERIC LETTER 83-28,
ITEM 2.2.2--VENDOR INTERFACE PROGRAMS FOR ALL OTHER SAFETY-RELATED
COMPONENTS: ST. LUCIE-1 AND -2," EGG-NTA-7657, JUNE 1987 (FIN D6001) -
EWR-160-87

Ref: NRC Form 189, "Evaluation of Conformance to Generic Letter 83-28 For
ORs (Project 2)" (D6001)

Dear Mr. Carrington:

Transmitted herewith is the above subject report.

The report documents INEL's evaluation of the licensee actions in response
to NRC Generic Letter 83-28, Item 2.2.2--Vendor Interface Programs for All
Other Safety-Related Components. Based on the licensee submittal, we
conclude that the plant does not conform to the generic letter on this
item. The licensee should document and describe their program of regular
contact with the NSSS supplier and with vendors of other safety-related
equipment.

Very truly yours,

E. W. Roberts, Manager
NRC Headquarters Support

ACU:gp

Enclosure:
As Stated

cc: G. L. Jones, DOE-ID
D. Lasher, NRR-SICB (2)
J. O. Zane, EG&G Idaho, Inc. (w/o Encl.)

Hood
1/1 Add: E. Tourigny Ltr Encl



11428 Rockville Pike Suite 410

Rockville, MD 20852

8707170144 870625
PDR ADDCK 05000335
P PDR