REGULATORY INFORMATION DISTRIBUTION_SYSTEM (RIDS)

ACCESSION NBR: 8708060116 DOC. DATE: 87/07/31 NOTARIZED: NO FACIL: 50-389 St. Lucie Plant, Unit 2, Florida Power & Light Co.

DOCKET # 05000389

AUTH. NAME WOODY, C. O.

AUTHOR AFFILIATION

RECIP. NAME

Florida Power & Light Co.
RECIPIENT AFFILIATION

Document Control Branch (Document Control Desk)

SUBJECT: Forwards enhanced "Technical Evaluation Flow Measurement of Centrifugal Pumps in Fixed Resistance Sys at St Lucie

Plant," per NRC 870304 meeting. Meeting concerned appeal of NRC 870210 denial of relief request from ASME Section XI.

DISTRIBUTION CODE: A047D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2+17
TITLE: OR Submittal: Inservice Inspection/Testing

NOTES:

	RECIPIENT ID CODE/NAME PD2-2 LA	COPI LTTR 1	ES ENCL O	RECIPIENT ID CODE/NAME PD2-2 PD	COPI LTTR 5	
	TOURIGNY, E	1	1			
INTERNAL:	AEOD/DOA	1	1	AEOD/DSP/TPAB	1	1
	ARM/DAF/LFMB	1	Ø	NRR/DEST/ADE	1	0
	NRR/DEST/MEB	1	1	NRR/DEST/MTB	1	1
	NRRYPMAS/ILRB	1	1	DGC/HDS2	1	Q
	REG FILE 01	. 1	1	RES/DE/EIB	1	1
EXTERNAL:	LPDR	1	1	NRC PDR	1	1
	NSIC	1	1			



JULY 3 1 1987

L-87-318

U. S. Nuclear Regulatory Commission Attn: Document Control Desk Washington, D. C. 20555

Gentlemen:

Re: St. Lucie Unit 2 Docket No. 50-389

Relief from Parts of ASME Section XI

By letter dated January 13, 1986, the NRC denied a Florida Power & Light Company (FPL) relief request from the requirements of IWP-4600 of ASME Section XI regarding flow measurement. By letter dated October 13, 1986, FPL submitted a revised request for relief from performing quarterly flow measurements for certain pumps as specified in the 1980 Edition through the Winter 1980 Addenda of Section XI. As a basis for this request, FPL showed that flow measurement cannot be performed for some of the pumps because the pumps do not contain flow measurement devices and that quarterly flow measurement for the remaining pumps is impractical without design modifications to permit performance of the flow measurement tests under Section XI of the ASME Code.

By letter dated February 10, 1987, the NRC denied FPL's revised relief request and directed FPL to install certain flow measurement devices for the pumps by the next refueling outage for St. Lucie Unit 2. Also, in that same letter, FPL was given the opportunity to request an appeal meeting.

On March 4, 1987, FPL met with the NRC to appeal the decision in NRC's letter of February 10, 1987. At this meeting, FPL restated its position that quarterly flow measurements were impossible or impractical absent design modifications, and that FPL was not required under 10 CFR 50.55a(g) to modify its design. Following the FPL appeal presentation, the NRC requested that FPL provide NRC with an enhanced technical evaluation which addresses the impracticality of performing flow measurements specified in Section XI of the ASME Code (including an evaluation of the adequacy of the tests proposed by FPL in its October 13, 1986 letter and an evaluation of whether installation of the flow measurement devices identified in the NRC's letter of February 10, 1987, would provide additional assurance of pump operational readiness). The purpose of this letter is to transmit the requested enhanced technical evaluation.



A047

r - *

The state of the s

•

.

U. S. Nuclear Regulatory Commission L-87-318 Page two

Revised relief requests are being developed consistent with the determinations of impracticality supported in the attached technical evaluation. The revised relief requests will be submitted to the NRC at a later date.

If there should be any questions, please contact us.

Very truly yours,

C. O. Woody

Group Vice President

Nuclear Energy

COW/MSD/gp

Attachment

cc: Dr. J. Nelson Grace, Regional Administrator, Region II, USNRC Senior Resident Inspector, USNRC, St. Lucie Plant

A CAMBERTAN TO THE REPORT OF A CAMBERT AND A

ing state of the s

Company of the second

And the second s

The state of the s

3 ¹⁶ 1