

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8709100217      DOC. DATE: 87/09/04      NOTARIZED: NO      DOCKET #  
 FACIL: 50-389 St. Lucie Plant, Unit 2, Florida Power & Light Co.      05000389  
 AUTH. NAME      AUTHOR AFFILIATION  
 WOODY, C. O.      Florida Power & Light Co.  
 RECIP. NAME      RECIPIENT AFFILIATION  
                                  Document Control Branch (Document Control Desk)

SUBJECT: Application for amend to License NPF-16 revising Tech Spec  
 Surveillance Requirement 4.4.5.2 re Steam Generator Tube  
 Sample Selection & Insp by adding new section excluding  
 tubes in batwing area of steam generator. Fee paid.

DISTRIBUTION CODE: A001D      COPIES RECEIVED: LTR 1 ENCL 1      SIZE: 3+11  
 TITLE: DR Submittal: General Distribution

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD2-2 LA	1 0	PD2-2 PD	5 5
	TOURIGNY, E	1 1		
INTERNAL:	ARM/DAF/LFMB	1 0	NRR/DEST/ADS	1 1
	NRR/DEST/CEB	1 1	NRR/DEST/MTB	1 1
	NRR/DEST/RSB	1 1	NRR/DOEA/TSB	1 1
	<del>NRR/PMAS/ILRB</del>	1 1	DGC/HDS2	1 0
	<u>REG FILE</u> 01	1 1	RES/DE/EIB	1 1
EXTERNAL:	EG&G BRUSKE, S	1 1	LPDR	1 1
	NRC PDR	1 1	NSIC	1 1

w/Check \$ 150  
 # 5408

11.4.84

1

1

02. 6 1984  
11.4.84



SEPTEMBER 04 1987

L-87-369

U. S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, D. C. 20555

Gentlemen:

Re: St. Lucie Unit 2  
Docket No. 50-389  
Proposed License Amendment  
Steam Generator Tube Sample Selection and Inspection

In accordance with 10 CFR 50.90, Florida Power & Light Company (FPL) submits herewith a request to amend Facility Operating License NPF-16.

The proposed amendment revises the Technical Specification Surveillance Requirement 4.4.5.2, Steam Generator Tube Sample Selection and Inspection, by adding a new section which excludes tubes in the "batwing" area of the steam generator from the sample selection. Tubes in the "batwing" area, if 100% inspected, would not be included in the determination of the Category of Inspection Results. This proposed amendment will result in a more representative determination of the status of tubes in all other areas of the steam generator while additionally recognizing the need for 100% surveillance of tubes in the "batwing."

A marked up copy of the affected Technical Specification page is included as Attachment 1. A Safety Evaluation, in support of the proposed amendment is included as Attachment 2. A "Determination of No Significant Hazards Consideration" is provided as Attachment 3.

The proposed amendment has been reviewed by the St. Lucie Facility Review Group and the Florida Power & Light Company Nuclear Review Board.

In accordance with 10 CFR 50.91(b)(1), a copy of the proposed amendment is being forwarded to the state designee for the State of Florida.

8709100217 870904  
PDR ADDCK 05000389  
P PDR

*Approved  
11/11 w/ check  
#150  
#5408*




U. S. Nuclear Regulatory Commission  
L-87-369  
Page two

In accordance with 10 CFR 170.21, FPL Check No. 5408 is attached as remittance for the license amendment application fee.

Please contact us if you have any questions about this submittal.

Very truly yours,

  
C. O. Woody  
Group Vice President  
Nuclear Energy

COW/EJW/gp

Attachments (5)

cc: Dr. J. Nelson Grace, Regional Administrator, USNRC, Region II  
Senior Resident Inspector, USNRC, St. Lucie Plant  
Mr. Lyle Jerrett, Florida Dept. of Health and Rehabilitative Services



1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

26

27

28

29

30

31

32

33

34

35

36

37

38

39

40

41

42

43

44

45

46

47

48

49

50


51

STATE OF FLORIDA            )  
  )  
COUNTY OF PALM BEACH    ) ss.



E. A. Adomat being first duly sworn, deposes and says:

That he is an Executive Vice President of Florida Power & Light Company, the Licensee herein;

That he has executed the foregoing document; that the statements made in this document are true and correct to the best of his knowledge, information, and belief, and that he is authorized to execute the document on behalf of said Licensee.

  
\_\_\_\_\_  
E. A. Adomat

Subscribed and sworn to before me this  
4th day of September, 1987.

   
\_\_\_\_\_  
NOTARY PUBLIC, in and for the County  
of Palm Beach, State of Florida

My Commission expires: NOTARY PUBLIC STATE OF FLORIDA  
MY COMMISSION EXP. JAN. 6, 1989  
BONDED THRU GENERAL INS. UND.



21794  
1954  
1954  
1954