

ATTACHMENT I

ST. LUCIE UNIT I.

MARKED UP TECHNICAL SPECIFICATION PAGE

3/4 6-23

8710260183 871021
PDR ADOCK 05000335
P PDR



Handwritten marks and scribbles in the top right corner.

Faint, illegible text or markings in the upper middle section of the page.

CONTAINMENT SYSTEMS

3/4.6.4 COMBUSTIBLE GAS CONTROL

HYDROGEN ANALYZERS

LIMITING CONDITION FOR OPERATION

^{Two independent}
3.6.4.1 [^] The containment hydrogen analyzers and grab sample system shall be OPERABLE.

APPLICABILITY: MODES 1 and 2.

ACTION:

With either ^{one} the hydrogen analyzer or grab sample system inoperable, restore the inoperable analyzer or grab sample system to OPERABLE status within 30 days or be in at least HOT STANDBY within the next 6 hours.

demonstrate within the next 24 hours that the grab sample system of the inoperable hydrogen analyzer has the capability to draw a sample of the containment atmosphere into the grab sample canister. Verify this capability of the grab sample system at least once per 30 days thereafter. Return the inoperable hydrogen analyzer to OPERABLE status within an additional 60 days. Otherwise,

SURVEILLANCE REQUIREMENTS

4.6.4.1.1 ^{Each} The hydrogen analyzer shall be demonstrated OPERABLE ^{by the performance of a CHANNEL FUNCTIONAL TEST} at least once per ³¹ 92 days, by: and at least once per 92 days on a STAGGERED TEST BASIS by performing a CHANNEL CALIBRATION using sample gases containing:

a. ~~Performing a CHANNEL CALIBRATION using sample gases containing:~~

^{Nominally}
a. ¹ One volume percent hydrogen, balance nitrogen, and oxygen.

^{Nominally}
b. ⁴ Four volume percent hydrogen, balance nitrogen, and oxygen.

b. ~~Verifying that the analyzer is aligned to receive electrical power from an OPERABLE emergency bus.~~

4.6.4.1.2 ~~The grab sample system shall be demonstrated OPERABLE at least once per 92 days by using the hydrogen sample pumps to draw a sample of the containment atmosphere into the grab sample canister. The hydrogen sample pumps shall be used on an alternating basis.~~

Handwritten marks in the top right corner, possibly initials or a date.



Faint, illegible text scattered across the lower half of the page, possibly bleed-through from the reverse side.

ATTACHMENT 2

ST. LUCIE UNIT 2

MARKED UP TECHNICAL SPECIFICATION PAGE

3/4 6-24



1944

1945

1946

1947

1948

1949

1950

1951

1952

1953

1954

1955

1956

1957

1958

1959

1960

1961

1962

1963

1964

1965

1966

1967

1968

1969

1970

1971

1972

1973

1974

1975

1976

1977

1978

1979

1980

1981

1982

1983

1984

1985

1986

1987

1988

1989

1990

1991

1992

1993

1994

1995

1996

1997

1998

1999

2000

2001

2002

2003

2004

2005

2006

2007

2008

2009

2010

2011

2012

2013

2014

2015

2016

2017

2018

2019

2020


2021

2022

2023

2024

2025



CONTAINMENT SYSTEMS

3/4.6.4 COMBUSTIBLE GAS CONTROL

HYDROGEN ANALYZERS

LIMITING CONDITION FOR OPERATION

3.6.4.1 Two independent containment hydrogen analyzers shall be OPERABLE.

APPLICABILITY: MODES 1 and 2.

ACTION:


With one hydrogen analyzer inoperable, restore the inoperable analyzer to OPERABLE status within 30 days or be in at least HOT STANDBY within the next 6 hours.

demonstrate within the next 24 hours that the grab sample system of the inoperable hydrogen analyzer has the capability to draw a sample of the containment atmosphere into the grab sample canister. Verify this capability of the grab sample system at least once per 30 days thereafter. Return the inoperable hydrogen analyzer to OPERABLE status within an additional 60 days. Otherwise,

SURVEILLANCE REQUIREMENTS

4.6.4.1 Each hydrogen analyzer shall be demonstrated OPERABLE by the performance of a CHANNEL FUNCTIONAL TEST at least once per 31 days, and at least once per 92 days on a STAGGERED TEST BASIS by performing a CHANNEL CALIBRATION using sample gases containing:

- a. ^{Nominally} One volume percent hydrogen, balance nitrogen and oxygen.
- b. ^{Nominally} Four volume percent hydrogen, balance nitrogen and oxygen.



DISTRIBUTION

Docket File w/o encl.
PD22 Reading w/o encl.
DMiller w/encl.
ETourigny w/encl.

October 21, 1987

DOCKET NO(S). 50-335 and 50-389
Mr. C. O. Woody
Group Vice President
Nuclear Energy
Florida Power and Light Company
Post Office Box 14000
Juno Beach, Florida 33408
SUBJECT: ST. LUCIE UNITS 1 AND 2

The following documents concerning our review of the subject facility are transmitted for your information.

- Notice of Receipt of Application, dated _____.
- Draft/Final Environmental Statement, dated _____.
- Notice of Availability of Draft/Final Environmental Statement, dated _____.
- Safety Evaluation Report, or Supplement No. _____ dated _____.
- Environmental Assessment and Finding of No Significant Impact, dated _____.
- Notice of Consideration of Issuance of Facility Operating License or Amendment to Facility Operating License, dated _____.
- Bi-Weekly Notice; Applications and Amendments to Operating Licenses Involving No Significant Hazards Considerations, dated 10/07/87 [see page(s)] _____.
- Exemption, dated _____.
- Construction Permit No. CPPR-_____, Amendment No. _____ dated _____.
- Facility Operating License No. _____, Amendment No. _____ dated _____.
- Order Extending Construction Completion Date, dated _____.
- Monthly Operating Report for _____ transmitted by letter dated _____.
- Annual/Semi-Annual Report- _____
_____ transmitted by letter dated _____.

Division of Reactor Projects-I/II
Office of Nuclear Reactor Regulation

Enclosures:
As stated

cc: See next page

OFFICE ▶	LA: PD22						
SURNAME ▶	DMiller						
DATE ▶	10/21/87						

