

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8711060290 DOC. DATE: 87/11/02 NOTARIZED: NO DOCKET #
 FACIL: 50-389 St. Lucie Plant, Unit 2, Florida Power & Light Co. 05000389
 AUTH. NAME: WOODY, C. O. AUTHOR AFFILIATION: Florida Power & Light Co.
 RECIP. NAME: RECIPIENT AFFILIATION: Document Control Branch (Document Control Desk)

SUBJECT: Informs that 8 tubes in Steam Generator A & 10 tubes in Steam Generator B plugged due to insp during Oct 1987.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 1
 TITLE: OR Submittal: General Distribution

NOTES:

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		LTR	ENCL		ID CODE/NAME		LTR	ENCL
	PD2-2 LA		1	0		PD2-2 PD		5	5
	TOURIGNY, E		1	0					
INTERNAL:	ARM/DAF/LFMB		1	0		NRR/DEST/ADS		1	1
	NRR/DEST/CEB		1	0		NRR/DEST/MTB		1	1
	NRR/DEST/RSB		1	0		NRR/DOEA/TSB		1	1
	NRR/PMAS/ILRB		1	0		OGC/HDS2		1	0
	<u>REG FILE</u> 01		1	0		RES/DE/EIB		1	1
EXTERNAL:	EG&G BRUSKE, S		1	1		LPDR		1	1
	NRC PDR		1	1		NSIC		1	1

TOTAL NUMBER OF COPIES REQUIRED: LTR 21 ENCL 10

mlAcl



NOVEMBER 02 1987

L-87-444

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D.C. 20555

Gentlemen:


Re: St. Lucie Unit 2
Docket No. 50-389
Technical Specification 4.4.5.5.a. Report

The St. Lucie Unit 2 steam generators were inspected during October, 1987. As a result of the inspection the following number of steam generator tubes were plugged.

Steam Generator A: 8
Steam Generator B: 10

Should there be any questions, please contact us.

Very truly yours,


C. O. Woody
Group Vice President
Nuclear Energy

COW/MSD/gp

cc: Dr. J. Nelson Grace, Regional Administrator, Region II, USNRC
Senior Resident Inspector, St. Lucie Plant

8711060290 871102
PDR ADOCK 05000389
Q PDR

Ass 1/10

1954

1954

1954

1954

1954

1954

1954

1954

1954

1954

1954

1954

1954

1954

1954