

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8712300085 DOC. DATE: 87/12/22 NOTARIZED: YES DOCKET #
 FACIL: 50-335 St. Lucie Plant, Unit 1, Florida Power & Light Co. 05000335
 50-389 St. Lucie Plant, Unit 2, Florida Power & Light Co. 05000389
 AUTH. NAME AUTHOR AFFILIATION
 WOODY, C.O. Florida Power & Light Co.
 RECIP. NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Application for amends to Licenses DPR-67 & NPF-16, modifying requirements to perform moderator temp coefficient test.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 3 + 15
 TITLE: OR Submittal: General Distribution

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR	ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR	ENCL
	PD2-2 LA	1	0	PD2-2 PD	5	5
	TOURIGNY, E	1	1			
INTERNAL:	ARM/DAF/LFMB	1	0	NRR/DEST/ADS	1	1
	NRR/DEST/CEB	1	1	NRR/DEST/MTB	1	1
	NRR/DEST/RSB	1	1	NRR/DOEA/TSB	1	1
	NRR/PMAS/ILRB	1	1	OGC/HDS2	1	0
	<u>REG FILE</u> 01	1	1	RES/DE/EIB	1	1
EXTERNAL:	LPDR	1	1	NRC PDR	1	1
	NSIC	1	1			

REC'D w/ check \$150.00

6779

R
I
D
S
/
A
D
D
S

TOTAL NUMBER OF COPIES REQUIRED: LTTR 20 ENCL 17



DECEMBER 22 1987

L-87-525

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

Gentlemen:

Re: St. Lucie Units 1 and 2
Docket Nos. 50-335 and 50-389
Proposed License Amendments
Moderator Temperature Coefficient Surveillance Requirements

In accordance with 10 CFR 50.90, Florida Power & Light Company (FPL) submits herewith a request to amend Facility Operating Licenses DPR-67 and NPF-16.

The proposed amendment involves changes to the St. Lucie Units 1 and 2 Technical Specifications which modify the requirements to perform a Moderator Temperature Coefficient (MTC) Test near the end of each cycle. Under the proposed change this test would not be required if tests conducted at earlier times in the cycle, design MTC calculations, and core reactivity characteristics predict satisfactory MTC behavior will be obtained for the remainder of the cycle. The proposed change will also modify St. Lucie Unit 1 MTC surveillance requirement 4.1.1.4.2.b so that it will be consistent with the Combustion Engineering Standard Technical Specifications and with the St. Lucie Unit 2 Technical Specifications.

Marked up copies of the affected Technical Specification pages for each Unit are included as Attachment 1. A Safety Evaluation in support of the proposed amendment is included as Attachment 2. A "Determination of No Significant Hazards Consideration" is provided as Attachment 3.

The proposed amendment has been reviewed by the St. Lucie Facility Review Group and the Florida Power & Light Company Nuclear Review Board.

In accordance with 10 CFR 50.91(b)(1), a copy of the proposed amendment is being forwarded to the state designee for the State of Florida.

Acc/
/1

Rec'd w/cheque \$150.00
6779

EJW4/052/1 (8712300085 871222
PDR ADOCK 05000335
P DCD)

an FPL Group company




[The text in this section is extremely faint and illegible due to low contrast and noise. It appears to be a large block of text, possibly a list or a series of entries, but the individual characters and words cannot be discerned.]

U. S. Nuclear Regulatory Commission
L-87-525
Page two

In accordance with 10 CFR 170.21, FPL Check No. 6779 is attached as remittance for the license amendment application fee.

Please contact us if you have any questions about this submittal.

Very truly yours,


C. O. Woody
Executive Vice President

COW/EJW/gp

Attachments

cc: Dr. J. Nelson Grace, Regional Administrator, USNRC, Region II
Senior Resident Inspector, USNRC, St. Lucie Plant
Mr. Lyle Jerrett, Florida Dept. of Health and Rehabilitative Services

1962
1963

1964
1965

1966
1967

1968
1969
1970


1971
1972
1973

STATE OF FLORIDA)
)
COUNTY OF PALM BEACH) ss.


C. O. Woody being first duly sworn, deposes and says:


That he is Executive Vice President of Florida Power & Light Company, the Licensee herein;

That he has executed the foregoing document; that the statements made in this document are true and correct to the best of his knowledge, information, and belief, and that he is authorized to execute the document on behalf of said Licensee.


C. O. Woody

Subscribed and sworn to before me this
22 day of DECEMBER, 1987.


NOTARY PUBLIC, in and for the County
of Palm Beach, State of Florida



My Commission expires: _____

NOTARY PUBLIC STATE OF FLORIDA
MY COMMISSION EXP. OCT. 30, 1991
BONDED THRU GENERAL INS. UND.

Two large black circular marks are positioned at the top center of the page. Faint, illegible text is scattered across the upper half of the document.

