

# ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8801070344      DOC. DATE: 87/12/30      NOTARIZED: NO      DOCKET #  
 FACIL: 50-335 St. Lucie Plant, Unit 1, Florida Power & Light Co.      05000335  
 50-389 St. Lucie Plant, Unit 2, Florida Power & Light Co.      05000389

AUTH. NAME      AUTHOR AFFILIATION  
 WOODY, C.O.      Florida Power & Light Co.  
 RECIPIENT AFFILIATION  
 Document Control Branch (Document Control Desk)

SUBJECT: Forwards NSHC & revised Tech Specs re pump & valve testing program, per 871116 request.


DISTRIBUTION CODE: A047D      COPIES RECEIVED: LTR 1 ENCL 1      SIZE: 9  
 TITLE: OR Submittal: Inservice Inspection/Testing

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTR	ENCL	RECIPIENT ID CODE/NAME	COPIES LTR	ENCL
	PD2-2 LA	1	0	PD2-2 PD	5	5
	TOURIGNY, E	1	1			
INTERNAL:	AEOD/DOA	1	1	AEOD/DSP/TPAB	1	1
	ARM/DAF/LFMB	1	0	NRR/DEST/MEB	1	1
	NRR/DEST/MTB	1	1	NRR/PMAS/ILRB	1	1
	OGC/HDS2	1	0	<u>REG FILE</u> 01	1	1
	RES/DE/EIB	1	1			
EXTERNAL:	LPDR	1	1	NRC PDR	1	1
	NSIC	1	1			

TOTAL NUMBER OF COPIES REQUIRED: LTR 19 ENCL 16

R  
I  
D  
S  
/  
A  
D  
D  
S  
  
R  
I  
D  
S  
/  
A  
D  
D  
S





DECEMBER 30, 1987

L-87-541

U. S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, D. C. 20555

Gentlemen:

Re: St. Lucie Unit 1  
Docket Nos. 50-335 and 50-389  
Proposed License Amendment  
Pump and Valve Testing Program Technical Specifications

By letter L-87-469, dated November 16, 1987, Florida Power & Light Company (FPL) proposed to revise various Technical Specifications with respect to the St. Lucie 1 Pump and Valve Program.

The proposed amendment was discussed with the NRC Staff in a conference call on December 22, 1987. During the conference call, it was requested that FPL amplify the no significant hazards consideration submitted in FPL's November 16, 1987 letter. Also, various administrative corrections were discussed with respect to the same letter. The attached no significant hazards consideration and the administrative correction replace Attachments 2 and 3 of FPL letter L-87-469 dated November 16, 1987.

If additional information is required about this submittal, please contact us.

Very truly yours,

  
C. O. Woody  
Executive Vice President

COW/EJW/gp

Attachments

cc: Dr. J. Nelson Grace, Regional Administrator,  
Region II, USNRC  
Mr. Lyle Jerrett, Florida Department of Health and  
Rehabilitative Services  
Senior Resident Inspector, USNRC, St. Lucie Plant

EJW/021.PLA

A047  
1/1

8801070344 871230  
PDR ADOCK 05000335  
P

PDR

an FPL Group company

## ATTACHMENT 2

### EVALUATION

As required by 10 CFR 50.55a(g), FPL updated the Inservice Inspection (ISI) and Inservice Testing (IST) programs, together with proposed Technical Specification amendments for St. Lucie Unit 1, to the requirements of the 1974 Edition through Summer 1975 Addenda of the ASME Boiler and Pressure Vessel Code. The ISI and IST programs were submitted to the NRC in July and September of 1977. On December 20, 1977, the NRC granted relief, on an interim basis, pending completion of a detailed review of the programs. On April 2, 1985, the NRC issued a safety evaluation on the St. Lucie Unit 1 IST Program, and, in particular, the requests for relief from regulatory requirements applicable to the program.

The proposed amendments which were submitted in 1977, removed reference to a specific Edition and Addenda of Section XI of the ASME Boiler and Pressure Vessel Code for inservice testing and, instead, proposed a new Specification 4.0.5 addressing Surveillance Requirements for inservice inspection and testing.

The subject revised amendment maintains a similar format as was originally submitted. Differences which exist between the original 1977 submittals and the revised submittals are a result of using a more recent revision of the Combustion Engineering - Standard Technical Specifications (CE-STs).

The following Specifications are either added, revised, or deleted with respect to the St. Lucie Unit 1 Pump and Valve Testing Program:

<u>Specification</u>	<u>Revision</u>
4.0.5	New Specification 4.0.5 is added to specify the pump and valve test requirements. This addition reflects wording in the CE-STs.
4.1.2.1.a.1	Boration Systems - Shutdown Flow Paths: The surveillance activity for testing each power operated or automatic valve in the flow path required for boron injection has been removed from the technical specifications. This activity is included in the St. Lucie Unit 1 Pump and Valve Program.
4.1.2.2.a.1	Boration Systems - Operation Flow Paths: The surveillance activity for testing each power operated or automatic valve in the flow path required for boron injection has been removed from the technical specifications. This activity is included in the St. Lucie Unit 1 Pump and Valve Program.
4.1.2.2.c.1	Boration Systems - Operating Flow Paths: The 18 month surveillance activity for cycling each power operated valve in the flow path that is <u>not</u> testable during plant operation has been removed from the technical specifications. This activity is included in St. Lucie Unit 1 Pump and Valve Program.



Specification

Revision (cont)

- 4.1.2.3 Boration Systems - Charging Pumps (shutdown): The surveillance activities of starting the pump and verifying pump operation for at least 15 minutes have been removed from the technical specifications. This activity is included in St. Lucie Unit 1 Pump and Valve Program. Also, the surveillance activity of verifying electrical power from an OPERABLE emergency bus has been removed. The operability requirement in Modes 5 and 6 for electrical power sources are maintained as required in the Electrical Power System portion of the St. Lucie Unit 1 Technical Specifications. The new Surveillance Requirements refer to testing pursuant to Specification 4.0.5 (ASME Pump and Valve test requirements).
- 4.1.2.4 Boration Systems - Charging Pumps (operating): The surveillance activities of starting the pump and verifying pump operation for at least 15 minutes have been removed from the technical specifications. These activities are included in the St. Lucie Unit 1 Pump and Valve Program. The new Surveillance Requirements refer to testing pursuant to Specification 4.0.5 (ASME Pump and Valve test requirements).
- 4.1.2.5 Boration Systems - Boric Acid Pumps (shutdown): The surveillance activities of starting the pump and verifying pump operation for at least 15 minutes have been removed from the Technical Specifications. These activities are included in the St. Lucie Unit 1 Pump and Valve Program. The new Surveillance Requirement refers to testing pursuant to Specification 4.0.5 (ASME Pump and Valve test requirements).
- 4.1.2.6 Boration Systems - Boric Acid Pumps (operating): The surveillance activities of starting the pump and verifying pump operation for at least 15 minutes have been removed from the Technical Specifications. These activities are included in the St. Lucie Unit 1 Pump and Valve Program. The new Surveillance Requirement refers to testing pursuant to Specification 4.0.5 (ASME Pump and Valve test requirements).
- 4.4.2 Reactor Coolant System - Safety Valves (shutdown): The reference to Surveillance Requirement 4.4.3 (Surveillance Requirement for Safety Valves-Operating) has been removed. The safety valves will be demonstrated OPERABLE in accordance with Section XI of the ASME Boiler and Pressure Vessel Code as referenced in new Specification 4.0.5. This activity is included in the St. Lucie Unit 1 Pump and Valve Program.

... ..  
... ..  
... ..  
... ..

... ..  
... ..  
... ..  
... ..

... ..  
... ..  
... ..  
... ..

... ..  
... ..  
... ..  
... ..

... ..  
... ..  
... ..  
... ..

... ..  
... ..  
... ..  
... ..

CONFIDENTIAL

CONFIDENTIAL

Specification

Revision (con't)

4.4.3

Reactor Coolant System - Safety Valves (operating): Reference to a specific Edition and Addenda of the ASME Code has been removed. The safety valves will be demonstrated OPERABLE in accordance with Section XI of the ASME Boiler and Pressure Vessel Code as referenced in new Specification 4.0.5. This activity is included in the St. Lucie Unit 1 Pump and Valve Program.

4.5.2

Emergency Core Cooling Systems - ECCS Subsystems -  $T_{avg} \geq 325^{\circ} F$ : The surveillance activities of starting both the HPSI and LPSI pumps and verifying pump operation for at least 15 minutes have been removed. These activities are included in the St. Lucie Unit 1 Pump and Valve Program.

The surveillance activities of verifying the HPSI and LPSI pump discharge pressures; surveillance items 4.5.2.b.1.b and 4.5.2.b.2.b have been moved to surveillance items f.1 and f.2, respectively. The new surveillance items require verification of the total developed head on recirculation flow for both the HPSI and LPSI pumps. The original discharge pressures were used to calculate the total developed head for the pumps.

The surveillance activities of cycling each testable, power operated valve in the flow path and cycling each valve in the flow path that is not testable during plant operation have been removed. These activities are included in the St. Lucie Unit 1 Pump and Valve Program.

The surveillance activity of verifying electrical power from an OPERABLE emergency bus has been removed. The operability requirements for electrical power sources are maintained as required in the Electrical Power System portion of the St. Lucie Unit 1 Technical Specifications.

The surveillance activity of verifying that the containment sump isolation valves open upon a recirculation actuation signal has been changed from a 31 day surveillance (4.5.2.b.3) to a new 18 month surveillance (4.5.2.e.3). The containment sump isolation valves are tested in accordance with the St. Lucie Unit 1 Valve Program and will continue to be tested on a frequency consistent with the approved Edition and Addenda of the ASME Code. The basis for verifying these valves open on a recirculation isolation signal every 31 days has not been determined. Therefore, it is proposed to perform this surveillance activity on an 18-month interval, consistent with the CE-STs, St. Lucie Unit 2 Technical Specifications and the periodic integrated test of the Engineered Safety Features.



THE UNITED STATES OF AMERICA  
DEPARTMENT OF JUSTICE  
FEDERAL BUREAU OF INVESTIGATION  
WASHINGTON, D. C. 20535

MEMORANDUM FOR THE DIRECTOR  
SUBJECT: [Illegible]

RE: [Illegible]

DATE: [Illegible]

BY: [Illegible]

FOR THE DIRECTOR: [Illegible]

APPROVED: [Illegible]

100-100000

100-100000

### ATTACHMENT 3

#### NO SIGNIFICANT HAZARDS CONSIDERATION

The standards used to arrive at a determination that a request for amendment involves no significant hazards consideration are included in the Commission's regulations, 10 CFR 50.92, which states that no significant hazards considerations are involved if the operation of the facility in accordance with the proposed amendment would not (1) involve a significant increase in the probability or consequences of an accident previously evaluated; or (2) create the possibility of a new or different kind of accident from any accident previously evaluated or (3) involve a significant reduction in a margin of safety. Each standard is discussed as follows:

- (1) Operation of the facility in accordance with the proposed amendment would not involve a significant increase in the probability or consequences of an accident previously evaluated.

The addition to Technical Specification Section 4.0, Surveillance Requirements, is a change to achieve consistency between the St. Lucie Unit 1 Technical Specifications and the St. Lucie Unit 2 Technical Specifications. The intent of the Specifications has not been changed. The change incorporates the format/wording of the Combustion Engineering - Standard Technical Specifications and the St. Lucie Unit 2 Technical Specifications which have been previously approved by the staff.

Reference to Surveillance Requirements of a specific Edition and Addenda of Section XI of the ASME Boiler and Pressure Vessel Code have been removed. A new Specification 4.0.5 has been added to provide Surveillance Requirements for Inservice Testing (IST) of ASME Code Class 1, 2 and 3 Components in accordance with Section XI of the Code and applicable addenda as required by 10 CFR 50.55a(g). The addition of a new Specification 4.0.5 will establish the relationship between the Technical Specification and the Code of Federal Regulations that deal with IST and the ASME Code. The pump and valve surveillance activities which have been removed from the Technical Specifications are contained in Section XI of the ASME Code and, therefore, are included in the St. Lucie Unit 1 Pump and Valve Program. The IST program will remain in effect as a licensee-controlled document referenced in the Technical Specifications instead of the program itself being a Technical Specification.

Requirements of the ASME Section XI Inservice Testing Program and, therefore, the St. Lucie Unit 1 Inservice Testing Program, provide for measurement and evaluation of pump mechanical characteristics as well as additional measurement and evaluation of pump hydraulic characteristics. These activities are performed to determine pump operational readiness. Also, requirements of the ASME Section XI Testing Program provide for additional measurement and evaluation for determining valve operational readiness. The St. Lucie Unit 1 Inservice Testing Program provides a level of quality in testing of pumps and valves consistent with recent versions of the ASME Section XI Code and,



therefore, the removal of certain pump and valve surveillance activities from the Technical Specifications does not involve a reduction in the level of quality in testing of pumps and valves at St. Lucie Unit 1.

The surveillance activity of verifying electrical power from an operable emergency bus has been removed from individual specifications in that the operability requirements for electrical power sources are maintained as required for the Electrical Power System portion of the St. Lucie Unit 1 Technical Specifications.

The surveillance activity of verifying that the containment sump isolation valves open upon a Recirculation Actuation Signal has been changed from a 31-day surveillance activity to an 18-month surveillance activity. This change is being made to achieve consistency with the Combustion Engineering-Standard Technical Specifications and the St. Lucie Unit 2 Technical Specifications. As required by the St. Lucie Unit 1 Technical Specifications, the manual recirculation actuation signal feature is tested on an 18 month frequency as are the other manual engineered safety features. Also, as required by the ASME Valve Program the containment sump isolation valves are tested on a quarterly basis. A review of the surveillance activity sheets for verifying that the containment sump isolation valves open upon a recirculation actuation signal has been completed for an 18 month period from May 1986 to October, 1987 and no failures were observed. The containment sump isolations valves on St. Lucie Unit 1 are similar to the valves on St. Lucie Unit 2 in that they are 24 inch valves manufactured by Henry Pratt.

An addition to the Turbine Cycle-Safety Valves action statement has been made to show that the provisions of Specification 3.0.4 are not applicable for entry into an OPERATIONAL MODE. This change is being made to achieve consistency with the Combustion Engineering-Standard Technical Specifications. This is consistent with the Technical Specifications, in that Startup and/or Power Operation is allowable with safety valves inoperable within the limitations of the ACTION requirements.

Therefore, based on the above, the changes do not involve a significant increase in the probability or consequences of an accident previously evaluated.

- (2) Use of the modified specification would not create the possibility of a new or different kind of accident from any accident previously evaluated.

The addition to Technical Specification Section 4.0, Surveillance Requirements, is a change to achieve consistency between the St. Lucie Unit 1 Technical Specifications and the St. Lucie Unit 2 Technical Specifications. The intent of the Specifications has not been changed. The change incorporates the format/wording of the Combustion Engineering - Standard Technical Specifications and the St. Lucie Unit 2 Technical Specifications which have been previously approved by the staff.

1. The first part of the document discusses the importance of maintaining accurate records of all transactions and activities. It emphasizes that this is essential for ensuring transparency and accountability in the organization's operations.

2. The second part of the document outlines the various methods and tools used to collect and analyze data. It highlights the need for consistent data collection procedures and the use of advanced analytical techniques to derive meaningful insights from the data.

3. The third part of the document focuses on the role of technology in data management and analysis. It discusses how modern software solutions can streamline data collection, storage, and processing, thereby improving efficiency and accuracy.

4. The fourth part of the document addresses the challenges associated with data management, such as data quality, security, and privacy. It provides strategies to mitigate these risks and ensure that the data remains reliable and secure throughout its lifecycle.

5. The fifth part of the document discusses the importance of data governance and the role of various stakeholders in ensuring data integrity and compliance with regulatory requirements. It emphasizes the need for clear policies and procedures to guide data handling practices.

6. The sixth part of the document explores the future of data management and analysis, highlighting emerging trends such as artificial intelligence, machine learning, and cloud-based data solutions. It suggests ways in which these technologies can be leveraged to enhance data-driven decision-making.

7. The seventh part of the document provides a summary of the key findings and recommendations. It reiterates the importance of a data-driven approach and offers practical advice for organizations looking to optimize their data management practices.

8. The eighth part of the document includes a list of references and sources used in the research. It provides a comprehensive overview of the literature and resources that informed the analysis and conclusions presented in the document.

9. The ninth part of the document contains a list of appendices and supplementary materials. These include detailed data sets, charts, and tables that provide further context and support for the findings discussed in the main body of the document.

Reference to Surveillance Requirements of a specific Edition and Addenda of Section XI of the ASME Boiler and Pressure Vessel Code have been removed. A new Specification 4.0.5 has been added to provide Surveillance Requirements for Inservice Testing of ASME Code Class 1, 2 and 3 Components in accordance with Section XI of the Code and applicable addenda as required by 10 CFR 50.55a(g). The pump and valve surveillance activities which have been removed from the Technical Specifications are contained in Section XI of the ASME Code and, therefore, are included in the St. Lucie Unit 1 Pump and Valve Program. The IST program will still be governed by the Commission's rules and regulations.

Requirements of the ASME Section XI Inservice Testing Program and, therefore, the St. Lucie Unit 1 Inservice Testing Program, provide for measurement and evaluation of pump mechanical characteristics as well as additional measurement and evaluation of pump hydraulic characteristics. These activities are performed to determine pump operational readiness. Also, requirements of the ASME Section XI Testing Program provide for additional measurement and evaluation for determining valve operational readiness. The St. Lucie Unit 1 Inservice Testing Program provides a level of quality in testing of pumps and valves consistent with recent versions of the ASME Section XI Code and, therefore, the removal of certain pump and valve surveillance activities from the Technical Specifications does not involve a reduction in the level of quality in testing of pumps and valves at St. Lucie Unit 1.

The surveillance activity of verifying electrical power from an operable emergency bus has been removed from individual specifications in that the operability requirements for electrical power sources are maintained as required for the Electrical Power System portion of the St. Lucie Unit 1 Technical Specifications.

The surveillance activity of verifying that the containment sump isolation valves open upon a Recirculation Actuation Signal has been changed from a 31-day surveillance activity to an 18-month surveillance activity. This change is being made to achieve consistency with the Combustion Engineering-Standard Technical Specifications and the St. Lucie Unit 2 Technical Specifications. As required by the St. Lucie Unit 1 Technical Specifications, the manual recirculation actuation signal feature is tested on an 18 month frequency as are the other manual engineered safety features. Also, as required by the ASME Valve Program the containment sump isolation valves are tested on a quarterly basis. A review of the surveillance activity sheets for verifying that the containment sump isolation valves open upon a recirculation actuation signal has been completed for an 18 month period from May 1986 to October, 1987 and no failures were observed. The containment sump isolations valves on St. Lucie Unit 1 are similar to the valves on St. Lucie Unit 2 in that they are 24 inch valves manufactured by Henry Pratt.

An addition to the Turbine Cycle-Safety Valves action statement has been made to show that the provisions of Specification 3.0.4 are not applicable for entry into an OPERATIONAL MODE. This change is being made to achieve consistency with the Combustion Engineering-Standard Technical Specifications. This is consistent with the Technical Specifications, in



that Startup and/or Power Operation is allowable with safety valves inoperable within the limitations of the ACTION requirements.

Therefore, based on the above, the changes would not create the possibility of a new or different kind of accident from any accident previously evaluated.

- (3) Use of the modified specification would not involve a significant reduction in a margin of safety.

The addition to Technical Specification Section 4.0, Surveillance Requirements, is a change to achieve consistency between the St. Lucie Unit 1 Technical Specifications and the St. Lucie Unit 2 Technical Specifications. The intent of the Specifications has not been changed. The change incorporates the format/wording of the Combustion Engineering - Standard Technical Specifications and the St. Lucie Unit 2 Technical Specifications which have previously been approved by the staff.

Reference to Surveillance Requirements of a specific Edition and Addenda of Section XI of the ASME Boiler and Pressure Vessel Code have been removed. A new Specification 4.0.5 has been added to provide Surveillance Requirements for Inservice Testing of ASME Code Class 1, 2 and 3 Components in accordance with Section XI of the Code and applicable addenda as required by 10 CFR 50.55a(g). The pump and valve surveillance activities which have been removed from the Technical Specifications are contained in Section XI of the ASME Code and, therefore, are included in the St. Lucie Unit 1 Pump and Valve Program.

Requirements of the ASME Section XI Inservice Testing Program and, therefore, the St. Lucie Unit 1 Inservice Testing Program, provide for measurement and evaluation of pump mechanical characteristics as well as additional measurement and evaluation of pump hydraulic characteristics. These activities are performed to determine pump operational readiness. Also, requirements of the ASME Section XI Testing Program provide for additional measurement and evaluation for determining valve operational readiness. The St. Lucie Unit 1 Inservice Testing Program provides a level of quality in testing of pumps and valves consistent with recent versions of the ASME Section XI Code and, therefore, the removal of certain pump and valve surveillance activities from the Technical Specifications does not involve a reduction in the level of quality in testing of pumps and valves at St. Lucie Unit 1. The IST program will remain in effect as a licensee-controlled document referenced in the Technical Specifications instead of the program itself being a Technical Specification.

The surveillance activity of verifying electrical power from an operable emergency bus has been removed from individual specifications in that the operability requirements for electrical power sources are maintained as required for the Electrical Power System portion of the St. Lucie Unit 1 Technical Specifications.



... ..

... ..

... ..

... ..

... ..

... ..

... ..

The surveillance activity of verifying that the containment sump isolation valves open upon a Recirculation Actuation Signal has been changed from a 31-day surveillance activity to an 18-month surveillance activity. This change is being made to achieve consistency with the Combustion Engineering-Standard Technical Specifications and the St. Lucie Unit 2 Technical Specifications. As required by the St. Lucie Unit 1 Technical Specifications, the manual recirculation actuation signal feature is tested on an 18 month frequency as are the other manual engineered safety features. Also, as required by the ASME Valve Program the containment sump isolation valves are tested on a quarterly basis. A review of the surveillance activity sheets for verifying that the containment sump isolation valves open upon a recirculation actuation signal has been completed for an 18 month period from May 1986 to October, 1987 and no failures were observed. The containment sump isolations valves on St. Lucie Unit 1 are similar to the valves on St. Lucie Unit 2 in that they are 24 inch valves manufactured by Henry Pratt.

An addition to the Turbine Cycle-Safety Valves action statement has been made to show that the provisions of Specification 3.0.4 are not applicable for entry into an OPERATIONAL MODE. This change is being made to achieve consistency with the Combustion Engineering-Standard Technical Specifications. This is consistent with the Technical Specifications, in that Startup and/or Power Operation is allowable with safety valves inoperable within the limitations of the ACTION requirements.

Therefore, based on the above, the changes do not involve a significant reduction in a margin of safety.

In conclusion, we have determined that the amendment request does not (1) involve a significant increase in the probability or consequences of an accident previously evaluated, (2) create the possibility of a new or different kind of accident from any accident previously evaluated, or (3) involve a significant reduction in a margin of safety; and therefore does not involve a significant hazards consideration.

The first part of the report deals with the general situation in the country. It is a very interesting and detailed account of the political and social conditions. The author has done a great deal of research and has gathered a wealth of material. The report is well written and is a valuable contribution to the study of the country.

The second part of the report deals with the economic situation. It is a very interesting and detailed account of the economic conditions. The author has done a great deal of research and has gathered a wealth of material. The report is well written and is a valuable contribution to the study of the country.

The third part of the report deals with the social situation. It is a very interesting and detailed account of the social conditions. The author has done a great deal of research and has gathered a wealth of material. The report is well written and is a valuable contribution to the study of the country.

The fourth part of the report deals with the cultural situation. It is a very interesting and detailed account of the cultural conditions. The author has done a great deal of research and has gathered a wealth of material. The report is well written and is a valuable contribution to the study of the country.