

XN-NF-87-43

CRITICALITY SAFETY ANALYSIS  
ST. LUCIE NEW FUEL STORAGE VAULT  
WITH 4.5% ENRICHED  
14x14 FUEL ASSEMBLIES  
MARCH 1987  
MARCH 1987


RICHLAND, WA 99352

**ADVANCED NUCLEAR FUELS CORPORATION**

AN AFFILIATE OF KRAFTWERK UNION



8801270017 880120  
PDR ADDCK 05000335  
P PDR



CRITICALITY SAFETY ANALYSIS  
ST. LUCIE NEW FUEL STORAGE VAULT  
WITH 4.5% ENRICHED 14x14 FUEL ASSEMBLIES  
MARCH 1987

**CUSTOMER DISCLAIMER**

**IMPORTANT NOTICE REGARDING CONTENTS AND USE OF THIS  
DOCUMENT**

**PLEASE READ CAREFULLY**

Advanced Nuclear Fuels Corporation's warranties and representations concerning the subject matter of this document are those set forth in the Agreement between Advanced Nuclear Fuels Corporation and the Customer pursuant to which this document is issued. Accordingly, except as otherwise expressly provided in such Agreement, neither Advanced Nuclear Fuels Corporation nor any person acting on its behalf makes any warranty or representation, expressed or implied, with respect to the accuracy, completeness, or usefulness of the information contained in this document, or that the use of any information, apparatus, method or process disclosed in this document will not infringe privately owned rights; or assumes any liabilities with respect to the use of any information, apparatus, method or process disclosed in this document.

The information contained herein is for the sole use of Customer.

In order to avoid impairment of rights of Advanced Nuclear Fuels Corporation in patents or inventions which may be included in the information contained in this document, the recipient, by its acceptance of this document, agrees not to publish or make public use (in the patent use of the term) of such information until so authorized in writing by Advanced Nuclear Fuels Corporation or until after six (6) months following termination or expiration of the aforesaid Agreement and any extension thereof, unless otherwise expressly provided in the Agreement. No rights or licenses in or to any patents are implied by the furnishing of this document.

CRITICALITY SAFETY ANALYSIS  
ST. LUCIE NEW FUEL STORAGE VAULT  
WITH 4.5% ENRICHED 14x14 FUEL ASSEMBLIES  
MARCH 1987

TABLE OF CONTENTS

<u>SECTION</u>		<u>Page</u>
1.0	SUMMARY	1
2.0	FUEL PARAMETERS	2
3.0	STORAGE RACK GEOMETRY	4
4.0	CALCULATION METHODS	5
5.0	MODERATION AND SPACING EFFECTS	6
5.1	Removal of Fuel Rods (Fully Flooded)	6
5.2	Optimum Interspersed Moderation Within Racks	7
5.3	Rack Spacing Effects (Bundle-Bundle Spacing)	11
5.4	Fuel Handling Accidents	12
6.0	METHODS VERIFICATION	15
6.1	Reference 2 Experiments	15
6.2	Reference 3 Data	16
6.3	Reference 4 Data	17
6.4	Reference 5 Data	18
6.5	Acceptability Limit	20
7.0	REFERENCES	22



1944

1945

1946

1947

1948

1949

1950

1951

1952

1953

1954

1955

1956

1957

1958

LIST OF TABLES

<u>Table</u>		<u>Page</u>
2.0	Bundle Parameters	2
5.1	Single Full Water Reflected Bundle System Full Water Density, Infinite Length Bundle Moderation Effects (Fuel Rod Removal) (XSDRNPM Results)	7
5.2a	Infinite System Data (Zero Leakage) Interspersed Moderation Effects (XSDRNPM Results)	8
5.2b	Finite System Data (New Fuel Racks) Interspersed Moderation Effects Moderation Between Rack Edge and Walls (Reflector Not Close-Fitted) (KENO-Va Results)	10
5.3	Infinite System Data (Zero Leakage) Fully Flooded State Bundle Spacing Effects (XSDRNPM Results)	12
5.4	Fuel Handling Accidents Fully Flooded, Full Water Reflection (KENO-Va Results)	13
6.1	Benchmark Results Data of Reference 2	16
6.2	Benchmark Data From Reference 3	17
6.3	Reference 4 Data KENO with Hansen-Roach Cross Sections	18
6.4a	Fuel Design Parameters	18
6.4b	Reference 5 Data Low Density Moderation Between Bundles KENO Results	19

LIST OF FIGURES

<u>Figure</u>		<u>Page</u>
2.0	Rod Arrangement	3

CRITICALITY SAFETY ANALYSIS  
ST. LUCIE NEW FUEL STORAGE VAULT  
WITH 4.5% ENRICHED 14x14 FUEL ASSEMBLIES  
MARCH 1987


1.0 SUMMARY

The criticality safety of the new fuel storage vault with 4.5% enriched 14x14 bundles is assessed in accordance with NUREG-0800 and ANSI/ANS-57.3-1983.

The subject system meets the applicable criticality safety criteria subject to the limits and controls given below.

1. Fuel Design - As specified in Section 2.0
2. Bundle-Bundle Spacing Within Racks - 21" nominal (center-center) (14" minimum bundle pitch is acceptable)
3. Loading Arrangement - Rows 5 and 6 of 10x10 array locked out
4. Dissolved boron (greater than or equal to 1720 ppm) in water during fuel movements in normally flooded systems unless 4" (minimum) edge-edge bundle spacing (two bundles) is assured at all credible accident conditions.





## 2.0 FUEL PARAMETERS

The key bundle design parameters used in these calculations are listed in Table 2.0.

The bundle is a 14x14 design with five guide tubes. Since the guide tubes are much larger than the fuel rods, the bundle may be more easily visualized as a 7x7 array of two cell types. Type F is a 2x2 fuel rod array, and type G is a single guide tube. Using this 7x7 description, the bundle is composed as shown in Figure 2.0.

---

Table 2.0  
Bundle Parameters

<u>Parameter</u>	<u>Design Value</u>	<u>Model Value</u>
Enrichment (wt% U-235)	4.50 (max.)	4.50
Pellet Diameter (inch)	0.3700	0.3700
Pellet Density (%TD)	94.0	95.0
Pellet Dish Volume (%)	1.0	0
Active Fuel Length (inch)	136.7	136.7 (min.)
Clad ID/OD (inch)	0.378/0.440	0.378/0.440
Rod Pitch (inch)	0.5800	0.5800
Gd/Boron Content	Variable	None
Fuel Rods per Bundle	176	176
Guide Tube ID/OD (inch)	1.035/1.115	1.035/1.115

---

ROW/COL	1	2	3	4	5	6	7
1	F	F	F	F	F	F	F
2	F	F	F	F	F	F	F
3	F	F	F	F	F	F	F
4	F	F	F	F	F	F	F
5	F	F	F	F	F	F	F
6	F	F	F	F	F	F	F
7	F	F	F	F	F	F	F

---

Key: F = 2x2 Fuel Rod Array  
G = Guide Tube

Figure 2.0 Rod Arrangement



100

100

100

100

100

100

100

100

100

100

### 3.0 STORAGE RACK GEOMETRY

The new fuel vault contains a 10x10 array of storage cells on a 21 inches nominal square pitch. Rows 5 and 6 have been designated as unavailable for fuel bundle storage and are physically locked out of service. Therefore, the racks modeled contained only 80 bundles. The racks were modeled in accordance with Figure 9.1-1 of the FSAR. The racks were modeled with concrete reflection (30 cm thick) at the four walls, the floor, and at the top of the racks (14 feet above the floor). The modeled spacings between the edge of the racks and the walls are 40.5 inches (north), 37.5 inches (south), 31.5 inches (east), and 36.0 inches (west).

All materials of construction were neglected in the model. All neutron absorptions occur in the fuel, the moderator, or the reflector. This is a conservative model.

#### 4.0 CALCULATION METHODS


All computer codes and cross sections are part of the SCALE<sup>(1)</sup> system.

The neutron multiplication factors,  $k_{inf}$  and  $k_{eff}$ , were calculated using KENO-Va, a three dimensional Monte Carlo code, or using XSDRNPM, a one dimensional discrete ordinates transport code.

The 16 group (Hansen-Roach) cross sections were used with resonance corrections by BONAMI/NITAWL.

All codes and cross sections have been extensively benchmarked against critical experiment data.

Evidence of methods verification is presented later in this document.



## 5.0 MODERATION AND SPACING EFFECTS

To assure safety at all credible accident conditions, the following effects were assessed.

1. The effect of removing fuel rods from a fully flooded bundle; i.e., increase the water/fuel volume ratio ( $V_w/V_f$ ) within the bundle.
2. Achieve optimum interspersed moderation within the racks.
3. Effect of bundle-bundle spacing within the racks.
4. Fuel handling accidents resulting in two or more bundles placed closely together at fully flooded and reflected conditions.

### 5.1 Removal of Fuel Rods (Fully Flooded)


Generic models with  $V_w/V_f$  ratios in the range of 2.03 to 4.0 were calculated. The nominal dimensions for the pellet and clad were used with a variable rod pitch to yield the desired  $V_w/V_f$ .

The calculation sequence for each  $V_w/V_f$  case was:

1. Prepare self-shielded cross sections using BONAMI/NITAWL.
2. Perform cell weighting of the unit rod cell using XSDRNPM.
3. Using the cell weighted (homogeneous) cross sections from step 2, model an infinite length bundle surrounded by 30 cm of water. The bundle and the water reflector were modeled as concentric cylindrical regions.

The results are in Table 5.1.





---

Table 5.1  
Single Full Water Reflected Bundle System  
Full Water Density, Infinite Length Bundle  
Moderation Effects (Fuel Rod Removal)  
(XSDRNPM Results)

<u>V<sub>w</sub>/V<sub>f</sub></u>	<u>k<sub>eff</sub></u>
2.03 (nom.)	0.888
2.5	0.903
3.0	0.910
3.5	0.911
4.0	0.907

---

The optimum V<sub>w</sub>/V<sub>f</sub> is near 3.5. Since the bundle is relatively small (7.98 inch surface-surface or 8.12 inch across homogeneous cells), the neutron leakage is adequate to maintain the fully flooded k<sub>eff</sub> well below 0.95 with any number of removed fuel rods.

## 5.2 Optimum Interspersed Moderation Within Racks

For these cases, the nominal bundle design and the nominal rack design parameters were modeled.

The water within and between the bundles in the rack was modeled as uniform in the range zero to 100 volume percent. Infinite and finite systems were modeled. The infinite system results were used to estimate the optimum interspersed water density. The finite system was then modeled with water densities near the estimated optimum. The calculation sequence for each water density was:

1. Prepare self-shielded cross sections using BONAMI/NITAWL.
2. Perform cell weighting of the unit rod cell using XSDRNPM.
3. Model an infinite array of infinite length bundles on 21 inch centers. As described before, the fuel and moderation were concentric cylindrical regions.


The  $k_{inf}$  results for the rod lattice and for the bundle lattice (21 inch centers) are listed in Table 5.2a.

---

Table 5.2a  
Infinite System Data (Zero Leakage)  
Interspersed Moderation Effects  
(XSDRNPM Results)

<u>Water Density (Vol%)</u>	<u><math>k_{inf}</math> (Rod Lattice)</u>	<u><math>k_{inf}</math> (Bundle Lattice) (21" Centers)</u>
0 (normal)	0.7534	0.7534
1	0.7784	1.0480
3	0.8204	1.3344
5	0.8617	1.3874
8	0.9240	1.3294
10	0.9640	1.2563
12	1.0020	1.1749
15	1.0546	1.0543
20	1.1300	0.8858
40	1.3172	0.6548
60	1.4080	0.7131
80	1.4571	0.8063
100	1.4838	0.8901


---



The above data indicate that an infinite array of infinite length bundles is adequately subcritical at all interspersed water densities greater than 20 percent and also with zero interspersed moderation. Although the optimum water density for an infinite system is near 5 percent, leakage effects in a finite system will typically result in higher optimum water densities and lower  $k_{eff}$ 's.

The actual finite system was explicitly modeled using KENO-Va. The parameters modeled for the fuel and for the racks were given in Sections 2.0 and 3.0.

The results for low density interspersed moderation conditions are listed in Table 5.2b.



---

Table 5.2b  
Finite System Data (New Fuel Racks)  
Interspersed Moderation Effects  
Moderation Between Rack Edge and Walls (Reflector Not Close-Fitted)  
(KENO-Va Results)

<u>Water Density (Vol%)</u>	<u>k<sub>eff</sub></u>
5	0.903 ± 0.0041
8	0.963 ± 0.0047
10	0.961 ± 0.0049
12	0.942 ± 0.0044
20	0.800 ± 0.0045

Interpolated Data Below (Polynomial Regression)

5.0	0.9031
5.5	0.9187
6.0	0.9318
6.5	0.9426
7.0	0.9511
7.5	0.9576
8.0	0.9620
8.5	0.9646
9.0	0.9655
9.5	0.9648
10.0	0.9626
10.5	0.9590
11.0	0.9542
11.5	0.9483
12.0	0.9414
13.0	0.9253
14.0	0.9067
15.0	0.8866
16.0	0.8662
17.0	0.8463
18.0	0.8280
19.0	0.8122
20.0	0.8000

---



100-100000

100-100000

100-100000

100-100000

100-100000

100-100000

100-100000

100-100000



The KENO calculations (finite system) were performed using 83 (typical) generations of 300 neutrons. To establish the 95 percent upper limit on the Monte Carlo calculations, the appropriate one-sided "Student"  $t$  (80 degrees of freedom) is 1.66. Using the highest interpolated  $k_{eff}$  (9 percent water) and the highest KENO standard deviation (0.0049), the 95 percent upper limit is:


$$k_{eff} (95\% UL) = 0.9655 + 1.66 * 0.0049 = 0.9736$$

Since the  $k_{eff}$  is less than 0.98 with 95 percent confidence, the system is demonstrated to be adequately subcritical at optimum moderation.

### 5.3 Rack Spacing Effects (Bundle-Bundle Spacing)

The peak  $k_{eff}$  with low density interspersed moderation will change little if any with credible changes in bundle-bundle spacings. However, the optimum interspersed water density will tend to increase with decreasing bundle-bundle spacings.

The effect of bundle-bundle spacings on the reactivity of an infinite array of flooded infinite length bundles was assessed as described in Section 5.2 (infinite system) except that the bundle-bundle spacing was decreased and also the water density was fixed at 100 percent. The results are in Table 5.3.



-----  
 Table 5.3  
 Infinite System Data (Zero Leakage)  
 Fully Flooded State  
 Bundle Spacing Effects  
 (XSDRNPM Results)

<u>Bundle Spacing (Center-Center) (inches)</u>	<u>Bundle Spacing (Edge-Edge) (inches)</u>	<u><math>k_{inf}</math></u>
21 (nominal)	12.88	0.890
18	9.88	0.894
14	5.88	0.930
12	3.88	1.024
8.12	0.00	1.484


-----

An explicit KENO-Va model of the 14 inch center-center spacing condition resulted in a  $k_{inf}$  of  $0.938 \pm 0.0060$ . Thus, the KENO and XSDRNPM results are statistically identical.

An infinite array of flooded infinite length bundles is adequately subcritical ( $k_{eff}$  less than 0.95) at all bundle pitches greater than 14 inches. No credible combination of dimensional tolerances, eccentric positioning, or accident condition would result in a pitch approaching 14 inches. Therefore, the flooded state is acceptable.

#### 5.4 Fuel Handling Accidents

As shown in Table 5.2a, an infinite array of edge-edge bundles (infinite rod lattice) is adequately subcritical for all interspersed water densities less than 10 percent.



It was also shown that an infinite array of flooded bundles is adequately sub-critical if the bundle pitch is at least 14 inches.

Close placement of two flooded bundles was also explicitly modeled using KENO-Va. This covers potential accidents at the Fuel Inspection Elevator, U-pender and the Fuel Transfer Tube, as well as generic cases such as dropping a bundle or moving a bundle next to another flooded bundle.

Finite bundle arrays with various spacings were modeled. In each case, the array was reflected by 30 cm of full density water. The KENO Va results are in Table 5.4.


---

Table 5.4  
Fuel Handling Accidents  
Fully Flooded, Full Water Reflection  
(KENO-Va Results)

<u>Bundle Array</u>	<u>Bundle-Bundle Spacing (Inches Edge-Edge)</u>	<u>k<sub>eff</sub></u>
1x1		0.897 + 0.0057
2x1	0	1.016 + 0.0061
2x1	2.0	0.992 + 0.0056
2x1	4.0	0.920 + 0.0053


---

It is seen that two closely placed bundles may become critical if flooded and reflected. About four inches of water between two adjacent bundles is adequate to assure safety.



Full flooding and close placement of bundles represent two independent and improbable accident conditions in the new fuel vault. Since either condition alone has been shown to be acceptable, the new fuel vault is adequately subcritical.

In other systems which are normally flooded and which may accidentally allow close placement of bundles, additional controls are required. Assurance of dissolved boron (1720 ppm minimum) in these locations during fuel movement will lower the maximum credible  $k_{eff}$  by about 0.20, resulting in reactivities far below the 0.95 limit.





## 6.0 METHODS VERIFICATION

Supplemental benchmarking of the methods employed in this analysis were performed. Critical experiments documented in references 2-5 were modeled using methods identical to those of this report. The critical experiments include bundle arrays with variable bundle-bundle spacings, and with and without neutron absorber rods/plates between the bundles.

### 6.1 Reference 2 Experiments

Reference 2 experiments include a 3x3 array of 14x14 bundles. The rods contain 2.46 percent enriched  $UO_2$  pellets on a 1.636 cm square pitch. Five of the experiments were selected for this benchmark. These cases contain little, if any, dissolved boron in the moderator (water), and include the effects of neutron absorbers. The other cases, not selected for benchmarking, include effects such as dissolved boron content and slight temperature changes.

The critical moderator height was determined in these experiments. The reported  $k_{eff}$ 's were normalized to a constant moderator height for each of the two classes of experiments. Therefore, the observed  $k_{eff}$ 's are not all unity. The data are in Table 6.1.

-----  
Table 6.1  
Benchmark Results  
Data of Reference 2

<u>Case Number</u>	<u>k<sub>eff</sub> (Observed)</u>	<u>k<sub>eff</sub> (Calculated)</u>	<u>k<sub>eff</sub> (95% UL)</u>
2321	1.0030 ± 0.0009	0.997 ± 0.005	1.007
2317	1.0083 ± 0.0012	1.004 ± 0.004	1.012
2378	1.0000 ± 0.0010	1.009 ± 0.005	1.019
2396	1.0001 ± 0.0019	1.004 ± 0.004	1.012
2420	0.9997 ± 0.0015	1.002 ± 0.004	1.010
Average	1.0022 ± 0.0016	1.0032 ± 0.0019	1.0120

-----

The 95 percent upper limit on the calculated k<sub>eff</sub>, which is the parameter used in judging acceptability, exceeds the observed k<sub>eff</sub> in every case. The average of the individual biases (calculated minus observed) is 0.00098 ± 0.0028.

## 6.2 Reference 3 Data

Reference 3 includes data on experiments using 2.35 and 4.31 percent enriched UO<sub>2</sub> rods in a 1x3 bundle array. Only the 4.31 percent enriched cases were selected for this benchmark. These cases were either 8x13 bundles (2.54 cm rod pitch) or 16x12 bundles (1.892 cm pitch). The critical separation between the bundles was determined with various neutron absorbers between the bundles and with various spacings to a thick steel wall.

In these cases, the observed k<sub>eff</sub>'s are all 1.000.




Table 6.2  
Benchmark Data From Reference 3

<u>Rod Pitch (cm)</u>	<u>Distance to Steel Wall (cm)</u>	<u>Neutron Absorbers</u>	<u>k<sub>eff</sub></u>
2.54	0		0.999 ± 0.006
2.54	6.6		1.001 ± 0.005
2.54	26.16		1.012 ± 0.005
1.892	6.6		0.999 ± 0.004
1.892	13.21		0.998 ± 0.004
1.892	54.05		1.008 ± 0.005
1.892	1.96	Boroflex	1.003 ± 0.004
1.892	1.96	Boral	0.997 ± 0.005
Average			1.0021

The average bias is  $0.0021 \pm 0.0019$ . The 95 percent upper limit on the KENO  $k_{eff}$  exceeds the observed value in each case.

### 6.3 Reference 4 Data

A single, undermoderated 22x22 array of 4.742 percent enriched rods with various patterns of 25 "water holes" (removed fuel rods) was tested to determine the critical moderator height. Since the bundle modeled contains guide tubes, the reference 4 data are useful to verify the methods, particularly the homogeneous representation of the bundle.

Three cases were calculated using KENO with explicit modeling and homogeneous modeling.

-----  
Table 6.3  
Reference 4 Data  
KENO with Hansen-Roach Cross Sections

<u>Case</u>	<u>k<sub>eff</sub> (Explicit)</u>	<u>k<sub>eff</sub> (Homogeneous)</u>
1670	0.995 ± 0.0054	1.002 ± 0.0055
1674	0.996 ± 0.0054	1.001 ± 0.0054
1680	1.000 ± 0.0051	1.005 ± 0.0063
Average	0.997	1.0027

-----

The bias is  $-0.00017 \pm 0.0015$  for all six cases.

The homogeneous model results appear to be about 0.005 higher than the explicit model results, but this bias is not significant. All results agree very well with the observed  $k_{eff}$  of unity.


#### 6.4 Reference 5 Data

The rod design here is identical to that of the reference 4 data:

-----  
Table 6.4a  
Fuel Design Parameters

Rod Diameter (cm)	0.79
Enrichment (% U-235)	4.742
UO <sub>2</sub> Density (%TD)	94.71
Fuel Length (cm)	90
Clad	Aluminum
Clad ID/OD (cm)	0.82/0.94

-----



Four flooded 18x18 bundles were placed in a 2x2 array spaced by various thicknesses of various between-bundle moderators. These moderators included air, water, expanded polystyrene, polyethylene powder (low density), and polyethylene balls (higher density).

These experiments were modeled using the SCALE system as documented in reference 6. Selected cases were modeled here for comparison.

These experiments are useful in validating the optimum moderation calculations. Experimental data with low density moderation within and between bundles are not available.

The three cases selected had a 10 cm spacing between bundles. This spacing was filled with either air, polystyrene, or polyethylene powder. The corresponding hydrogen densities were 0, 0.0022, and 0.0464 gm/cc, respectively. The water densities to yield these H densities are 0, 1.97 and 41.47 percent, respectively.

-----  
Table 6.4b  
Reference 5 Data  
Low Density Moderation Between Bundles  
KENO Results

H Density (gm/cc)	$k_{eff}$ (16 Group)	$k_{eff}$ (27 Group)
0	1.012 $\pm$ 0.0046	0.985 $\pm$ 0.0053
0.0022	1.012 $\pm$ 0.0059	
0.0464	1.036 $\pm$ 0.0045	1.024 $\pm$ 0.0050

-----

For the three 16-group cases, the bias is 0.020  $\pm$  0.008.

The results presented, agree well with the complete result set of reference 6. The 16 group (Hansen-Roach) results appear to be slightly conservative.

These results indicate that the low density moderation results are accurate or perhaps slightly conservative.

### 6.5 Acceptability Limit

Pooling data from references 2, 3 and 4 (flooded cases), the average and standard deviation of the systematic bias are 0.0011 and 0.0011, respectively. Clearly, there is no significant systematic bias. Based on the limited replication of the low moderation cases (reference 5), and the complete results in reference 6, the bias at this condition will be conservatively set equal to that for the flooded cases.

Using the criteria of ANSI/ANS-8.17-1984 (and other similar documents), the maximum allowable, calculated  $k_{eff}$  is established as follows.

$$\text{LIMIT} = A - B - C - D$$

The terms are defined below.

- LIMIT: Maximum acceptable  $k_{eff}$ .
- A: Mean  $k_{eff}$  from appropriate benchmarks. The assigned value is 1.0011.
- B: An allowance for uncertainties in parameter A. The assigned value is 0.0011.
- C: An allowance for uncertainty in  $k_{eff}$  calculations. This allowance is variable, and is included in the final  $k_{eff}$  result; i.e., the 95 percent upper limit statement. Therefore, the acceptability limit is not adjusted, and C is set to zero.



D: An arbitrary margin to ensure subcriticality. This is set to 0.05, except for optimum moderation conditions where the value is 0.02.

Therefore, the acceptability limit is 0.95, or 0.98 (optimum moderation).

It should be noted that allowances B and C are often pooled before applying a confidence level multiplier (usually about 2.0).

In this format:

$$\text{LIMIT} = A - D - K * B + C$$

where K is the confidence level multiplier.

Since the KENO standard deviation is typically 0.003-0.006, the sum of squares is dominated by the KENO variance. The limits calculated by the two methods are very close. The ANS/ANSI format is more conservative by 0-0.0004 for typical KENO standard deviations.

7.0 REFERENCES

- (1) "SCALE: A Modular Code System for Performing Standardized Computer Analyses for Licensing Evaluation," NUREG/CR-0200.
- (2) M. N. Baldwin, et. al., "Critical Experiments Supporting Close Proximity Water Storage of Power Reactor Fuel," BAW-1484-7, July 1979.
- (3) S. R. Bierman and E. D. Clayton, "Criticality Experiments with Subcritical Clusters of 2.35 wt% and 4.31 wt% U-235 Enriched UO<sub>2</sub> Rods in Water with Steel Reflecting Walls," NUREG/CR-1784 (PNL-3602), January 1981.
- (4) J. C. Manaranche, et. al., "Critical Experiments with Lattices of 4.75% wt% U-235 Enriched UO<sub>2</sub> Rods in Water," ANS Trans, Vol. 28, pp. 302-303.
- (5) J. C. Manaranche, et. al., "Dissolution and Storage Experimental Program with U(4.75)O<sub>2</sub> Rods," ANS Trans, Vol. 33, pp. 362-364.
- (6) A. M. Hathout, et. al., "SCALE System Cross Section Validation for Criticality Safety Analysis," ANS Trans, Vol. 35, pp. 281-283.

