



NOTES

- * - SUPPLIED BY EQUIPMENT MANUFACTURERS
- A, B, C, OR ABC ENCLOSED IN A SQUARE IDENTIFIES LOOP DESIGNATION OF CLASS PIPING SYSTEM
- IDENTIFIES INTERFACE OF QUALITY GROUPS A, B, C & D COMPONENTS
- QUALITY GROUPS "A", "B", & "C" COMPONENTS ARE DESIGNED AS SEISMIC CLASS I. QUALITY GROUP "D" COMPONENTS ARE NOT DESIGNED AS SEISMIC CLASS I UNLESS OTHERWISE NOTED.

REFERENCE DRAWINGS

LIST OF DRAWINGS

2998-A-146
2998-A-051
2998-B-052
2998-B-057A
2998-B-251
2998-B-270C
2998-G-078
SH-100
SH-121
SH-130
SH-140
SH-160
SH-162

NUCLEAR SAFETY RELATED IN PART ONLY

RECEIVED
SEP 08 1987

DOCUMENT CONTROL INFORMATION ONLY

THE DESIGN INFORMATION FOR THE CHARGES SHOWN IN THIS REVISION HAS BEEN ENGINEERED BY FLORIDA POWER & LIGHT COMPANY.

THIS DOCUMENT IS THE PROPERTY OF EBASCO SERVICES INCORPORATED. ITS USE IS EXPRESSLY RESTRICTED BY THE TERMS OF THE CONTRACT, DATED AS OF SEPTEMBER 1, 1975 BETWEEN EBASCO SERVICES INCORPORATED AND FLORIDA POWER & LIGHT COMPANY.

FLORIDA POWER & LIGHT COMPANY
ST LUCIE PLANT
1983 - 890 MW EXTENSION - UNIT 2
FLOW DIAGRAM
CONTAINMENT SPRAY AND
REFUELING WATER SYSTEMS

EBASCO SERVICES INCORPORATED

8805190100

NO.	DATE	REVISION	BY	CHK	APPROVED
18	9/10/87	GEN. DEL. (A) B. B. D. D. F. L. G. S. NOT INSTALLED BY PCIM 162-283 REV. (D) 2-74-83 (A) (H) (K) (M) (S) INST. REF.	NA	MM	MM

SCALE NONE APPROVED DATE 9/10/87
DIV. MECH. DR. AND/OR CH. NUMBER 2998-G-088