

# ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8805230126      DOC. DATE: 88/05/16      NOTARIZED: NO      DOCKET #  
 FACIL: 50-335 St. Lucie Plant, Unit 1, Florida Power & Light Co.      05000335  
       50-389 St. Lucie Plant, Unit 2, Florida Power & Light Co.      05000389

AUTH. NAME      AUTHOR AFFILIATION  
 CONWAY, W.F.      Florida Power & Light Co.  
 RECIP. NAME      RECIPIENT AFFILIATION  
                          Document Control Branch (Document Control Desk)

SUBJECT: Forwards util response to EPA notice of violation of NPDES Permit FL 0002208.


DISTRIBUTION CODE: IE23D      COPIES RECEIVED: LTR 1 ENCL 1      SIZE: 2  
 TITLE: Environmental Event Report (per Tech Specs)

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	
	PD2-2 LA	1 0	PD2-2 PD	1 1	/
	TOURIGNY, E	1 1			A
INTERNAL:	ACRS	5 5	AEOD/DOA	1 1	D
	AEOD/DSP/TPAB	1 1	AEOD/PTB	1 1	D
	NRR/DEST/ADE 8H	1 1	NRR/DOEA/EAB 11	1 1	D
	NRR/DREP/EPB 10	1 1	NRR/DREP/RPB 10	1 1	S
	NRR/PMAS/ILRB12	1 1	NRR/PMAS/PTSB12	1 1	
	<del>NUDACS-ABSTRACT</del>	1 1	OGC 15-B-18	1 1	
	<u>REG FILE</u>	1 1	RGN2 FILE 01	1 1	
	RGN2/DRSS/EPRPB	1 1			
EXTERNAL:	LPDR	1 1	NRC PDR	1 1	
	NSIC	1 1			

R  
I  
D  
S  
/  
A  
D  
D  
S

TOTAL NUMBER OF COPIES REQUIRED: LTTR 25 ENCL 24



MAY 16 1988

L-88-218

U. S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, D. C. 20555

Gentlemen:

Re: St. Lucie Units 1 and 2  
Docket Nos. 50-335 and 50-389  
Environmental Protection Plan Report

In accordance with Section 3.2.1 of the St. Lucie Units 1 and 2 Environmental Protection Plans, attached is one copy of a Florida Power & Light Company letter to the U. S. Environmental Protection Agency, Region IV. The letter responds to a Notice of Violation of NPDES Permit FL0002208.

Very truly yours,

W. F. Conway  
Senior Vice President - Nuclear

WFC/GRM/gp

Attachment

cc: Dr. J. Nelson Grace, Regional Administrator,  
Region II, USNRC  
Senior Resident Inspector, USNRC, St. Lucie Plant

GRMA.EPP

IE213  
11

8805230126 880516  
PDR ADOCK 05000335  
P DCD

an FPL Group company



CERTIFIED MAIL  
RETURN RECEIPT REQUESTED

April 12, 1988

Mr. Peter T. McGarry, PE, Chief  
Florida/Mississippi Unit  
Compliance Section  
Facilities Performance Branch  
Water Management Division  
US Environmental Protection Agency  
Region IV  
Atlanta, Georgia 30365

RE: Notice of Violation  
NPDES Permit No. FLO002208  
St. Lucie Power Plant

Dear Mr. McGarry:

On December 3, 1987, Florida Power and Light Company, FPL, received a Notice of Violation for the above-referenced permit. The Notice of Violation identified two issues. The first issue, concerning acid in the sewer system, was resolved by a directive sent to supervisors at the Plant telling them to not place acidic solutions into the sewer system.

The second issue concerned FPL's failure to report a temperature exceedence within five days. The plant has directed the departments who have responsibility for reading and recording the data that any exceedence must be reported immediately to the Chemistry Department. The Chemistry Department will in turn notify the Environmental Affairs Department, who has responsibility for notifying EPA.

We believe that this directive will avoid delays from occurring in the future. Please feel free to call Winifred Perkins at (305)694-3645 if you have any questions concerning this matter.

Sincerely,

T. R. Fair, Manager  
Environmental Permitting and Programs

TRF:eh:3