

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-335
 UNIT NAME St. Lucie Unit 1
 DATE August 19, 1988
 COMPLETED BY S. D. Ferrell
 TELEPHONE (407) 694-4433

REPORT MONTH July, 1988

8808290114 880822
 PDR ADDOCK 05000335
 PDIC

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Licensee Event Report #	System Code ⁴	Component Code ⁵	Cause & Corrective Action to Prevent Recurrence
02	880630	F	3.9	A	4	335/88-04	HH	RELAY	Unit #1 was operating at 100% power when the reactor tripped on high-pressurizer pressure. The trip was caused by a spurious actuation of the current balance relay associated with the 1B condensate pump. The relay was replaced. Return to power operation then commenced.
03	880701	F	3.7	A	2		HH	VALVEX	Unit #1 reached approximately 15% power when it was manually shutdown to repair a leaking safety relief valve in the feedwater filter system. Following repairs the unit was returned to full power operation.
04	880711	S	503.8	C	1		RC	FUELXX	Unit #1 was shutdown for refueling and scheduled maintenance.

1
 F Forced
 S Scheduled

2
 Reason
 A - Equipment Failure (Explain)
 B - Maintenance or Test
 C - Refueling
 D - Regulatory Restriction
 E - Operator Training & License Examination
 F - Administrative
 G - Operational Error (Explain)
 H - Other (Explain)

3
 Method
 1 - Manual
 2 - Manual Scram
 3 - Automatic Scram
 4 - Continued
 5 - Load Reduction
 9 - Other (Explain)

4
 Exhibit G-Instructions
 for Preparation of Data
 Entry Sheets Licensee
 Event Report (LER) File
 (NUREG-0161)

5
 Exhibit 1 - Same Source

1224
 111

