

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8903010115 DOC. DATE: 89/02/21 NOTARIZED: YES DOCKET #
 FACIL: 50-335 St. Lucie Plant, Unit 1, Florida Power & Light Co. 05000335
 50-389 St. Lucie Plant, Unit 2, Florida Power & Light Co. 05000389

AUTH. NAME AUTHOR AFFILIATION
 CONWAY, W.F. Florida Power & Light Co.
 RECIPIENT NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Application for amends to Licenses DPR-67 & NPF-16, changing Tech Specs, per Generic Ltr 85-19.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 37 18
 TITLE: OR Submittal: General Distribution

NOTES:

	RECIPIENT		COPIES			RECIPIENT		COPIES		
	ID CODE/NAME		LTTR	ENCL		ID CODE/NAME		LTTR	ENCL	
	PD2-2 LA		1	0		PD2-2 PD		2	2	
	NORRIS, J		1	1						
INTERNAL:	ACRS		6	6	ARM/DAF/LFMB		1	0		
	NRR/DEST/ADS 7E		1	1	NRR/DEST/CEB 8H		1	1		
	NRR/DEST/ESB 8D		1	1	NRR/DEST/MTB 9H		1	1		
	NRR/DEST/RSB 8E		1	1	NRR/DEST/SICB		1	1		
	NRR/DOEA/TSB 11		1	1	NUDOCS-ABSTRACT		1	1		
	OGC/HDS2		1	0	REG FILE 01		1	1		
	RES/DSIR/EIB		1	1						
EXTERNAL:	LPDR		1	1	NRC PDR		1	1		
	NSIC		1	1						


NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 25 ENCL 22

R
I
D
S
/
A
D
D
S

R
I
D
S
/
A
D
D
S





FPL

P.O. Box 14000, Juno Beach, FL 33408-0420

FEBRUARY 21 1989

L-89-53
10 CFR 50.90

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

Gentlemen:

Re: St. Lucie Units 1 and 2
Docket Nos. 50-335 and 50-389
Proposed License Amendments
Generic Letter 85-19
Iodine Reporting Requirements

In accordance with 10 CFR 50.90, Florida Power & Light Company (FPL) submits herewith a request to amend Facility Operating Licenses DPR-67 and NPF-16 for St. Lucie Units 1 and 2, respectively.

These amendments are submitted to implement the NRC recommendations of Generic Letter (GL) 85-19, "Reporting Requirements on Primary Coolant Iodine Spikes". In GL 85-19, the staff determined that the primary coolant iodine spike reporting requirement could be reduced from a short-term report (e.g., Special Report or Licensee Event Report) to an item which is included in the Annual Report. Additionally, the staff determined that the existing requirements to shutdown a plant if coolant iodine activity limits are exceeded for 800 hours in a 12-month period can be eliminated. The St. Lucie Unit 1 and 2 Technical Specifications 3.4.8, and Bases for these Technical Specifications, are proposed to be revised.

Attachments 1 and 2 to this letter include the proposed Units 1 and 2 Technical Specification changes, respectively. Attachment 3 is the Safety Analysis in support of the proposed amendment. Attachment 4 is a "Determination of No Significant Hazards Consideration".

The proposed amendment has been reviewed by the St. Lucie Facility Review Group and the Florida Power & Light Company Nuclear Review Board.

GL85-19.EJW

3903010115 890221
PDR ADOCK 05000335
P PDC

an FPL Group company

Aool
1/11

1301

1302

1303

1304

1305

1306

1307

1308

1309

1310

1311

1312

1313

1314

1315

1316

1317

1318

1319

1320

1321


U. S. Nuclear Regulatory Commission
L-89-53
Page two

In accordance with 10 CFR 50.91(b)(1), a copy of the proposed amendment is being forwarded to the State Designee for the State of Florida.

In accordance with 10 CFR 170.12(c), FPL Check No. 9820 is attached as remittance for the license amendment application fee.

Please contact us if there are any questions about this submittal.

Very truly yours,


W. F. Conway
Senior Vice President - Nuclear

WFC/EJW/cm

Attachments

cc: Malcolm L. Ernst, Acting Regional Administrator,
Region II, USNRC
Senior Resident Inspector, USNRC, St. Lucie Plant
Mr. Jacob Nash, Florida Department of Health and
Rehabilitative Services

GL85-19.EJW

STATE OF TEXAS
COUNTY OF [illegible]
[illegible]
[illegible]