

# ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8904170297      DOC. DATE: 89/04/04      NOTARIZED: YES      DOCKET #  
 FACIL: 50-335 St. Lucie Plant, Unit 1, Florida Power & Light Co.      05000335  
 50-389 St. Lucie Plant, Unit 2, Florida Power & Light Co.      05000389

AUTH. NAME      AUTHOR AFFILIATION  
 CONWAY, W.F.      Florida Power & Light Co.  
 RECIPIENT NAME      RECIPIENT AFFILIATION  
                          Document Control Branch (Document Control Desk)

SUBJECT: Advises that visual insp of pressurizer surge line for Unit 2 complete, per Bulletin 88-011.

DISTRIBUTION CODE: IE30D      COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 2  
 TITLE: Bulletin 88-11 Pressurizer Surge Line Thermal Stratification

NOTES:

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		LTR	ENCL		ID CODE/NAME		LTR	ENCL
	PD2-2 LA		1	0		PD2-2 PD		1	1
	NORRIS, J		1	1				1	1
INTERNAL:	AEOD/DOA		1	1		AEOD/DSP/TPAB		1	1
	NRR CHAN, T		1	1		NRR HOU, S		1	1
	NRR KADAMBI, P		1	1		NRR KUO, P		1	1
	NRR/DEST/ADE 8H		1	1		NRR/DEST/ADS 7E		1	1
	NRR/DEST/MEB 9H		1	1		NRR/DOEA/EAB 11		1	1
	NRR/DOEA/GCB 11		1	1		NRR/DREP/EPB 10		1	1
	NRR/PMAS/ILRB12		1	1		NUDOCS-ABSTRACT		1	1
	<del>REG FILE</del> 02		1	1		RES/DSIR/EIB		1	1
	RGN2 FILE 01		1	1				1	1
EXTERNAL:	LPDR		1	1		NRC PDR		1	1
	NSIC		1	1					

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,  
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION  
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 23 ENCL 2

R  
I  
D  
S  
/  
A  
D  
D  
S  
  
R  
I  
D  
S  
/  
A  
D  
D  
S



FPL

APRIL 4 1989

L-89-91  
10 CFR 50.54(f)

U. S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, D. C. 20555

Gentlemen:

Re: St. Lucie Unit Nos. 1 and 2  
Docket Nos. 50-335 and 50-389  
NRC Bulletin 88-11  
Pressurizer Surge Line Thermal Stratification

Per NRC Bulletin 88-11, Florida Power & Light Company (FPL) was requested to conduct a visual inspection (ASME, Section XI, VT-3) of the St. Lucie Plant pressurizer surge lines at the first available cold shutdown which exceeds seven days (Action Requested 1.a.). Additionally, it was requested in the bulletin that FPL report any discernable distress and damage observed during the visual inspection of Action Requested 1.a., along with corrective actions taken or plans and schedules for repair before restart of the units.

St. Lucie Unit 2 was shutdown in January, 1989 for a refueling outage. The visual inspection of the pressurizer surge line has been completed at St. Lucie Unit 2 and no gross discernable distress or structural damage was identified in the line.

St. Lucie Unit 1 will complete the visual inspection as required by the subject bulletin at the first available planned cold shutdown which exceeds 7 days.

Please contact us if there are any questions.

Very truly yours,

W. F. Conway  
Senior Vice President - Nuclear

WFC/MSD/cm

cc: Stewart D. Ebnetter, Regional Administrator, Region II, USNRC  
Senior Resident Inspector, USNRC, St. Lucie Plant

MSDPSLTS

8904170297 890404  
PDR ADOCK 05000335  
PDC

IE 30  
1/0

STATE OF FLORIDA            )  
  ) ss.  
COUNTY OF PALM BEACH )

W. F. Conway being first duly sworn, deposes and says:

That he is Senior Vice President- Nuclear of Florida Power & Light Company, the Licensee herein;

That he has executed the foregoing document; that the statements made in this document are true and correct to the best of his knowledge, information, and belief, and that he is authorized to execute the document on behalf of said Licensee.

W. F. Conway  
W. F. Conway

Subscribed and sworn to before me this

4 day of April, 1989.

Roberta S. Economy

NOTARY PUBLIC, in and for the County of Palm Beach, State of Florida

My Commission expires: Notary Public, State of Florida  
My Commission Expires June 1, 1989  
Bonded State Law Firm - Insurance, Etc.