

# ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8807250040      DOC. DATE: 88/07/18      NOTARIZED: NO      DOCKET #  
 FACIL: 50-336 Millstone Nuclear Power Station, Unit 2, Northeast Nu      05000336  
       50-423 Millstone Nuclear Power Station, Unit 3, Northeast Nu      05000423  
 AUTH. NAME                      AUTHOR AFFILIATION  
 MROCZKA, E.J.                    Northeast Utilities  
 RECIPIENT NAME                  RECIPIENT AFFILIATION  
    Document Control Branch (Document Control Desk)

SUBJECT: Forwards info re ECCS single-failure analysis.

DISTRIBUTION CODE: A001D      COPIES RECEIVED: LTR 1 ENCL 1      SIZE: 3  
 TITLE: OR Submittal: General Distribution

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR	ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR	ENCL
	PD1-4 LA	1	0	PD1-4 PD	5	5
	JAFFE, D	1	1	FERGUSON, R	1	1
INTERNAL:	ACRS	6	6	ARM/DAF/LFMB	1	0
	NRR/DEST/ADS 7E	1	1	NRR/DEST/CEB 8H	1	1
	NRR/DEST/ESB 8D	1	1	NRR/DEST/MTB 9H	1	1
	NRR/DEST/RSB 8E	1	1	NRR/DOEA/TSB 11	1	1
	NRR/PMAS/ILRB12	1	1	NUDOCS-ABSTRACT	1	1
	OGC 15-B-18	1	0	<u>REG FILE</u> 01	1	1
	RES/DSIR/EIB	1	1			
EXTERNAL:	LPDR	1	1	NRC PDR	1	1
	NSIC	1	1			

TOTAL NUMBER OF COPIES REQUIRED: LTTR 29 ENCL 26

R  
I  
D  
S  
/  
A  
D  
S  
  
R  
I  
D  
S  
/  
A  
D  
D  
S

# NORTHEAST UTILITIES



THE CONNECTICUT LIGHT AND POWER COMPANY  
WESTERN MASSACHUSETTS ELECTRIC COMPANY  
HOLYOKE WATER POWER COMPANY  
NORTHEAST UTILITIES SERVICE COMPANY  
NORTHEAST NUCLEAR ENERGY COMPANY

General Offices • Selden Street, Berlin, Connecticut

P.O. BOX 270  
HARTFORD, CONNECTICUT 06141-0270  
(203) 665-5000

July 18, 1988

Docket Nos. 50-336  
50-423  
B12969

U.S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, DC 20555

Reference: (1) E. J. Mroczka letter to U.S. Nuclear Regulatory Commission, Information Regarding ECCS Single Failure Analysis, dated May 12, 1988.

Gentlemen:

Millstone Nuclear Power Station  
Unit Nos. 2 and 3  
Information Regarding ECCS Single-Failure Analysis

As a result of valve failure (CH-MOV-257, located between the volume control tank [VCT] and the charging pump suction header) identified during in-service testing on May 2, 1988, Connecticut Yankee Atomic Power Company (CYAPCO) evaluated the cause and potential implication of such a failure and noted a potential single-failure vulnerability in one portion of the Haddam Neck Plant emergency core cooling system (ECCS), specifically the charging system. In Reference (1), CYAPCO provided the NRC with information on the single-failure analysis of the Haddam Neck Plant ECCS.

As a prudent measure, Northeast Nuclear Energy Company (NNECO) conducted a review of the above information for applicability to Northeast Utilities' other nuclear plants (PWRs only), namely, Millstone Unit Nos. 2 and 3. The purpose of this letter is to forward to the Staff the results of our review.

Millstone Unit No. 2

Emergency core cooling at Millstone Unit No. 2 is accomplished using high-pressure safety injection (HPSI), low-pressure safety injection (LPSI), containment spray (CS), shutdown cooling heat exchangers, SI accumulators, charging pumps, and associated piping instrumentation and valves. Millstone Unit No. 2 has three positive displacement charging pumps rated at 44 gpm per pump. The "A" and "C" pumps are connected to emergency electrical bus 22E and

8807250040 880718  
PDR ADOCK 05000336  
P FDC

Appl  
1/1



1944  
1945  
1946  
1947  
1948  
1949  
1950  
1951  
1952  
1953  
1954  
1955  
1956  
1957  
1958  
1959  
1960  
1961  
1962  
1963  
1964  
1965  
1966  
1967  
1968  
1969  
1970  
1971  
1972  
1973  
1974  
1975  
1976  
1977  
1978  
1979  
1980  
1981  
1982  
1983  
1984  
1985  
1986  
1987  
1988  
1989  
1990  
1991  
1992  
1993  
1994  
1995  
1996  
1997  
1998  
1999  
2000  
2001  
2002  
2003  
2004  
2005  
2006  
2007  
2008  
2009  
2010  
2011  
2012  
2013  
2014  
2015  
2016  
2017  
2018  
2019  
2020  
2021  
2022  
2023  
2024  
2025

1944  
1945  
1946  
1947  
1948  
1949  
1950  
1951  
1952  
1953  
1954  
1955  
1956  
1957  
1958  
1959  
1960  
1961  
1962  
1963  
1964  
1965  
1966  
1967  
1968  
1969  
1970  
1971  
1972  
1973  
1974  
1975  
1976  
1977  
1978  
1979  
1980  
1981  
1982  
1983  
1984  
1985  
1986  
1987  
1988  
1989  
1990  
1991  
1992  
1993  
1994  
1995  
1996  
1997  
1998  
1999  
2000  
2001  
2002  
2003  
2004  
2005  
2006  
2007  
2008  
2009  
2010  
2011  
2012  
2013  
2014  
2015  
2016  
2017  
2018  
2019  
2020  
2021  
2022  
2023  
2024  
2025

U.S. Nuclear Regulatory Commission  
B12969/Page 2  
July 18, 1988

22F, respectively. The "B" pump is an installed spare which can be aligned to either emergency bus.

The charging pumps are normally aligned to take suction from the VCT. Upon receipt of a safety injection actuation signal (SIAS), suction is transferred from the VCT to the boric acid storage tanks (BASTs). The VCT is isolated by a gate valve (2-CH-501) and a check valve (2-CH-118). Fluid from the BASTs is delivered to the charging pump suction by either of two boric acid transfer pumps or a gravity feed (valve 2-CH-508 or 2-CH-509) from each of the two tanks.

Both boric acid transfer pumps are on emergency electrical bus 22F (MCC B61) and valves 2-CH-501, 2-CH-508, and 2-CH-509 are on emergency bus 22E (MCC B51). Therefore, if bus 22E (MCC B31) were to fail or valve 2-CH-501 were to fail to close, the discharge pressure of the boric acid transfer pumps would hold check valve 2-CH-118 in the closed position and effectively isolate the VCT. Conversely, if bus 22F (MCC B61) were to fail, both boric acid transfer pumps will fail to start. However, valve 2-CH-501 will close on SIAS and valves 2-CH-508 and 2-CH-509 will open to provide the path from BASTs to the charging pump suction. The charging pumps are not required during sump recirculation nor are they required once the water supply in the BASTs is exhausted. It has therefore been concluded that the Millstone Unit No. 2 charging system is not subject to a limiting single failure similar to the recently identified problem at the Haddam Neck Plant.

### Millstone Unit No. 3

Emergency core cooling for Millstone Unit No. 3 is accomplished by the centrifugal charging (CHS), safety injection (SI), and residual heat removal (RHS) pumps, accumulators, containment recirculation (CR) pumps, CR coolers, RHS heat exchangers, and the refueling water storage tank (RWST), along with the associated piping, valves, instrumentation, and other related equipment as applicable. Among the ECCS functions is the automatic delivery of borated water to the reactor vessel for cooling the core following a loss-of-coolant accident (LOCA). In the case of the charging system, delivery of water to the core occurs by transferring charging pump suction from the VCT to the RWST. Specifically, on a safety injection signal (SIS), the normal charging supply from the VCT is isolated by two series isolation valves (3CHS\*LCV112B and C) and two normally closed (3CHS\*LCV112D and E), parallel, motor-operated gate valves open to align the RWST to the charging pump suction. These valves (3CHS\*LCV112D and E) stay open until the operator realigns the system for the recirculation phase of ECCS operation. A failure mode and effects analysis is presented in the Millstone Unit No. 3 FSAR Table 6.3-10. This analysis demonstrates that not only this portion of ECCS can sustain the failure of any single active component, but overall ECCS can sustain the failure of any single active component in either the short or long term and still meet the level of performance for core cooling.

U.S. Nuclear Regulatory Commission  
B12969/Page 3  
July 18, 1988

In summary, the Millstone Unit Nos. 2 and 3 charging systems are not subject to a potential single-failure vulnerability similar to the recently identified problem at the Haddam Neck Plant.

If there are any questions regarding this submittal, please contact our licensing representative directly.

Very truly yours,

NORTHEAST NUCLEAR ENERGY COMPANY

  
\_\_\_\_\_  
E. J. Mroczka  
Senior Vice President

cc: W. T. Russell, Region I Administrator  
D. H. Jaffe, NRC Project Manager, Millstone Unit Nos. 2 and 3  
W. J. Raymond, Senior Resident Inspector, Millstone Unit Nos. 1, 2, and 3