

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8912210037 DOC. DATE: 89/12/15 NOTARIZED: YES DOCKET #
 FACIL: 50-335 St. Lucie Plant, Unit 1; Florida Power & Light Co. 05000335
 AUTH. NAME AUTHOR AFFILIATION
 GOLDBERG, J.H. Florida Power & Light Co.
 RECIP. NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Application for amend to License DPR-67, revising TS re electrical power sys - AC sources.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 3+37
 TITLE: OR Submittal: General Distribution

NOTES:


| | RECIPIENT | | COPIES | | | RECIPIENT | | COPIES | |
|-----------|-----------------|--|--------|------|--|-----------------|--|--------|------|
| | ID CODE/NAME | | LTTR | ENCL | | ID CODE/NAME | | LTTR | ENCL |
| | PD2-2 LA | | 1 | 1 | | PD2-2 PD | | 1 | 1 |
| | NORRIS, J | | 5 | 5 | | | | | |
| INTERNAL: | ACRS | | 6 | 6 | | NRR/DET/ECMB 9H | | 1 | 1 |
| | NRR/DOEA/OTSB11 | | 1 | 1 | | NRR/DST 8E2 | | 1 | 1 |
| | NRR/DST/SELB 8D | | 1 | 1 | | NRR/DST/SICB 7E | | 1 | 1 |
| | NRR/DST/SRXB 8E | | 1 | 1 | | NUDOCS-ABSTRACT | | 1 | 1 |
| | OC/LFMB | | 1 | 0 | | OGC/HDS2 | | 1 | 0 |
| | REG FILE 01 | | 1 | 1 | | RES/DSIR/EIB | | 1 | 1 |
| EXTERNAL: | LPDR | | 1 | 1 | | NRC PDR | | 1 | 1 |
| | NSIC | | 1 | 1 | | | | | |

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 27 ENCL 25

R
I
D
S
/
A
D
D
S
/
A
D
D
S





DECEMBER 15 1989

L-89-406
10 CFR 50.90

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

Gentlemen:

Re: St. Lucie Unit 1
Docket No. 50-335
Proposed License Amendment
Electrical Power Systems - A. C. Sources

In accordance with 10 CFR 50.90, Florida Power & Light Company (FPL) submits herewith a request to amend Facility Operating Licensing DPR-67 for St. Lucie Unit 1.


On July 2, 1984, the NRC issued Generic Letter (GL) 84-15 "Proposed Staff Actions to Improve and Maintain Diesel Generator Reliability" which presented NRC recommendations regarding improvements to the Technical Specifications to enhance diesel generator reliability. As a result of GL 84-15, and subsequent discussions related to Technical Specification improvements for emergency diesel generators for St. Lucie Unit 2, FPL submits the enclosed. This proposed license amendment will make the St. Lucie Unit 1 Technical Specifications for "Electrical Power Systems, A. C. Sources" similar to the St. Lucie Unit 2 Technical Specifications.

Marked up copies of the affected Technical Specifications pages are included as Attachment 1. A Safety Analysis in support of the proposed amendment is included as Attachment 2. A "Determination of No Significant Hazards Consideration" is provided as Attachment 3.

The proposed amendment has been reviewed by the St. Lucie Facility Review Group and the Florida Power & Light Company Nuclear Review Board.

8912210037 891215
PDR ADOCK 05000335
P PDC

A001
111



U. S. Nuclear Regulatory Commission
L-89-406
Page two

In accordance with 10 CFR 50.9(b)(1), a copy of the proposed amendment is being forwarded to the state designee for the State of Florida.

If additional information is required on this topic, please contact us.

Very truly yours,



J. H. Goldberg
Executive Vice President

JHG/EJW/gp

Attachments

cc: Stewart D. Ebnetter, Regional Administrator, Region II, USNRC
Senior Resident Inspector, USNRC, St. Lucie Plant
Mr. Jacob D. Nash, Florida Department of Health and
Rehabilitative Services

STATE OF FLORIDA)
)
COUNTY OF PALM BEACH) ss.

J. H. Goldberg being first duly sworn, deposes and says:


That he is an Executive Vice President, of Florida Power & Light Company, the Licensee herein;

That he has executed the foregoing document; that the statements made in this document are true and correct to the best of his knowledge, information and belief, and that he is authorized to execute the document on behalf of said Licensee.



J. H. Goldberg

Subscribed and sworn to before me this
15 day of December, 1989.



NOTARY PUBLIC, in and for the County of
Palm Beach, State of Florida

My Commission expires _____
Notary Public, State of Florida
My Commission Expires June 1, 1993
Bonded Thru Troy Fain - Insurance Inc.